



Rule 1109.1 – NOx Emission Reduction for Refinery Equipment and Related Operations

Working Group Meeting #17

February 4, 2021

Join Zoom Meeting

<https://scaqmd.zoom.us/j/98588912973>

Meeting ID: 985 8891 2973

Password: 076494

Teleconference Dial-In: +1 669 900 6833

Agenda

2

- Progress of Rule Development
- Comments from Working Group Meeting #16
- Follow-up on Boilers <40 MMBtu/hour
- Co-Pollutant Discussion
- Rule Language Updates Released on 12/24/20
- Clear Sign Presentation
- Next Steps

Progress of Rule Development

3

Summary of Working Group # 16 (12/10/20)

- Provided response to stakeholder's comments on CO limits and CEMS
- Consultants presented their findings and final report released
- Provided response to consultant's report
- Presented revised BARCT Compliance Alternative Plan (B-CAP)

Since Last Working Group Meeting

- Released second version of rule language based on stakeholder feedback
- Followed up with consultants regarding recommendations
- Meeting with facilities to discuss specific BARCT Compliance Alternative Plan (B-CAP)
- Continued meetings with control technology manufacturers

Key Comments From WGM #16

4

Comment #1: Installation of ultra-low NOx burners (ULNB)

- Not feasible for all units
- Based on Norton's Report, some ULNB applications may only achieve 50 ppmv; therefore, 2 ppmv may not be technically feasible even with 95% reduction from SCR


Comment #2: Superficial velocity of the flue gas must be evaluated when assessing the BARCT limits

Comment #3: Fuel NOx must be considered for the SRU/TG Incinerator

- Fuel NOx contributes to overall NOx emissions

Comment #1: Installation of ultra-low NOx burners (ULNB)

5

- For boilers and heaters >40 MMBtu/hr, staff proposed a 2 ppmv NOx limit based on a combination of ULNB and SCR
 - Typical ULNB achieve between 30 to 40 ppmv NOx
 - SCR can achieve 95% NOx reductions

Combination can achieve 2 ppmv
- Stakeholders stated not all units can be retrofit with ULNB and therefore 2 ppmv is not technically feasible even with 95% reduction from SCR

Comment #1: Installation of ultra-low NOx burners (ULNB)


(cont.)

6


- Staff consulted with Norton, FERCo, and SCR catalyst vendors regarding the feasibility of installing ULNB and achieving 2 ppmv NOx for units with sub-optimal conditions
- Consultants stated that regardless of ULNB NOx performance, 2 ppmv is feasible by installing multiple catalyst reactors or a two-stage SCR reactor
 - Multiple ammonia injection grids (AIG) in between each reactor or a reactor designed to achieve proper distribution and mixing
 - Static mixer in between each bed or SCR reactor (two stage arrangement)
- According to SCR vendor, two-stage reactors are typically employed in nitric acid plants where NOx can be up to 4,000 ppmv

Options for Achieving Proposed NOx Limit


7



1) SCR Only (90-95% NOx reduction)



2) ULNB + SCR (>95% NOx reduction)



3) Two-Stage Reactor SCR without ULNB (>95% NOx reduction)

Cost Assessment for Multiple Reactor SCR

8

- Consultants and SCR vendor stated the additional reactor would contribute an additional ~25% to the cost of the SCR
 - Additional piping for the ammonia injections and catalyst (capital)
 - Additional cost for the catalyst replacement and ammonia (O&M)
- Staff re-assessed the cost-effectiveness of boilers and heaters greater than 40 MMBtu/hr
 - Increasing costs 25% for multiple reactors and removing the cost for the ULNBs
 - Adding \$40,000/year for SCR tuning as recommended by FERCo
- Revised cost-effectiveness will follow the superficial velocity discussion

Comment #2: Superficial velocity of the flue gas must be evaluated when assessing the BARCT limits

9

- Superficial velocity is a design parameter that sets the size of the catalyst bed and plot area for the SCR
 - Superficial velocity is the volumetric rate of the flue gas divided by the front-face area of the catalyst
- Lower superficial velocity equals a greater NO_x reduction but requires a bigger catalyst inventory, increasing cost and plot space
- Vendors recommended 10 ft/s or lower at the inlet to the SCR to achieve maximum NO_x reductions
- Superficial velocity can be reduced by increasing the catalyst volume

Comment #2: Superficial velocity of the flue gas must be evaluated when assessing the BARCT limits (cont.)

10

- Staff consulted with Norton, FERCo, and SCR catalyst vendors regarding how to address superficial velocity concerns
 - Norton recommended increasing the catalyst volume by 30% to address units that may require additional catalyst volume to slow the flue gas velocity
 - 30% catalyst volume increase was confirmed by FERCo and SCR catalyst vendors to be effective for this purpose
- Staff accounted for a 30% increase in the catalyst costs to address the potential need for increased catalyst volume
 - Catalyst costs are a minor cost of the overall SCR (5% of the TIC)

10

Staff's Revised Cost Assumptions base

11

- Initial costs based on U.S. EPA spreadsheet staff altered costs as follows:
 - ✓ Amended U.S. EPA spreadsheet with costs refineries provided to reflect costs at California refinery costs
 - ✓ Used stakeholder costs when available, otherwise used amended U.S. EPA spreadsheet
 - ✓ Added cost of ULNB if percent reduction exceeded 92% - burner costs estimated using curve generated from costs refineries provided
 - ✓ Alternatively, conducted cost assessment for installation of dual reactors
 - ✓ 25% increase to TIC to address additional costs
 - ✓ Added \$40,000 annual costs for SCR tuning – based on Ferco recommendation
 - ✓ Added 30% increased cost for the catalyst based on Norton recommendation to account for gas velocity
- Cost for SCR installation estimated ~ \$10 to \$80 million (present worth value)

Reassessment of Cost-Effectiveness for SCR Based on Consultant and Vendor Feedback

12

SCR Cost-Effectiveness Reassessment

SCR Design Parameter	Cost Increase	Comments
Catalyst Increase	30% of Catalyst Cost	Addresses the potential need of additional catalyst
Multiple Stage Reactor with additional AIG or Static Mixer	25% of Total Installed Cost (TIC)	Addresses potential cost increase of additional catalyst, reactor, and installation
Increased O&M	25% of O&M	Addresses potential increase in ammonia consumption and electricity needed for larger fan associated with multiple beds of reactors
Annual Tuning	Additional \$40K added to annual O&M Costs	Addresses the proper mixing and distribution

Revised Cost Effectiveness for 2 ppmv NOx Limits

13

Original and Revised Cost-Effectiveness

Equipment Class	NOx Limit	ULNB/SCR	Dual Reactor
Heaters 40 – 110 MMBtu/hr	2 ppmv	\$35,000	\$39,000
Heaters >110 MMBtu/hr	2 ppmv	\$35,000	\$44,000
Boilers 40 – 110 MMBtu/hr	2 ppmv	\$49,000	\$48,000
Boilers >110 MMBtu/hr	2 ppmv	\$12,000	\$15,000

Staff's Recommendation:

- 2 ppmv NOx limit is technically achievable and cost-effective
- Several technologies are available to achieve 2 ppmv limit

Comment #3: Fuel NOx must be considered for the SRU/TG Incinerator

14

- Stakeholder commented the source of NOx for these units can be from fuel NOx in addition to thermal NOx
 - Most NOx formed in combustion equipment is thermal NOx or prompt NOx which are both controlled by the burner
 - Units that combust fuel that contains nitrogen containing components will also produce fuel NOx which cannot be controlled by the burner
- SRU/TG Incinerators combust nitrogen containing fuel which will generate fuel NOx
 - Retrofitting with ULNBs will not address fuel NOx
- Staff consulted with Norton who suggested longer averaging times (365-day rolling average) to address any NOx spikes formed by fuel NOx
- Staff seeking input from stakeholders

**Follow-up on Boilers
<40 MMBtu/hr**

BARCT Assessment for Boilers <40 MMBtu/hr

16

- Stakeholder inquired about a low-use exemption for boilers <40 MMBtu/hr
 - Low-use exemptions can be included for units that have very high cost-effectiveness
- For these units, *first draft* of rule included a provision that the burners would have to be replaced within 10 years of rule adoption or at the end of useful life, whichever was sooner
- None of the boilers <40 MMBtu/hr were cost effective to replace burners until burner replacement
 - Requiring burner replacement within 10 years of rule adoption may precede routine burner replacement cycle


BARCT Assessment for Boilers <40 MMBtu/hr (cont.)

17

Original cost-effectiveness analysis assumed:

Burner replacement at the end of useful life


No or minimal additional costs since burner already being replaced



Staff revisited assumptions:

10 years deadline in first version of PR 1109.1 may not represent end of useful life

John Zink stated the 5 ppmv burners will cost 25 – 40% more than a traditional 9 ppmv burner



Staff reassessed the BARCT approach for this class/category

BARCT Assessment for Boilers <40 MMBtu/hr (cont.)

18

- Four boilers in this class/category
- All fueled with natural gas boilers and operate between 9 ppmv and 30 ppmv
- One boiler is low-use where cost-effectiveness would be > \$1 million
- Staff re-evaluated cost-effectiveness based on 40% higher cost for 5 ppmv burner replacement (~\$4 million/burner)

Boilers <40 MMBtu/hr	Prior to Burner Replacement	At Burner Replacement
Original Cost Effectiveness	\$120,000	No Additional Cost
Revised Cost Effectiveness	\$170,000	\$36,000*
* Excludes Low-Use Unit		

Staff's Recommendation:

- ULNB to achieve 5 ppmv at burner replacement
- Remove the 10-year replacement requirement in PR 1109.1
- Low-use exemption (200 hours/year) for boilers <40 MMBtu/hr with 9 ppmv permit limit


Co-Pollutant Discussion

19

Co-Pollutant Background – BACT Applicability

20


- Rulemaking discussions for Proposed Rule 1109.1 have highlighted that installations of Selective Catalytic Reduction (SCR) to control NO_x emissions from a refinery boiler or heater can result in secondary particulate matter (PM) emissions
- Under Regulation XIII, emission increases exceeding the NSR threshold would require BACT, modeling, and offsetting for PM₁₀
 - Regulation XIII threshold for PM₁₀ is one pound per day



Co-Pollutant Issue Significance

21

- Staff has been working with CARB and U.S. EPA on different strategies to address the co-pollutant issue
- PR 1109.1 will be the most significant command-and-control rule to address NOx emissions
 - NOx emission reduction potential is substantial (7 to 9 tons per day)
- NOx reductions from implementing PR 1109.1 is staff's priority in order to attain federal and state ozone standards
 - South Coast Air Basin is in extreme non-attainment for the federal ozone standard



Proposed Co-pollutants Strategy

22

- Other California air districts have provisions that exempt sources from BACT when complying with a BARCT requirement
- Staff is proposing a similar but narrower BACT exemption that:
 - Will be limited to projects needed to transition from RECLAIM to command-and-control
 - Will be limited to a rule that establishes BARCT emission limits for an ozone precursor where the project is “solely the addition” of air pollution control equipment
 - *Will not apply to additional improvements, upgrades, or capacity increases that are included as part of the installation of the air pollution control equipment*
 - Will be limited to non-ozone precursor emission increases that are below the federal NSR thresholds
 - Will not apply to ammonia emissions associated with installation of SCR



Further discussion
in next Working
Group Meeting

Co-Pollutant Strategy Summary

23

- Staff is proposing a BACT exemption for non-ozone precursor emission increases associated with air pollution control equipment installations to comply with NOx BARCT standards
- Staff worked with CARB and U.S. EPA to develop the proposed strategy
 - CARB is supportive of the co-pollutant strategy
 - U.S. EPA agrees that BACT is not triggered unless federal thresholds are exceeded
 - For major sources over 70 tons per year, the major modification thresholds are 15 ton per year for PM10 and 10 tons per year for PM2.5
- Proposed Amendment to Rule 1304 scheduled for June 2021
- Staff will address refinery fuel sulfur content during the transition of SOx RECLAIM
- More details provided in the RECLAIM/NSR presentation on January 21st, 2021
<http://www4.aqmd.gov/enewsletterpro/uploadedimages/000001/Vo/RECLAIM%20-%20WGM%2001-21-2021%20%20Final.pdf>

**Rule Language Updates Released on
12/24/20**

Subdivision (d) – Emission Limits

25

- Averaging Time was increased from 8-hours to 24-hours for the following equipment based on consultant feedback:
 - Boilers (≥ 40 MMBtu/hr)
 - Gas Turbines
 - Process Heaters (≥ 40 MMBtu/hr)
 - SRU/TG Incinerators
 - SMR Heaters
 - SMR Heater with Gas Turbine
- Excluding emissions measurements during the start-up, shutdown, and malfunction events when calculating the applicable Table 1 rolling average NO_x and CO emissions
- Removed CO CEMS requirement but must maintain if already installed

Subdivision (e) – Start-up, Shutdown and Malfunction (SSM)

- Added SSM limits for all units
- Removed requirement to submit planned start-up/shutdown schedule
- Revised to include recordkeeping requirements instead of reporting requirements
- Added requirements for the best engineering practices to minimize SSM

TABLE 2: START-UP, SHUTDOWN, MALFUNCTION ALLOWANCES

Unit	Not to Exceed per Start-up, Shutdown, or Malfunction Event (hours)
<ul style="list-style-type: none"> • Boilers and Process Heaters <40MMBtu/hour • Gas Turbines • Flares • Vapor Incinerators 	2
<ul style="list-style-type: none"> • Sulfuric Acid Furnace 	24
<ul style="list-style-type: none"> • Boilers and Process Heaters ≥40MMBtu/hour • Steam Methane Reformer Heaters 	48
<ul style="list-style-type: none"> • Steam Methane Reformer with Gas Turbine 	60
<ul style="list-style-type: none"> • FCCUs • Petroleum Coke Calciner • SRU/TG Incinerators 	120

Subdivision (e) – Start-up, Shutdown and Malfunction (SSM)

27

- Staff considering addressing SSM in separate rule
 - Rule 429 - Start-up And Shutdown Exemption Provisions For Oxides Of Nitrogen (adopted 1989, last amended 1990)
 - PAR 429 would be considered at the same time as PR 1109.1
 - Would include SSM provisions for PR 1109.1 sources and other combustion sources
 - Streamline rule provisions
 - Similar approach to Rule 430 – Breakdown Provisions

Subdivision (f) – CEMS Requirements

28

- Included requirement for SRU/TG Incinerators to install and maintain CEMS (*inadvertently omitted in the initial draft*)
- Omitted the requirement for calculating missing data due to a non-operational CEMS
- Removed requirement to install CO CEMs
 - Included provision to require existing CO CEMS to be operated and maintained
- Revised new requirements for Sulfuric Acid Furnace:
 - NO_x CEMS in operation at the time of rule adoption
 - Revised O₂ CEMS requirement to allow 12 months for installation

Subdivision (g) & (h) – Source Test Requirements & Diagnostic Emission Checks

- Updated Source Testing Schedule to remove SRU/TG Incinerators – included in CEMS requirements
- Updated source test schedule for a unit that has not conducted a source test within the schedule in Table 3:
 - 20 – <40 MMBtu/hr: 6 months from date of rule adoption
 - <20 MMBtu/hr: 12 months from date of rule adoption
- Revised requirements for Diagnostic Emission Checks from every 30 days to every 90 days

TABLE 3: SOURCE TESTING SCHEDULE

Combustion Equipment	Rated Heat Input Capacity (MMBtu/hour)	Source Test Schedule
Boilers and Process Heaters	<40	Within 12 months from previous source test and every 12 months thereafter
Vapor Incinerators and Flares	All	Within 36 months from previous source test and every 36 months thereafter

Subdivision (i) – Monitoring, Recordkeeping and Reporting (MRR) Requirements

30

- Added MRR provisions for the process heater, boiler or flare that is exempt from emission limits pursuant to section (I)
 - Install and operate a non-resettable totalizing time meter or a fuel meter for the exempt equipment in section (I) within 90 days of rule adoption date:
 - Must be equipped with a permanent supply of electric power that cannot be unplugged, switched off, or reset except by the main power supply circuit for the building and associated equipment or the safety shut-off switch, only for maintenance or safety
 - Must be calibrated, and recalibrated annually thereafter, based on the manufacturer's recommended procedures or an alternative calibration method approved in writing by the Executive Officer

Subdivision (j) – Compliance Schedule

31

- Removed the requirement to replace burners within 10 years for boilers less than 40 MMBtu/hour based on revised BARCT assessment
- Added a provision to require facilities that exceed the low-use exemptions (e.g., 200 hours for start-up heaters at FCCU and start-up or shutdown boilers or heaters used at sulfuric acid plants) to meet the emissions limits within 6 months of surpassing the low-use limits

Subdivision (k) – BARCT Compliance Alternative Plan

- Extended B-CAP Schedule as previously discussed in Working Group #16 Meeting

TABLE 4: B-CAP IMPLEMENTATION SCHEDULE

	Phase I	Phase II	Phase III
Permit Application Submittal Deadline	July 1, 2022	July 1, 2024	July 1, 2026
Implementation and Final Compliance Date	30 months after a Permit to Construct is issued	24 months after a Permit to Construct is issued	24 months after a Permit to Construct is issued

Subdivision (I) - Exemptions

33

- Removed exemption for heaters less than 40 MMBtu/hour from meeting the 30 ppmv interim NOx limit
 - 30 ppmv limit was removed based on Norton's feedback
- Included exemption for FCCU from meeting Table 1 emission limits during required boiler inspections
- Included a low-use exemption (less than 200 hours annual) for boilers less than 40 MMBtu/hour
- Included exemption for boiler or process heater operating only the pilot during start-up or shutdown

Clear Sign Presentation

34

Next Steps

Continuing Meetings with Facilities on B-CAP

Working Group Meeting #17 to Discuss Comment Letters -
February 11th

Provide Update to Stationary Source Committee -
February 19th

Continue Meetings with Stakeholders

Release Preliminary Draft Staff Report and Rule Language

Public Workshop

Public Hearing

Rule 1109.1 Staff Contacts

36

Michael Krause
Planning & Rules Manager
mkrause@aqmd.gov
909.396.2706

Heather Farr
Program Supervisor
hfarr@aqmd.gov
909.396.3672

Sarady Ka
AQ Specialist
ska@aqmd.gov
909.396.2331

Mojtaba Moghani, Ph.D.
AQ Specialist
mmoghani@aqmd.gov
909.396.2527

Zoya Banan, Ph.D.
AQ Specialist
zbanan@aqmd.gov
909.396.2332



RECLAIM Staff Contacts

37

Michael Morris
Planning & Rules Manager
mmorris@aqmd.gov
909.396.3282

Gary Quinn, P.E.
Program Supervisor
gquinn@aqmd.gov
909.396.3121

