

BOARD MEETING DATE: November 3, 2023

AGENDA NO. 22

PROPOSAL: Determine that Proposed Rule 1110.3 – Emissions from Linear Generators and Proposed Amended Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines, are Exempt from CEQA; and Adopt Rule 1110.3 and Amend Rule 1110.2

SYNOPSIS: Proposed Rule 1110.3 will establish NOx, CO, and VOC emission limits for linear generators, as well as provisions for source testing, monitoring, reporting, and recordkeeping. Proposed Amended Rule 1110.2 will be amended to exclude linear generators from the applicability and requirements.

COMMITTEE: Stationary Source, February 17, September 15 and October 20, 2023, Reviewed

RECOMMENDED ACTIONS:

Adopt the attached Resolution:

1. Determining that Proposed Rule 1110.3 – Emissions from Linear Generators and Proposed Amended Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines, are exempt from the requirements of the California Environmental Quality Act; and
2. Adopting Rule 1110.3 – Emissions from Linear Generators and Amending Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines

Wayne Natri
Executive Officer

SR:MK:MM:IS:HL

Background

Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines is a source-specific rule which applies to engines greater than 50 rated brake horsepower and was last amended in 2019. During the rule amendment process, emission limits for linear generators were included and stakeholders commented on the unique characteristics of

linear generators. Unlike internal combustion engines (ICEs), linear generators produce electricity by driving magnets through copper coils in a linear motion. One unique feature of linear generators is that the thermochemical reaction takes place at lower temperatures than ICEs, which results in lower NOx emissions without an add-on control device such as selective catalytic reduction. In response to stakeholder comments, Proposed Rule 1110.3 – Emissions from Linear Generators (PR 1110.3), was developed to allow for specific considerations of the technology and capabilities of linear generators.

Public Process

The development of PR 1110.3 and Proposed Amended Rule 1110.2 (PAR 1110.2) was conducted through a public process. A Working Group was formed that included facility representatives, equipment manufacturers, other agencies, community and environmental groups, and other interested parties. Three Working Group meetings were held to discuss rule concepts on November 9, 2022, December 8, 2022, and February 23, 2023. A Public Workshop was held on January 25, 2023.

Proposal

PR 1110.3 applies to linear generators fueled solely by natural gas and establishes NOx, CO, and VOC emission limits for linear generators as well as source testing, monitoring, reporting, and recordkeeping requirements. PR 1110.3 contains a reduced source testing frequency that will reduce source testing costs by approximately 60 percent compared to Rule 1110.2. In addition, facilities with six or more units may elect to conduct pooled source testing to further alleviate costs. PAR 1110.2 will be amended to exclude linear generators from the applicability and requirements.

Key Issues

Throughout the rulemaking process, staff worked with stakeholders to resolve key issues. Staff is not aware of any remaining key issues.

California Environmental Quality Act

Pursuant to the California Environmental Quality Act (CEQA) Guidelines Sections 15002(k) and 15061, the proposed project (PR 1110.3 and PAR 1110.2) is exempt from CEQA pursuant to CEQA Guidelines Section 15061(b)(3). A Notice of Exemption has been prepared pursuant to CEQA Guidelines Section 15062 and is included as Attachment I to this Board Letter. If the proposed project is approved, the Notice of Exemption will be filed for posting with the county clerks of Los Angeles, Orange, Riverside, and San Bernardino counties, and with the State Clearinghouse of the Governor's Office of Planning and Research.

Socioeconomic Impact Assessment

Implementation of PR 1110.3 and PAR 1110.2 will not result in any significant changes in air quality or emission limitations. Therefore, a socioeconomic impact assessment per Health and Safety Code Sections 40440.8 and 40728.5 is not required. PR 1110.3 and PAR 1110.2 would result in a cost savings to affected facilities due to a reduced source testing frequency and are not expected to result in any adverse socioeconomic impacts.

Resource Impacts

Based on current trends, staff estimates that approximately 400 new and additional permit applications are expected to be submitted in the next two years due to the expected growth of the linear generator industry. Conservative estimates of increased workload would require at least one additional full-time Air Quality Engineer which is being requested in the upcoming budget.

Attachments

- A. Summary of Proposal
- B. Key Issues and Responses
- C. Rule Development Process
- D. Key Contacts List
- E. Resolution
- F. Proposed Rule 1110.3
- G. Proposed Amended Rule 1110.2
- H. Final Staff Report
- I. Notice of Exemption from CEQA
- J. Board Presentation

ATTACHMENT A
SUMMARY OF PROPOSAL

Proposed Rule 1110.3
Emissions from Linear Generators

Applicability

- Linear generators fueled solely by natural gas are subject to this rule

Emission Limits

- Establishes NO_x, CO, and VOC concentration limits for linear generators

Maintenance Requirements

- Maintenance per manufacturer's recommendations
- Requires a copy of the operating and maintenance manual to be kept and made available

Monitoring, Recordkeeping, and Reporting

- Requires a net output meter and parametric monitoring system
- Establishes requirements for inspection and maintenance of parametric monitoring system per manufacturer's recommendations
- Requires records to be kept for a period of five years and made available to staff
- Source tests required every five years
- Option for pooled source testing every three years for facilities with six or more units
- Diagnostic emissions checks required every two years
- Source test results must be submitted to Executive Officer

Exemptions

- Exemptions for laboratory units, emergency units, and units used for fire-fighting and flood control

**Proposed Amended Rule 1110.2
Emissions from Gaseous- and Liquid-Fueled Engines**

Definitions

- Modifies the definition of engine to exclude linear generators
- Creates a definition for linear generators

Requirements

- Removes NO_x, CO, and VOC concentration limits from Table IV, which were included for linear generators
- Removes interim provision allowing 25 ppmvd VOC for linear generators

Inspection and Monitoring (I&M) Requirements

- Remove accommodations for I&M Plan flexibility, which were included for linear generators

Exemptions

- Clarify language for equipment located at landfills or publicly owned treatment works

ATTACHMENT B

KEY ISSUES AND RESPONSES

Proposed Rule 1110.3 – Emissions from Linear Generators


Proposed Amended Rule 1110.2 – Emissions from Gaseous- And Liquid Fueled Engines

Throughout the rulemaking process, staff worked with stakeholders to resolve key issues. Staff is not aware of any remaining key issues.

ATTACHMENT C
RULE DEVELOPMENT PROCESS

Proposed Rule 1110.3
Emissions from Linear Generators

Proposed Amended Rule 1110.2
Emissions from Gaseous- and Liquid-Fueled Engines



Thirteen (13) months spent in rule development
One (1) Public Workshop
Three (3) Stationary Source Committee Meetings
Three (3) Working Group Meetings

ATTACHMENT D

KEY CONTACTS LIST

**Proposed Rule 1110.3
Emissions from Linear Generators**

**Proposed Amended Rule 1110.2
Emissions from Gaseous- And Liquid-Fueled Engines**

Benz Air Engineering Co.

Bioenergy Association of California

California Hydrogen Business Council

Clean Water SoCal

Coalition for Clean Air

Hyllion Inc

Mainspring Energy, Inc.

Prologis

Southern California Alliance of Publicly Owned Treatment Works

Southern California Gas Company

Yorke Engineering

ATTACHMENT E

RESOLUTION NO. 23-_____

A Resolution of the Governing Board of the South Coast Air Quality Management District (South Coast AQMD) determining that Proposed Rule 1110.3 – Emissions from Linear Generators and Proposed Amended Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines, are exempt from the requirements of the California Environmental Quality Act (CEQA).

A Resolution of the South Coast AQMD Governing Board adopting Rule 1110.3 – Emissions from Linear Generators and amending Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines.

WHEREAS, the South Coast AQMD Governing Board finds and determines that Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 are considered a “project” as defined by CEQA; and

WHEREAS, the South Coast AQMD has had its regulatory program certified pursuant to Public Resources Code Section 21080.5 and CEQA Guidelines Section 15251(l) and has conducted a CEQA review and analysis of the proposed project pursuant to such program (South Coast AQMD Rule 110); and

WHEREAS, the South Coast AQMD Governing Board finds and determines after conducting a review of the proposed project in accordance with CEQA Guidelines Section 15002(k) – General Concepts, the three-step process for deciding which document to prepare for a project subject to CEQA, and CEQA Guidelines Section 15061 – Review for Exemption, procedures for determining if a project is exempt from CEQA, that the proposed project is exempt from CEQA; and

WHEREAS, the South Coast AQMD Governing Board finds and determines that, because the proposed project transfers existing requirements from Rule 1110.2 into Proposed Rule 1110.3, and contains other revisions in Proposed Amended Rule 1110.2 to improve clarity and enforceability without requiring physical modifications, it can be seen with certainty that implementing the proposed project would not cause a significant adverse effect on the environment, and is therefore exempt from CEQA pursuant to CEQA Guidelines Section 15061(b)(3) – Common Sense Exemption; and

WHEREAS, the South Coast AQMD staff has prepared a Notice of Exemption for the proposed project that is completed in compliance with CEQA Guidelines Section 15062 – Notice of Exemption; and

WHEREAS, Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 and supporting documentation, including but not limited to, the Notice of Exemption and Final Staff Report, were presented to the South Coast AQMD Governing Board and the

South Coast AQMD Governing Board has reviewed and considered this information, as well as has taken and considered staff testimony and public comment prior to approving the proposed project; and

WHEREAS, the South Coast AQMD Governing Board finds and determines, taking into consideration the factors in Section (d)(4)(D) of the Governing Board Procedures (Section 30.5(4)(D)(i) of the Administrative Code), that no modifications have been made to the proposed project since the Notice of Public Hearing was published that are so substantial as to significantly affect the meaning of Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 within the meaning of Health and Safety Code Section 40726 because: (a) the changes do not significantly impact emission reductions, (b) the changes do not affect the number or type of sources regulated by the rules, (c) the changes are consistent with the information contained in the Notice of Public Hearing, and (d) the consideration of the range of CEQA alternatives is not applicable because the proposed project is exempt from CEQA; and

WHEREAS, Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 will be submitted for inclusion into the State Implementation Plan; and

WHEREAS, Health and Safety Code Section 40001(c) requires that prior to adopting any rule or regulation to reduce criteria pollutants, a district shall determine that there is a problem that the proposed rule or regulation will alleviate and that the rule or regulation will promote the attainment or maintenance of state or federal ambient air quality standards; and

WHEREAS, the South Coast AQMD Governing Board finds that there is an ozone problem that Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 will alleviate and will promote the attainment or maintenance of both the state and federal ambient air quality standards for ozone; and

WHEREAS, Health and Safety Code Section 40727 requires that prior to adopting, amending or repealing a rule or regulation, the South Coast AQMD Governing Board shall make findings of necessity, authority, clarity, consistency, non-duplication, and reference based on relevant information presented at the Public Hearing and in the Final Staff Report; and

WHEREAS, the South Coast AQMD Governing Board has determined that a need exists to adopt Proposed Rule 1110.3 to establish oxides of nitrogen (NO_x), carbon monoxide (CO), and volatile organic compound (VOC) emission limits for linear generators, as well as provisions for source testing, monitoring, reporting, and recordkeeping; and

WHEREAS, the South Coast AQMD Governing Board has determined that a need exists to amend Rule 1110.2 to exclude linear generators from applicability and requirements; and

WHEREAS, the South Coast AQMD Governing Board obtains its authority to adopt, amend, or repeal rules and regulations from Health and Safety Code Sections 39002, 40000, 40001, 40440, 40702, and 40725 through 40728; and

WHEREAS, the South Coast AQMD Governing Board has determined that Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 are written and displayed so that their meanings can be easily understood by persons directly affected by them; and

WHEREAS, the South Coast AQMD Governing Board has determined that Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 are in harmony with, and not in conflict with or contradictory to, existing statutes, court decisions, or state or federal regulations; and

WHEREAS, the South Coast AQMD Governing Board has determined that Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 do not impose the same requirements as any existing state or federal regulations, and Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 are necessary and proper to execute the powers and duties granted to, and imposed upon, the South Coast AQMD; and

WHEREAS, the South Coast AQMD Governing Board, in adopting Proposed Rule 1110.3 and Proposed Amended Rule 1110.2, references the following statute which the South Coast AQMD hereby implements, interprets or makes specific: Health and Safety Code Sections 39002, 40000, 40001, 40440(a), 40702, 40725 through 40728.5; and the federal Clean Air Act; and

WHEREAS, Health and Safety Code Section 40727.2 requires the South Coast AQMD to prepare a written analysis of existing federal air pollution control requirements applicable to the same source type being regulated whenever it adopts, or amends a rule, and the South Coast AQMD's comparative analysis of Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 are included in the Final Staff Report; and

WHEREAS, the South Coast AQMD Governing Board has determined that no socioeconomic impact assessment for Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 is required per Health and Safety Code Sections 40440.8 and 40728.5 because no adverse socioeconomic impacts are expected and the proposed project will not significantly affect air quality or emission limitations; and

WHEREAS, the South Coast AQMD Governing Board has determined that Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 will result in a cost savings to affected facilities and thus, no adverse socioeconomic impacts are expected; and

WHEREAS, the South Coast AQMD Governing Board has determined that Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 neither include new Best Available Retrofit Control Technology (BARCT) requirements nor a feasible measure pursuant to Health and Safety Code Section 40914, therefore analyses for cost-effectiveness and incremental cost-effectiveness consistent with the Health and Safety Code Section 40920.6, are not applicable; and

WHEREAS, the South Coast AQMD staff conducted a Public Workshop on January 25, 2023 regarding Proposed Rule 1110.3 and Proposed Amended Rule 1110.2; and

WHEREAS, the Public Hearing has been properly noticed in accordance with all provisions of Health and Safety Code Sections 40725 and 40440.5; and

WHEREAS, the South Coast AQMD Governing Board has held a Public Hearing in accordance with all provisions of state and federal law; and

WHEREAS, the South Coast AQMD specifies the Planning and Rules Manager overseeing the rule development for Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 as the custodian of the documents or other materials which constitute the record of proceedings upon which the adoption of the proposed amended rule is based, which are located at the South Coast Air Quality Management District, 21865 Copley Drive, Diamond Bar, California; and

NOW, THEREFORE BE IT RESOLVED, the South Coast AQMD Governing Board directs staff to begin the development of a South Coast AQMD certification program for linear generators within 90 days of the adoption of Proposed Rule 1110.3 and Proposed Amended Rule 1110.2, and initiate a rule development process after finalizing a South Coast AQMD certification program for linear generators; and

BE IT FURTHER RESOLVED, that the South Coast AQMD Governing Board does hereby determine, pursuant to the authority granted by law, that the proposed project (Proposed Rule 1110.3 and Proposed Amended Rule 1110.2) is exempt from CEQA pursuant to CEQA Guidelines Sections 15061(b)(3) – Common Sense Exemption. This information was presented to the South Coast AQMD Governing Board, whose members exercised their independent judgment and reviewed, considered, and approved the information therein prior to acting on the proposed project; and

BE IT FURTHER RESOLVED, that the South Coast AQMD Governing Board does hereby adopt, pursuant to the authority granted by law, Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 as set forth in the attached, and incorporated herein by reference; and

BE IT FURTHER RESOLVED, that the South Coast AQMD Governing Board requests that Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 be submitted for inclusion in the State Implementation Plan; and

BE IT FURTHER RESOLVED, that the Executive Officer is hereby directed to forward a copy of this Resolution, Proposed Rule 1110.3 and Proposed Amended Rule 1110.2, and supporting documentation to the California Air Resources Board for approval and subsequently submitted to the U.S. Environmental Protection Agency for inclusion into the State Implementation Plan.

DATE: _____

CLERK OF THE BOARDS

ATTACHMENT F

(Adopted TBD)

PROPOSED RULE 1110.3 EMISSIONS FROM LINEAR GENERATORS

[RULE INDEX TO BE ADDED AFTER RULE ADOPTION]

(a) Purpose

The purpose of this rule is to reduce emissions of Oxides of Nitrogen (NO_x), Volatile Organic Compounds (VOCs), and carbon monoxide (CO) from linear generators.

(b) Applicability

All linear generators fueled solely by natural gas are subject to this rule.

(c) Definitions

For the purpose of this rule, the following definitions shall apply:

- (1) EMERGENCY STANDBY UNIT means any Linear Generator which operates as a temporary replacement for primary power during periods of fuel or energy shortage or while the primary power supply is under repair.
- (2) FACILITY means any source or group of sources or other air contaminant emitting activities which are located on one or more contiguous properties within South Coast AQMD, in actual physical contact or separated solely by a public roadway or other public right-of-way, and are owned or operated by the same person (or by persons under common control), or an outer continental shelf (OCS) source as determined in Section 55.2 of Title 40, Part 55 of the Code of Federal Regulations (40 CFR Part 55). Such above-described groups, if noncontiguous, but connected only by land carrying a pipeline, shall not be considered one facility. Sources or installations involved in crude oil and gas production in Southern California Coastal or OCS Waters and transport of such crude oil and gas in Southern California Coastal or OCS Waters shall be included in the same facility which is under the same ownership or use entitlement as the crude oil and gas production facility on-shore.
- (3) IDENTICAL UNITS means any Units with the same manufacturer, model, and output rating.

- (4) LINEAR GENERATOR means any power generation technology that uses a thermochemical reaction to create linear motion that is directly converted into electricity.
 - (5) NATURAL GAS means a mixture of gaseous hydrocarbons, with at least 80 percent methane by volume, and of pipeline quality, such as the gas sold or distributed by any utility company regulated by the California Public Utilities Commission.
 - (6) OXIDES OF NITROGEN (NO_x) means the sum of nitric oxides and nitrogen dioxides emitted, collectively expressed as nitrogen dioxide emissions.
 - (7) TUNING means adjusting, optimizing, rebalancing, or other similar operations to a Unit or an associated control device or as otherwise defined in the Permit to Operate. Tuning does not include automatic adjustments made by a Unit’s control system or normal operations to meet load fluctuations.
 - (8) UNIT means any single linear generator core.
 - (9) VOLATILE ORGANIC COMPOUND (VOC) as defined in Rule 102 – Definition of Terms.
- (d) Emission Limits
 An owner or operator of a Unit with a Permit to Operate issued on or after [*Date of Adoption*] shall not operate the Unit in a manner that exceeds the NO_x, CO, and VOC emission limits listed in Table 1.

**Table 1: Concentration Limits for Linear Generators
 Units with a Permit to Operate Issued on or after
 [*Date of Adoption*]**

Fuel Type	NO _x (ppmv) ¹	CO (ppmv) ¹	VOC (ppmv) ²
Natural Gas	2.5	12	10

¹ Parts per million by volume, corrected to 15% oxygen on a dry basis and averaged over 15 minutes.

² Parts per million by volume, measured as carbon, corrected to 15% oxygen on a dry basis, and averaged over the sampling time required by the test method.

(e) Maintenance Requirements

- (1) An owner or operator of a Unit shall perform maintenance per manufacturer’s recommendations as specified in the operating and maintenance manual.
- (2) An owner or operator of a Unit shall keep a copy of the manufacturer’s operating and maintenance manual and make it available to the Executive Officer within 48 hours upon request.

(f) Source Testing

- (1) An owner or operator of a Unit that is not pooled pursuant to paragraph (f)(10) shall conduct source testing for NOx, VOC reported as carbon, and CO concentrations (concentrations in ppm by volume, corrected to 15 percent oxygen on dry basis):
 - (A) Initially, within six months of installation of a Unit or within six months of not meeting the eligibility requirements for pooled source testing in paragraph (f)(10); and
 - (B) Subsequently, at least once every five years from the date of the previous source test, no later than the last day of the calendar month that the test is due.
- (2) An owner or operator of a Unit shall conduct the source test by using a contractor that is approved under South Coast AQMD’s Laboratory Approval Program (LAP) for the test methods specified in Table 2, or any test methods approved by CARB and U.S. EPA, and authorized by the Executive Officer.

Table 2: Testing Methods

Pollutant	Method
NOx	South Coast AQMD Method 100.1
CO	South Coast AQMD Method 100.1
VOC	South Coast AQMD Method 25.1* or Method 25.3*

*Excluding ethane and methane

- (3) An owner or operator of a Unit without an approved generic source test protocol shall submit a source test protocol to the Executive Officer for written approval at least 60 days before the scheduled date of the test. The source test protocol shall include, but is not limited to the following:

- (A) Name, address, and phone number of the Unit operator and a South Coast AQMD-approved source testing contractor that will conduct the test;
 - (B) All relevant application number(s), permit number(s), and emission limits;
 - (C) Description of the Unit(s) to be tested and the test methods and procedures to be used;
 - (D) Number of tests to be conducted and under what loads; and
 - (E) Required minimum sampling time for the VOC test, based on the analytical detection limit and expected VOC levels.
- (4) An owner or operator of a Unit with an approved generic source test protocol or other valid approved source test protocol shall conduct the source test within 90 days after a written approval of the source test protocol by the Executive Officer is electronically distributed.
- (5) An owner or operator of a Unit with an approved generic protocol, or with a previously approved source test protocol, shall submit a subsequent protocol if the Unit has been altered in a manner that requires a permit modification, if emission limits for the Unit have changed since the previous source test, or if requested by the Executive Officer.
- (6) An owner or operator of a Unit shall provide the Executive Officer at least 30 days prior notice of any source test to afford the Executive Officer the opportunity to have an observer present. If, after the 30 days prior notice is given, there is a delay (due to operational problems, etc.) in conducting the scheduled source test, the owner or operator of a Unit shall notify the Executive Officer as soon as possible of any delay in the original test date, either by providing notice of the rescheduled date of the source test at least seven days prior, or by arranging a rescheduled date mutually agreed upon with the Executive Officer.
- (7) An owner or operator of a Unit shall provide source testing facilities as follows:
- (A) Sampling ports adequate for the applicable test methods. This includes constructing the air pollution control system and stack or duct such that pollutant concentrations can be accurately determined by applicable test methods;
 - (B) Safe sampling platform(s), scaffolding or mechanical lifts, including safe access, that comply with California General Safety Orders; and
 - (C) Utilities for sampling and testing equipment.

- (8) The LAP contractor shall not conduct a source test within 1 week of any Unit servicing or Tuning.
- (9) The LAP contractor shall conduct source testing for at least 30 mins during normal operation (actual duty cycle). This test shall not be conducted under a steady-state condition unless it is a normal operation. The LAP contractor shall not conduct any pre-tests for compliance.
- (10) In lieu of meeting the requirements in paragraph (f)(1), an owner or operator of six or more Identical Units located at the same Facility may elect to conduct pooled source testing for NO_x, VOC reported as carbon, and CO concentrations (concentrations in ppm by volume, corrected to 15 percent oxygen on dry basis), pursuant to the following:
 - (A) At least one-third of the Units shall be source tested during the initial source test and all subsequent source testing shall be conducted on a different one-third of the Units. Source testing of pooled Units shall be conducted at least once every three years from the date of the previous source test, no later than the last day of the calendar month that the test is due;
 - (B) Identical Units installed after the initial source test has been performed shall be included with the Units subject to the pooled subsequent emissions testing pursuant to subparagraph (f)(10)(A);
 - (C) If any Unit subject to the pooled source testing exceeds any emissions standards in Table 1, the owner or operator shall repair the Unit that failed, repeat the source test within 60 days of repair, and conduct source testing on an additional one-third Units; and
 - (D) All pooled Units at a Facility shall be source tested at least once every nine years.
- (g) Monitoring, Recordkeeping, and Reporting
 - (1) Monitoring
 - (A) An owner or operator of a Unit shall conduct diagnostic emission checks by a portable NO_x, CO, and oxygen analyzer at least once every two years from the date of the previous emission check, no later than the last day of the calendar month that the test is due, and comply with the following requirements:

- (i) No Unit or control system maintenance or Tuning may be conducted within 1 week prior to the diagnostic emission check, unless it is an unscheduled, required repair;
 - (ii) The portable analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations and in accordance with South Coast AQMD's Combustion Gas Periodic Monitoring Protocol of Nitrogen Oxides, Carbon Monoxide, and Oxygen from Combustion Sources subject to South Coast Air Quality Management District Rules 1110.2, 1146, and 1146.1, or subsequent protocol approved by U.S. EPA and the Executive Officer;
 - (iii) The portable analyzer tests required in subparagraph (g)(1)(A) shall only be conducted by a person who has completed an appropriate South Coast AQMD-approved training program in the operation of portable analyzers and has received a certification issued by South Coast AQMD; and
 - (iv) A source test pursuant to paragraphs (f)(1) and (f)(10) shall be an acceptable substitute diagnostic emission check to satisfy subparagraph (g)(1)(A).
- (B) If a diagnostic emission check results in finding emissions in excess of rule or permit limits, an owner or operator shall correct the exceedance as soon as possible and demonstrate compliance with another diagnostic emission check pursuant to (g)(1)(A).
 - (C) An owner or operator of a Unit shall maintain a net output meter that meets ANSI C12.20 or an equivalent standard.
 - (D) An owner or operator of a Unit shall maintain an operational parametric monitoring system including the associated components necessary to maintain a system that measures air-to-fuel ratio.
 - (E) An owner or operator of a Unit shall inspect and maintain all sensors and meters used by the parametric monitoring system per manufacturer's recommendations as specified in the operating manual.
 - (F) An owner or operator of a Unit shall develop and implement procedures for at least daily monitoring of the parametric monitoring system.

(2) Recordkeeping

An owner or operator of a Unit shall retain all data logs, source test reports, and other records required by this rule for at least five years and be made available to the Executive Officer upon request.

(A) The owner or operator of a Unit shall maintain records, on a monthly basis, for the following parameters(s) or item(s):

- (i) Quantity of fuel consumption (e.g., cubic feet of gas);
- (ii) Date of last emissions test required in subdivision (f) and subparagraph (g)(1)(A);
- (iii) Megawatt-hours of electricity produced; and
- (iv) Air-to-Fuel system faults, alarms, and any other related emission control malfunctions.

(B) An owner or operator of a Unit shall keep records to demonstrate compliance with paragraphs (e)(1), (f)(1), (f)(8), (f)(10), and (g)(1).

(3) Reporting

An owner or operator of a Unit shall submit all source test reports to the Executive Officer within 60 days of completion of the test.

(h) Exemptions

(1) The provisions of subdivision (d) and subparagraph (g)(1)(A) shall not apply to Laboratory Units used for testing and research purposes.

(2) The provisions of subdivision (f) and subparagraph (g)(1)(A) shall not apply to Emergency Standby Units, Units used for fire-fighting and flood control, or any other emergency Unit approved by the Executive Officer, which have permit conditions that limit operation to 200 hours or less per year as determined by an operational non-resettable totalizing time meter.

ATTACHMENT G

(Adopted August 3, 1990)(Amended September 7, 1990)(Amended August 12, 1994)
(Amended December 9, 1994)(Amended November 14, 1997)(Amended June 3, 2005)
(Amended February 1, 2008)(Amended July 9, 2010)(Amended September 7, 2012)
(Amended December 4, 2015)(Amended June 3, 2016)(Amended November 1, 2019)
(Amended TBD)

PROPOSED EMISSIONS FROM GASEOUS- AND LIQUID-FUELED
AMENDED ENGINES
RULE
1110.2

(a) Purpose

The purpose of Rule 1110.2 is to reduce Oxides of Nitrogen (NO_x), Volatile Organic Compounds (VOCs), and Carbon Monoxide (CO) from engines.

(b) Applicability

All stationary and portable engines over 50 rated brake horsepower (bhp) are subject to this rule.

(c) Definitions

For the purpose of this rule, the following definitions shall apply:

- (1) AGRICULTURAL STATIONARY ENGINE is a non-portable engine used for the growing and harvesting of crops of the raising of fowl or animals for the primary purpose of making a profit, providing a livelihood, or conducting agricultural research or instruction by an educational institution. An engine used for the processing or distribution of crops or fowl or animals is not an agricultural engine.
- (2) APPROVED EMISSION CONTROL PLAN is a control plan, submitted on or before December 31, 1992, and approved by the Executive Officer prior to November 14, 1997, that was required by subdivision (d) of this rule as amended September 7, 1990.
- (3) BREAKDOWN is a physical or mechanical failure or malfunction of an engine, air pollution control equipment, or related operating equipment that is not the result of operator error, neglect, improper operation or improper maintenance procedures, which leads to excess emissions beyond rule related emission limits or equipment permit conditions.
- (4) CERTIFIED SPARK-IGNITION ENGINE means engines certified by California Air Resources Board (CARB) to meet emission standards in accordance with Title 13, Chapter 9, Article 4.5 of the California Code of Regulations (CCR).
- (5) COMPRESSOR GAS LEAN-BURN ENGINE is a stationary gaseous-fueled two-stroke or four-stroke lean-burn engine used to compress natural

gas or pipeline quality natural gas for delivery through a pipeline or into storage.

- (c) (6) EMERGENCY STANDBY ENGINE is an engine which operates as a temporary replacement for primary mechanical or electrical power during periods of fuel or energy shortage or while the primary power supply is under repair.
- (7) ENGINE is any spark- or compression-ignited internal combustion engine, including engines used for control of VOC's, but not including Linear Generators or engines used for self-propulsion.
- (8) ESSENTIAL PUBLIC SERVICE includes any facility or operator as defined in Rule 1302.
- (9) EXEMPT COMPOUNDS are defined in South Coast AQMD Rule 102 – Definition of Terms.
- (10) FACILITY means any source or group of sources or other air contaminant emitting activities which are located on one or more contiguous properties within the South Coast AQMD, in actual physical contact or separated solely by a public roadway or other public right-of-way, and are owned or operated by the same person (or by persons under common control), or an outer continental shelf (OCS) source as determined in Section 55.2 of Title 40, Part 55 of the Code of Federal Regulations (40 CFR Part 55). Such above-described groups, if noncontiguous, but connected only by land carrying a pipeline, shall not be considered one facility. Sources or installations involved in crude oil and gas production in Southern California Coastal or OCS Waters and transport of such crude oil and gas in Southern California Coastal or OCS Waters shall be included in the same facility which is under the same ownership or use entitlement as the crude oil and gas production facility on-shore.
- (11) FORMER RECLAIM FACILITY means a facility, or any of its successors, that was in the Regional Clean Air Incentives Market as of January 5, 2018, as established in Regulation XX, that has received a final determination notification, and is no longer in the RECLAIM program.
- (12) LEAN-BURN ENGINE means an engine that operates with high levels of excess air and an exhaust oxygen concentration of greater than 4 percent.
- (13) LINEAR GENERATOR means any power generation technology that uses a thermochemical reaction to create linear motion that is directly converted into electricity.

- (143) LOCATION means any single site at a building, structure, facility, or installation. For the purpose of this definition, a site is a space occupied or to be occupied by an engine. For engines which are brought to a facility to perform maintenance on equipment at its permanent or ordinary location, each maintenance site shall be a separate location.
- (c) (154) NET ELECTRICAL ENERGY means the electrical energy produced by a generator, less the electrical energy consumed by any auxiliary equipment necessary to operate the engine generator and, if applicable, any heat recovery equipment, such as heat exchangers.
- (165) NON-RECLAIM FACILITY means a facility, or any of its successors, that was not in the Regional Clean Air Incentives Market as of January 5, 2018, as established in Regulation XX.
- (176) NON-ROAD ENGINE is any engine, defined under 40 CFR Part 89, that does not remain or will not remain at a location for more than 12 consecutive months, or a shorter period of time where such period is representative of normal annual source operation at a stationary source that resides at a fixed location for more than 12 months (e.g., seasonal operations such as canning facilities), and meets one of the following:
- (A) Is used in or on a piece of equipment that is self-propelled or serves a dual purpose by both propelling itself and performing another function (such as a mobile crane); or
 - (B) Is used in or on a piece of equipment that is intended to be propelled while performing its function (such as lawn mowers and string trimmers); or
 - (C) By itself, or in or on a piece of equipment, is portable or transportable, meaning designed to be and capable of being carried or moved from one location to another. Transportability includes, but is not limited to, wheels, skids, carrying handles, dolly, trailer, platform or mounting.
- (187) OPERATING CYCLE means a period of time within which a round of regularly recurring events is completed, and cannot be stopped without the risk of endangering public safety or health, causing material damage to the equipment or product, or cannot be stopped due to technical constraints. Economic reasons alone will not be sufficient to extend this time period. The operating cycle includes batch processes that may start and finish

several times within a twenty-four hour period, in which case each start to finish interval is considered a complete cycle.

(198) OXIDES OF NITROGEN (NO_x) means nitric oxide and nitrogen dioxide.

(204 9) PORTABLE ENGINE is an engine that, by itself or in or on a piece of equipment, is designed to be and capable of being carried or moved from one location to another. Indications of portability include, but are not limited to, wheels, skids, carrying handles, dolly, trailer, platform or mounting. The operator must demonstrate the necessity of the engine being periodically moved from one location to another because of the nature of the operation.

(c)

An engine is not portable if:

(A) The engine or its replacement remains or will reside at the same location for more than 12 consecutive months. Any engine, such as a back-up or stand-by engine, that replaces an engine at a location and is intended to perform the same function as the engine being replaced, will be included in calculating the consecutive time period. In that case, the cumulative time of both engines, including the time between the removal of the original engine and installation of the replacement engine, will be counted toward the consecutive time period; or

(B) The engine remains or will reside at a location for less than 12 consecutive months where such a period represents the full length of normal annual source operations such as a seasonal source; or

(C) The engine is removed from one location for a period and then it or its equivalent is returned to the same location thereby circumventing the portable engine residence time requirements.

The period during which the engine is maintained at a designated storage facility shall be excluded from the residency time determination.

(210) RATED BRAKE HORSEPOWER (bhp) is the rating specified by the manufacturer, without regard to any derating, and listed on the engine nameplate.

(224) RECLAIM FACILITY means a facility, or any of its successors, that was in the Regional Clean Air Incentives Market as of January 5, 2018, as established in Regulation XX.

- (c) (232 RICH-BURN ENGINE WITH A THREE-WAY CATALYST means an engine designed to operate near stoichiometric conditions with a catalytic control device that simultaneously reduces emissions of NO_x, CO and VOC.)
- (243 STATIONARY ENGINE is an engine which is either attached to a foundation or if not so attached, does not meet the definition of a portable or non-road engine and is not a motor vehicle as defined in Section 415 of the California Vehicle Code.)
- (254 TIER 2 AND TIER 3 DIESEL ENGINES mean engines certified by CARB to meet Tier 2 or Tier 3 emission standards in accordance with Title 13, Chapter 9, Article 4 of the CCR.)
- (265 USEFUL HEAT RECOVERED means the waste heat recovered from the engine exhaust and/or cooling system that is put to productive use. The waste heat recovered may be assumed to be 100% useful unless the hot water, steam or other medium is vented to the atmosphere, or sent directly to a cooling tower or other unproductive use.)
- (276 VOLATILE ORGANIC COMPOUND (VOC) is as defined in Rule 102.)

(d) Requirements

(1) Stationary Engines:

(A) Operators of stationary engines with an amended Rule 1110.1 Emission Control Plan submitted by July 1, 1991, or an Approved Emission Control Plan, designating the permanent removal of engines or the replacement of engines with electric motors, in accordance with subparagraph (d)(1)(B), shall do so by December 31, 1999, or not operate the engines on or after December 31, 1999 in a manner that exceeds the emission concentration limits listed in Table I:

TABLE I ALTERNATIVE TO ELECTRIFICATION CONCENTRATION LIMITS		
NO_x (ppmvd)¹	VOC (ppmvd)²	CO (ppmvd)¹
11	30	70

- 1 Parts per million by volume, corrected to 15% oxygen on a dry basis and averaged over 15 minutes.
 - 2 Parts per million by volume, measured as carbon, corrected to 15% oxygen on a dry basis and averaged over the sampling time required by the test method.
- (B) The operator of any other stationary engine not covered by subparagraph (d)(1)(A) shall:
- (i) Remove such engine permanently from service or replace the engine with an electric motor, or alternatively comply with the following, if applicable:
 - (ii) Comply with the applicable emission concentration limits listed in either Table II or Table III-A or B, or technologically achievable case-by-case VOC or CO emission concentration limits approved by the Executive Officer pursuant to clause (d)(1)(B)(vii), averaged over 15 minutes or other averaging time period allowed by clauses (d)(1)(B)(iii) through (d)(1)(B)(v);
 - (iii) Use an averaging time approved by the Executive Officer for an engine that uses non-pipeline quality natural gas that has demonstrated that due to the varying heating value of the gas a longer averaging time was necessary. The fixed-interval averaging time shall not exceed six hours for any of the concentration limits of Table II, unless an engine is subject to an existing permit condition allowing for an averaging time greater than six hours. Non-pipeline quality natural gas is a gas that does not meet the gas specifications of the local gas utility and is not supplied to the local gas utility;
 - (iv) Use a fixed-interval averaging time of one hour for engines equipped with a Continuous Emissions Monitoring System (CEMS), to demonstrate compliance with the emission concentration limits of Table II or Table III-B;
 - (v) Use a fixed-interval averaging time of three hours for compressor gas lean-burn engines equipped with selective catalytic reduction pollution control equipment and a
- (d)

CEMS, to demonstrate compliance with the NOx emission concentration limit of Table II;

- (vi) Comply with the emission concentration limits listed in Table II for Low-Use Engines. A Low-Use engine is an engine that operates less than 500 hours per year or uses less than 1×10^9 British Thermal Units (Btus) per year (higher heating value) of fuel;
 - (vii) Comply with any technologically achievable case-by-case CO and VOC limits that were approved by the Executive Officer in lieu of the concentration limits in Table II effective on and after July 1, 2011 for a two-stroke engine equipped with an oxidation catalyst and insulated exhaust ducts and catalyst housing that has demonstrated that the CO and VOC limits effective on and after July 1, 2011 were not achievable. The case-by-case limits shall not exceed 250 ppmvd VOC and 2000 ppmvd CO, but must comply with the applicable NOx concentration limit in Table II.
- (d)

TABLE II		
CONCENTRATION LIMITS FOR LOW-USE ENGINES		
NO_x (ppmvd)¹	VOC (ppmvd)²	CO (ppmvd)¹
bhp ≥ 500: 36 bhp < 500: 45	250	2000
CONCENTRATION LIMITS		
EFFECTIVE JULY 1, 2011		
NO_x (ppmvd)¹	VOC (ppmvd)²	CO (ppmvd)¹
11	30	250

¹ Parts per million by volume, corrected to 15% oxygen on a dry basis.

² Parts per million by volume, measured as carbon, corrected to 15% oxygen on a dry basis and averaged over the sampling time required by the test method.

- (C) The operator of any stationary engine fired by landfill or digester gas (biogas) shall not operate the engine in a manner that exceeds the emission concentration limits of Table III-A, provided that the

- (d) facility monthly average biogas usage by the biogas engine is 90% or more, based on the higher heating value of the fuels used. The calculation of the monthly facility biogas use percentage may exclude natural gas fired during: any electrical outage at the facility; a Stage 2 or higher electrical emergencies called by the California Independent System Operator Corporation; and when a sewage treatment plant activates an Emergency Operations Center or Incident Command System, as part of an emergency response plan, because of either high influent flows caused by precipitation or a disaster.

TABLE III-A CONCENTRATION LIMITS FOR LANDFILL AND DIGESTER GAS (BIOGAS)-FIRED LOW-USE ENGINES		
NO _x (ppmvd) ¹	VOC (ppmvd) ²	CO (ppmvd) ¹
bhp ≥ 500: 36 x ECF ³ bhp < 500: 45 x ECF ³	Landfill Gas: 40 Digester Gas: 250 x ECF ³	2000
TABLE III-B CONCENTRATION LIMITS FOR LANDFILL AND DIGESTER GAS (BIOGAS)-FIRED ENGINES EFFECTIVE JANUARY 1, 2017		
NO _x (ppmvd) ¹	VOC (ppmvd) ²	CO (ppmvd) ¹
11	30	250

¹ Parts per million by volume, corrected to 15% oxygen on a dry basis.

² Parts per million by volume, measured as carbon, corrected to 15% oxygen on a dry basis and averaged over the sampling time required by the test method.

³ ECF is the efficiency correction factor.

The ECF shall be 1.0 unless:

- (i) The engine operator has measured the engine’s net specific energy consumption (q_a), in compliance with ASME Performance Test Code PTC 17 -1973, at the average load of the engine; and

- (ii) The ECF-corrected emission limit is made a condition of the engine's permit to operate.

The ECF is as follows:

$$\text{ECF} = \frac{9250 \text{ Btus/hp-hr}}{\text{Measured } q_a \text{ in Btus/hp-hr}}$$

Measured q_a shall be based on the lower heating value of the fuel. ECF shall not be less than 1.0.

- (d) The Executive Officer may approve the burning of more than 10% natural gas in a landfill or digester gas-fired engine, when it is necessary, if: the only alternative to limiting natural gas to 10% would be shutting down the engine and flaring more landfill or digester gas; or the engine requires more natural gas in order for a waste heat recovery boiler to provide enough thermal energy to operate a sewage treatment plant, and other boilers at the facility are unable to provide the necessary thermal energy.
- (D) Notwithstanding the provisions of subparagraph (d)(1)(B), the operator of any stationary engine fired by landfill or digester gas (biogas) shall not operate the engine in a manner that exceeds the emission concentration limits of Table III.
- (E) Biogas engine operators that establish to the satisfaction of the Executive Officer that they have complied with the emissions limits of Table III-B by January 1, 2015 will have their respective engine permit application fees refunded.
- (F) For the City of San Bernardino, Orange County Sanitation District, and Eastern Municipal Water District that commenced and implemented technology demonstration projects prior to January 1, 2015, all their biogas engines shall have until January 1, 2018 to comply with the requirements of Table III-B.
- (G) Once an engine complies with the concentration limits as specified in Table III-B, there shall be no limit on the percentage of natural gas burned.
- (H) The concentration limits effective as specified in Table III-A shall apply to engines that are biogas-fired Low-Use engines. A biogas-fired Low-Use engine is an engine that operates fewer than 500

hours per year or uses less than 1×10^9 Btus per year (higher heating value) of fuel.

- (I) An operator of a biogas engine with a CEMS shall meet either:
 - (i) The NO_x and CO limits of Table III-B, averaged pursuant to the specified averaging provisions in subparagraph (d)(1)(B);
 - (ii) The emission limits at or below 11 ppmvd for NO_x and 250 ppmvd for CO (if CO is selected for averaging), each corrected to 15% O₂ and averaged over a 24-hour fixed interval, with the emission limits and averaging time specified as a condition in the engine's permit to operate on or before November 1, 2019; or
 - (iii) The emission limits at or below 9.9 ppmvd for NO_x and 225 ppmvd for CO (if CO is selected for averaging), each corrected to 15% O₂ and averaged over a 48-hour fixed interval, with emission limits and averaging time specified as a condition in the engine's permit to operate.
- (d)
 - (J) The operator of any new engine subject to subparagraph (e)(1)(B) shall:
 - (i) Comply with the requirements of Best Available Control Technology in accordance with Regulation XIII if the engine requires a South Coast AQMD permit; or
 - (ii) Not operate the engine in a manner that exceeds the emission concentration limits in Table I if the engine does not require a South Coast AQMD permit.
 - (K) By February 1, 2009, the operator of a spark-ignited engine without a Rule 218-approved continuous emission monitoring system (CEMS) or a Regulation XX (RECLAIM)-approved CEMS shall equip and maintain the engine with an air-to-fuel ratio controller with an oxygen sensor and feedback control, or other equivalent technology approved by the Executive Officer, CARB and EPA.
 - (L) New Non-Emergency Electrical Generators

- (i) All new non-emergency engines driving electrical-generators shall comply with the following emission standards in lbs/MW-hr:

(d)

TABLE IV EMISSION STANDARDS FOR NEW ELECTRICAL GENERATION DEVICES		
Pollutant	Emission Standard (lbs/MW-hr)¹	Concentration Limit³ (ppmvd)⁴
NO _x	0.070	2.5
CO	0.20	12
VOC	0.10 ²	10

- ¹ The averaging time of the emission standard for VOC is the sampling time required by the test method.
- ² Mass emissions of VOC shall be calculated using a ratio of 16.04 pounds of VOC per lb-mole of carbon.
- ³ ~~Concentration limit is calculated using a 40% engine efficiency and no applied thermal credit.~~
- ⁴ ~~Parts per million by volume, corrected to 15% oxygen on a dry basis.~~

- (ii) Engines subject to this subparagraph that produce combined heat and electrical power may include one megawatt-hour (MW-hr) for each 3.4 million Btus of useful heat recovered (MW_{th}-hr), in addition to each MW-hr of net electricity produced (MW_e-hr). The compliance of such engines shall be based on the following equation:

$$\frac{\text{Lbs}}{\text{MW-hr}} = \frac{\text{Lbs}}{\text{MW}_e\text{-hr}} \times \text{Electrical Energy Factor (EEF)}$$

Where:

Lbs/MW-hr = The calculated emissions standard.

Lbs/MW_e-hr = The short-term engine emission limit in pounds per MWe-hr of net electrical energy produced.

EEF = The annual MW_e-hrs of net electrical energy produced divided by the sum of

annual MW_e -hrs plus annual MW_{th} -hrs of useful heat recovered.

- (d)
- (iii) For combined heat and power engines, the short-term emission limits in lbs/ MW_e -hr and the maximum allowed annual EEF must be selected by operator and stated on the operating permit.
 - (iv) The requirements of this subparagraph shall apply to NO_x emissions from new non-emergency engines driving electrical-generators subject to Regulation XX (RECLAIM).
 - (v) This subparagraph does not apply to: engines installed prior to February 1, 2008; engines issued a permit to construct prior to February 1, 2008 and installed within 12 months of the date of the permit to construct; engines for which an application is deemed complete by October 1, 2007; engines installed by an electric utility on Santa Catalina Island; engines installed at remote locations without access to natural gas and electric power; engines used to supply electrical power to ocean-going vessels while at berth, prior to January 1, 2014; or landfill or digester gas-fired engines that meet the requirements of subparagraph (d)(1)(C).
 - (vi) For engines driving electrical generators and operating with a CEMS, a fixed-interval averaging time of one hour shall be used to demonstrate compliance with the NO_x and CO emission standard requirements of Table IV in lbs/MW-hr. For engines driving electrical generators and operating without a CEMS, the NO_x and CO emission standard requirements of Table IV in lbs/MW-hr shall be averaged over 15 minutes.
 - ~~(vii) Owners and operators of new engines installed prior to January 1, 2024 with no ammonia emissions from add-on control equipment and where NO_x emissions meet the concentration limit of Table IV at all times may elect to apply for and comply with the concentration limits of Table IV, expressed in ppmvd, except an alternative VOC concentration limit that is equal to or less than 25 ppmvd~~

(d) ~~may be complied with. The Executive Officer shall accumulate daily VOC emissions in excess of the concentration limit of Table IV based on the permitted VOC limits from each such engine and shall not approve any additional permit for such engine that will cause the total accumulated daily VOC emissions to exceed 45 lbs per day. Any new installation on or after January 1, 2024 shall comply with the VOC concentration limit in Table IV in ppmvd.~~

(2) Portable Engines:

(A) The operator of any portable engine generator subject to this rule shall not use the portable generator for:

(i) Power production into the electric grid, except to maintain grid stability during an emergency event or other unforeseen event that affects grid stability; or

(ii) Primary or supplemental power to a building, facility, stationary source, or stationary equipment, except during unforeseen interruptions of electrical power from the serving utility, maintenance and repair operations, and remote operations where grid power is unavailable. For interruptions of electrical power, the operation of a portable generator shall not exceed the time of the actual interruption of power.

This subparagraph shall not apply to a portable generator that complies with emission concentration limits of Table I and the other requirements in this rule applicable to stationary engines.

(B) The operator of any portable diesel engine shall comply with the applicable requirements of the Subchapter 7.5 Airborne Toxic Control Measures for diesel particulate matter in Chapter 1, Division 3, Title 17 of the California Code of Regulations.

(C) The operator of any portable spark-ignited engine shall comply with the applicable requirements of the Large Spark Ignition Engine Fleet Requirements, Article 2, Chapter 15, Division 3, Title 13 of the California Code of Regulations.

(e) Compliance

- (1) Agricultural Stationary Engines:
 - (A) The operator of any agricultural stationary engine subject to this rule and installed or issued a permit to construct prior to June 3, 2005 shall comply with subparagraph (d)(1)(B) and the other applicable provisions of this rule in accordance with the compliance schedules in Table V:

TABLE V COMPLIANCE SCHEDULES FOR STATIONARY AGRICULTURAL ENGINES		
Action Required	Tier 2 and Tier 3 Diesel Engines, Certified Spark-Ignition Engines, and All Engines at Facilities with Actual Emissions Less Than the Amounts in the Table of Rule 219(q)	Other Engines
Submit notification of applicability to the Executive Officer	January 1, 2006	January 1, 2006
Submit to the Executive Officer applications for permits to construct engine modifications, control equipment, or replacement engines	March 1, 2009	September 1, 2007
Initiate construction of engine modifications, control equipment, or replacement engines	September 30, 2009, or 30 days after the permit to construct is issued, whichever is later	March 30, 2008, or 30 days after the permit to construct is issued, whichever is later
Complete construction and comply with applicable requirements	January 1, 2010, or 60 days after the permit to construct is issued, whichever is later	July 1, 2008, or 60 days after the permit to construct is issued, whichever is later
Complete initial source testing	March 1, 2010, or 120 days after the permit to	September 1, 2008, or 120 days after the permit

	construct is issued, whichever is later	to construct is issued, whichever is later
--	--	---

- (e) The notification of applicability shall include the following for each engine:
 - (i) Name and mailing address of the operator
 - (ii) Address of the engine location
 - (iii) Manufacturer, model, serial number, and date of manufacture of the engine
 - (iv) Application number
 - (v) Engine type (diesel, rich-burn spark-ignition or lean-burn spark-ignition)
 - (vi) Engine fuel type
 - (vii) Engine use (pump, compressor, generator, or other)
 - (viii) Expected means of compliance (engine replacement, control equipment installation, or electrification)
- (B) The operator of any new agricultural stationary engine that is not subject to the compliance schedule of subparagraph (e)(1)(A) for existing engines shall comply with the requirements of subparagraph (d)(1)(J) immediately upon installation.
- (2) Non-Agricultural Stationary Engines:
 - (A) The operator of any stationary engine not meeting the requirements of subparagraph (d)(1)(B) or (d)(1)(C) that go into effect in 2010 or later, shall comply with the compliance schedule in Table VI.
 - (B) The operator of any stationary engine that elects to amend a permit to operate to incorporate ECF-adjusted emission limits shall submit to the Executive Officer an application for a change of permit conditions by August 1, 2008, and comply with emission limits of the previous version of this rule until February 1, 2009 when the engine shall be in compliance with the emission limits of this rule.
 - (C) The operator of any stationary engine that is required to add operating restrictions to a permit to operate to meet the requirements of this rule shall submit to the Executive Officer an application for a change of permit conditions by August 1, 2008.

(e)

TABLE VI COMPLIANCE SCHEDULE FOR NON -AGRICULTURAL STATIONARY ENGINES	
Action Required	Applicable Compliance Date
Submit to the Executive Officer applications for permits to construct engine modifications, control equipment, or replacement engines	Twelve months before the final compliance date
Initiate construction of engine modifications, control equipment, or replacement engines	Three months before the final compliance date, or 60 days after the permit to construct is issued, whichever is later
Complete construction and comply with applicable requirements	The final compliance date, or 120 days after the permit to construct is issued, whichever is later
Complete initial source testing	60 days after the final compliance date in subparagraph (d)(1)(B) or (d)(1)(C), or 180 days after the permit to construct is issued, whichever is later

(3) Stationary Engine CEMS

- (A) The operator of any stationary engine with an existing CEMS shall commence the reporting required by Rule 218 Subdivision (f) on January 1, 2008. The first summary report for the six months ending June 30, 2008 shall be due on July 30, 2008.
- (B) The operator of any stationary engine that is required to modify an existing CEMS or install a CEMS on an existing engine shall comply with the compliance schedule in Table VII. Public agencies shall be allowed one year more than the dates in Table VII, except for biogas engines.
- (C) The operator of any stationary engine that is located at a RECLAIM or former RECLAIM facility that is required to modify an existing CEMS or install a CEMS on an existing engine that is subject to paragraph (f)(1) shall comply with the compliance schedule in Table VII except that the operator shall submit to the Executive

- (e) Officer applications for a new or modified CEMS within 90 days of becoming a former RECLAIM facility.
 - (i) For engines at a RECLAIM or former RECLAIM facility, installation of a CEMS is required concurrently with the installation of retrofit control technologies or new engine replacements to meet the requirements of paragraph (d)(1).

TABLE VII COMPLIANCE SCHEDULE FOR NEW OR MODIFIED CEMS ON EXISTING ENGINES			
Action Required	Applicable Compliance Dates For:		
	Non-Biogas Engines Rated at 750 bhp or More	Non-Biogas Engines Rated at Less than 750 bhp	Biogas Engines*
Submit to the Executive Officer applications for new or modified CEMS	August 1, 2008	August 1, 2009	January 1, 2011
Complete installation and commence CEMS operation, calibration, and reporting requirements	Within 180 days of initial approval	Within 180 days of initial approval	Within 180 days of initial approval
Complete certification tests	Within 90 days of installation	Within 90 days of installation	Within 90 days of installation
Submit certification reports to Executive Officer	Within 45 days after tests are completed	Within 45 days after tests are completed	Within 45 days after tests are completed
Obtain final approval of CEMS	Within 1 year of initial approval	Within 1 year of initial approval	Within 1 year of initial approval

* A biogas engine is one that is subject to the emission limits of Table III.

- (e) (4) Stationary Engine Inspection and Monitoring (I&M) Plans:

The operator of stationary engines subject to the I&M plan provisions of subparagraph (f)(1)(D) shall:

- (A) By August 1, 2008, submit an initial I&M plan application to the Executive Officer for approval;
- (B) By December 1, 2008, implement an approved I&M plan or the I&M plan as submitted if the plan is not yet approved.

Any operator of 15 or more stationary engines subject to the I&M plan provisions shall comply with the above schedule for at least 50% of engines, and for the remaining engines shall:

- (C) By February 1, 2009, submit an initial I&M plan application to the Executive Officer for approval;
- (D) By June 1, 2009, implement an approved I&M plan or the I&M plan as submitted if the plan is not yet approved.

(5) Stationary Engine Air-to-Fuel Ratio Controllers

- (A) The operator of any stationary engine that does not have an air-to-fuel ratio controller, as required by subparagraph (d)(1)(K), shall comply with those requirements in accordance with the compliance schedule in Table V, except that the application due date is no later than May 1, 2008 and the initial source testing may be conducted at the time of the testing required by subparagraph (f)(1)(C).
- (B) The operator of any stationary engine that has the air-to-fuel ratio controller required by subparagraph (d)(1)(K), but it is not listed on the permit to operate, shall submit to the Executive Officer an application to amend the permit by April 1, 2008.
- (C) The operator of more than five engines that do not have air-to-fuel ratio controllers may take an additional three months, to May 1, 2009, to install the equipment on up to 50% of the affected engines.

(6) New Stationary Engines

The operator of any new stationary engine issued a permit to construct after February 1, 2008 shall comply with the applicable I&M or CEMS requirements of this rule when operation commences. If applicable, the operator shall provide the required information in subparagraph (f)(1)(D) to the Executive Officer prior to the issuance of the permit to construct so that the I&M procedures can be included in the permit. A separate I&M plan application is not required.

(e) (7) Biogas Engines

For any biogas engine for which the operator applies to the Executive Officer by April 1, 2008 for a change of permit conditions for ECF-corrected emission limits, or the approval to burn more than 10 percent natural gas in accordance with subparagraph (d)(1)(C), the biogas engine shall not be subject to the initial concentration limits of Tables II or III until August 1, 2008, provided the operator continues to comply with all emission limits in effect prior to February 1, 2008.

(8) Compliance Schedule Exception

If an engine operator submits to the Executive Officer an application for an administrative change of permit conditions to add a permit condition that causes the engine permit to expire by the effective date of any requirement of this rule, then the operator is not required to comply with the earlier steps required by this subdivision for that requirement. The effective date for the CEMS requirements shall be one year after the date that a CEMS application is due.

(9) Exceedance of Usage Limits

(A) If an engine was initially exempt from the new concentration limits in subparagraph (d)(1)(B) or subparagraph (d)(1)(C) that take effect on or after July 1, 2011 because of low engine use but later exceeds the low-use criteria, the operator shall bring the engine into compliance with the rule in accordance with the schedule in Table VI with the final compliance date in Table VI being twelve months after the conclusion of the first twelve-month period for which the engine exceeds the low-use criteria.

(B) If engines that were initially exempt from new CEMS by the low-use criterion in subclause (f)(1)(A)(ii)(I) later exceed that criterion, the operator shall install CEMS on those engines in accordance with the schedule in Table VII, except that the date for submitting the CEMS application in Table VII shall be six months after the conclusion of the first twelve-month period for which the engines exceed the criterion.

(10) RECLAIM or Former RECLAIM Facilities

The owner or operator of a RECLAIM or former RECLAIM facility with any unit(s) subject to subdivision (d) shall meet the applicable NOx

emission limit in Table II or III-B in accordance with the schedule specified in Rule 1100 – Implementation Schedule for NO_x Facilities.

(f) Monitoring, Testing, Recordkeeping and Reporting

(1) Stationary engines:

The operator of any engine subject to the provisions of paragraph (d)(1) of this rule shall meet the following requirements:

(A) Continuous Emission Monitoring

(i) For engines of 1000 bhp and greater and operating more than two million bhp-hr per calendar year, a NO_x and CO CEMS shall be installed, operated and maintained in calibration to demonstrate compliance with the emission limits of this rule.

(ii) (I) For facilities with engines subject to paragraph (d)(1), having a combined rating of 1500 bhp or greater at the same location, and having a combined fuel usage of more than 16 x 10⁹ Btus per year (higher heating value), CEMS shall be installed, operated and maintained in calibration to demonstrate compliance of those engines with the applicable NO_x and CO emission limits of this rule.

(II) Any engine that as of October 1, 2007 is located within 75 feet of another engine (measured from engine block to engine block) is considered to be at the same location. Operators of new engines shall not install engines farther than 75 feet from another engine unless the operator demonstrates to the Executive Officer that operational needs or space limitations require it.

(III) The following engines shall not be counted toward the combined rating or required to have a CEMS by this clause: engines rated at less than 500 bhp; standby engines that are limited by permit conditions to only operate when other primary engines are not operable; engines that are limited by permit conditions to operate less than 1000 hours per year

or a fuel usage of less than 8×10^9 Btus per year (higher heating value of all fuels used); engines that are used primarily to fuel public natural gas transit vehicles and that are required by a permit condition to be irreversibly removed from service by December 31, 2014; and engines required to have a CEMS by the previous clause. A CEMS shall not be required if permit conditions limit the simultaneous use of the engines at the same location in a manner to limit the combined rating of all engines in simultaneous operation to less than 1500 bhp.

- (f)
 - (IV) For engines rated below 1000 bhp, the CEMS may be time shared by multiple engines.
 - (V) Operation of engines by the electric utility in the Big Bear Lake area during the failure of a transmission line to the utility may be excluded from an hours-per-year or fuel usage limit that is elected by the operator pursuant to subclause (f)(1)(A)(ii)(III).
 - (VI) In lieu of complying with subclause (f)(1)(A)(ii)(I), an operator that is a public agency, or is contracted to operate engines solely for a public agency, may comply with the Inspection and Monitoring Plan requirements of subparagraph (f)(1)(D), except that the operator shall conduct diagnostic emission checks at least weekly or every 150 operating hours, whichever occurs later. If any such engine is found to exceed an applicable NO_x or CO limit by a source test required by subparagraph (f)(1)(C) or South Coast AQMD test using a portable analyzer on three or more occasions in any 12-month period, the operator shall comply with the CEMS requirements of this subparagraph for such engine in accordance with the compliance schedule of Table VII, except that the operator shall submit a CEMS application to

the Executive Officer within six months of the third exceedance.

- (iii) All CEMS required by this rule shall:
 - (I) Comply with the applicable requirements of Rules 218 and 218.1, including equipment specifications and certification, operating, recordkeeping, quality assurance and reporting requirements, except as otherwise authorized by this rule;
 - (II) Include equipment that measures and records exhaust gas concentrations, both uncorrected and corrected to 15 percent oxygen on a dry basis; and
 - (III) Have data gathering and retrieval capability approved by the Executive Officer
- (iv) The operator of an engine that is required to install CEMS may request the Executive Officer to approve an alternative monitoring device (or system components) to demonstrate compliance with the emission limits of this rule. The applicant shall demonstrate to the Executive Officer that the proposed alternative monitoring device is at a minimum equivalent in relative accuracy, precision, reliability, and timeliness to a CEMS for that engine, according to the criteria specified in 40 CFR Part 75 Subpart E. In lieu of the criteria specified in 40 CFR Part 75 Subpart E, substitute criteria is acceptable if the applicant demonstrates to the Executive Officer that the proposed alternative monitoring device is at minimum equivalent in relative accuracy, precision, reliability, and timeliness to a CEMS for that engine. Upon approval by the Executive Officer, the substitute criteria shall be submitted to EPA as an amendment to the State Implementation Plan (SIP).
If the alternative monitoring device is denied or fails to be recertified, a CEMS shall be required.
- (v) Notwithstanding the requirements of Rules 218 and 218.1, operators of engines that are required to install a CEMS by clause (f)(1)(A)(ii) may:

- (I) Store data electronically without a strip chart recorder, but there shall be redundant data storage capability for at least 15 days of data. The operator must demonstrate that both sets of data are equivalent.
 - (II) Conduct relative accuracy testing on the same schedule for source testing in clause (f)(1)(C)(i), instead of annually. The minimum sampling time for each test is 15 minutes.
- (f) (vi) Notwithstanding the requirements of Rules 218 and 218.1, operators of engines that are required to install a CEMS by clause (f)(1)(A)(ii), and that are to be monitored by a timeshared CEMS, may:
- (I) Monitor an engine with the CEMS for 15 consecutive minutes, purge for the minimum required purge time, then monitor the next engine for 15 consecutive minutes. The CEMS shall operate continuously in this manner, except for required calibrations.
 - (II) Record the corrected and uncorrected NO_x, CO and diluent data at least once per minute and calculate and record the 15-minute average corrected concentrations for each sampling period.
 - (III) Have sample lines to each engine that are not the same length. The purge time will be based on the sample line with the longest response time. Response times shall be checked during cylinder gas audits. Sample lines shall not exceed 100 feet in length.
 - (IV) Conduct a minimum of five tests for each engine during relative accuracy tests.
 - (V) Perform a cylinder gas audit every calendar quarter on each engine, except for engines for which relative accuracy testing was conducted that quarter.
 - (VI) Exclude monitoring of nitrogen dioxide (NO₂) for rich-burn engines, unless source testing

demonstrates that NO₂ is more than 10 percent of total NO_x.

- (VII) Conduct daily calibration error (CE) tests by injecting calibration gases at the analyzers, except that at least once per week the CE test shall be conducted by injecting calibration gases as close to the probe tip as practical.
- (VIII Stop operating and calibrating the CEMs during any) period that the operator has a continuous record that the engine was not in operation.
- (vii) A CO CEMS shall not be required for lean-burn engines or an engine that is subject to Regulation XX (RECLAIM), and not required to have a NO_x CEMS by that regulation.
- (viii) Notwithstanding the requirements of this paragraph and paragraph (c)(2) of Rule 2012, an operator may take an existing NO_x CEMS out of service for up to two weeks (cumulative) in order to modify the CEMS to add CO monitoring.
- (ix) In lieu of clause (f)(1)(A)(i), an Essential Public Service or a contractor for an Essential Public Service that is operating a biogas engine of 1000 bhp and greater and less than 1200 bhp, may alternatively comply with the Inspection and Monitoring Plan requirements of subparagraph (f)(1)(D), provided the operator conducts diagnostic emission checks at least weekly or every 150 operating hours, whichever occurs later.
- (x) If an Essential Public Service or a contractor for an Essential Public Service has elected to comply with the Inspection and Monitoring Plan provisions pursuant to clause (f)(1)(A)(ix) for biogas engines is found to exceed an applicable NO_x or CO limit by a source test required by subparagraph (f)(1)(C) or South Coast AQMD test using a portable analyzer on three or more occasions in any 12-month period, the operator shall comply with the CEMS requirements of clause (f)(1)(A)(i) for such biogas engine in accordance with the compliance schedule of Table VII except that the

operator shall submit a CEMS application to the Executive Officer within six months of the third exceedance.

- (f) (B) Elapsed Time Meter
Maintain an operational non-resettable totalizing time meter to determine the engine elapsed operating time.
- (C) Source Testing
 - (i) Effective August 1, 2008, conduct source testing for NO_x, VOC reported as carbon, and CO concentrations (concentrations in ppm by volume, corrected to 15 percent oxygen on dry basis) at least once every two years from the date of the previous source test, no later than the last day of the calendar month that the test is due, or every 8,760 operating hours, whichever occurs first. Relative accuracy tests required by Rule 218.1 or 40 CFR Part 75 Subpart E shall satisfy this requirement for those pollutants monitored by a CEMS. The above source test frequency may be reduced to once every three years if the engine has operated less than 2,000 hours since the last source test. If the engine has not been operated before the date a source test is due, the source test shall be conducted by the end of seven consecutive days or 15 cumulative days of resumed operation. The operator of the engine shall keep sufficient operating records to demonstrate that it meets the requirements for extension of the source testing deadlines.
 - (ii) Conduct source testing for at least 30 minutes during normal operation (actual duty cycle). This test shall not be conducted under a steady-state condition unless it is the normal operation. In addition, conduct source testing for NO_x and CO emissions for at least 15 minutes at: an engine's actual peak load, or the maximum load that can be practically achieved during the test, and; at actual minimum load, excluding idle, or the minimum load that can be practically achieved during the test. These additional two tests are not required if the permit limits the engine to operating at one defined load, ± 10%. No pre-tests for compliance are permitted. The emission test shall be

conducted at least 40 operating hours, or at least 1 week, after any engine servicing or tuning. If an emission exceedance is found during any of the three phases of the test, that phase shall be completed and reported. The operator shall correct the exceedance, and the source test may be immediately resumed. Relative accuracy tests required by Rule 218.1 or 40 CFR Part 75 Subpart E shall satisfy this requirement for those pollutants monitored by a CEMS for all applicable operating loads specified in this clause (f)(1)(C)(ii).

- (iii) Use a contractor to conduct the source testing that is approved by the Executive Officer under the Laboratory Approval Program for the necessary test methods.
- (iv) Submit a source test protocol to the Executive Officer for written approval at least 60 days before the scheduled date of the test. The source test protocol shall include the name, address and phone number of the engine operator and a South Coast AQMD-approved source testing contractor that will conduct the test, the application and permit number(s), emission limits, a description of the engine(s) to be tested, the test methods and procedures to be used, the number of tests to be conducted and under what loads, the required minimum sampling time for the VOC test, based on the analytical detection limit and expected VOC levels, and a description of the parameters to be measured in accordance with the I&M plan required by subparagraph (f)(1)(D). The source test protocol shall be approved by the Executive Officer prior to any testing. The operator is not required to submit a protocol for approval if: there is a previously approved protocol that meets these requirements; the engine has not been altered in a manner that requires a permit alteration; and emission limits have not changed since the previous test. If the operator submits the protocol by the required date, and the Executive Officer takes longer than 60 days to approve the protocol, the operator shall be allowed the additional time needed to conduct the test.

(f)

- (v) Provide the Executive Officer at least 30 days prior notice of any source test to afford the Executive Officer the opportunity to have an observer present. If after 30 days notice for an initially scheduled performance test, there is a delay (due to operational problems, etc.) in conducting the scheduled performance test, the engine operator shall notify the Executive Officer as soon as possible of any delay in the original test date, either by providing at least seven days prior notice of the rescheduled date of the performance test, or by arranging a rescheduled date with the Executive Officer by mutual agreement.
 - (vi) Submit all source test reports, including a description of the equipment tested, to the Executive Officer within 60 days of completion of the test.
 - (vii) By February 1, 2009, provide, or cause to be provided, source testing facilities as follows:
 - (I) Sampling ports adequate for the applicable test methods. This includes constructing the air pollution control system and stack or duct such that pollutant concentrations can be accurately determined by applicable test methods;
 - (II) Safe sampling platform(s), scaffolding or mechanical lifts, including safe access, that comply with California General Safety Orders. Agricultural stationary engines are excused from this subclause if they are in remote locations without electrical power;
 - (III) Utilities for sampling and testing equipment. Agricultural stationary engines are exempt from this subclause if they are on wheels and moved to storage during the off season.
 - (D) Inspection and Monitoring (I&M) Requirements
 - (i) I&M Plan. The operator shall:
 - (I) Submit to the Executive Officer for written approval an I&M plan. One plan application is required for each facility that does not have a NO_x and CO
- (f)

CEMS for each engine. The I&M plan shall include all items listed in Attachment 1. ~~The owner or operator may request an alternative item(s) in Attachment 1 that is determined by the Executive Officer to be equivalent in meeting the same objectives.~~

- (II) Upon written approval by the Executive Officer, implement the I&M plan as approved.
 - (III) Submit an I&M plan for approval to the Executive Officer for a plan revision before any change in I&M plan operations can be implemented. The operator shall apply for a plan revision prior to any change in emission limits or control equipment.
- (ii) Diagnostic emission checks by a portable NO_x, CO, and oxygen analyzer shall be conducted at least weekly or every 150 engine operating hours, whichever occurs later.
- (I) If an engine is in compliance for three consecutive diagnostic emission checks, without any adjustments to the oxygen sensor set points, then the engine may be checked monthly or every 750 engine operating hours, whichever occurs later, until there is a noncompliant diagnostic emission check or, for rich-burn engines with three-way catalysts, until the oxygen sensor is replaced. When making adjustments to the oxygen sensor set points that are not within 72 hours prior to the diagnostic emission check, returning to a more frequent diagnostic emission check schedule is not required if the engine is in compliance with the applicable emission limits prior to and after the set point adjustments.
 - (II) For diesel engines and other lean-burn engines that operate at a RECLAIM or former RECLAIM facility or have a NO_x CEMS, and that are subject to a CO limit more stringent than the 2000 ppmvd limit of Tables II or III, a CO diagnostic emission check shall
- (f)

be performed at least quarterly, or every 2,000 engine operating hours, whichever occurs later.

- (III) For diesel engines and other lean-burn engines that operate at a RECLAIM or former RECLAIM facility or have a NOx CEMS, and that are not subject to a CO limit more stringent than the 2000 ppmvd limit of Tables II or III, diagnostic emission checks are not required.
 - (IV) No engine or control system maintenance or tuning may be conducted within 72 hours prior to the diagnostic emission check, unless it is an unscheduled, required repair.
 - (V) The portable analyzer shall be calibrated, maintained and operated in accordance with the manufacturer's specifications and recommendations and in accordance with the South Coast AQMD's Combustion Gas Periodic Monitoring Protocol for the Periodic Monitoring of Nitrogen Oxides, Carbon Monoxide, and Oxygen from Combustion Sources Subject to Rules 1110.2, 1146, and 1146.1, or any subsequent protocol approved by U.S. EPA and the Executive Officer.
- (iii) Requirements for responding to, diagnosing and correcting breakdowns, faults, malfunctions, alarms, diagnostic emission checks finding emissions in excess of rule or permit limits, and parameters out-of-range.
- (I) For any diagnostic emission check or breakdown that results in emissions in excess of those allowed by this rule or a permit condition, the operator shall correct the problem as soon as possible and demonstrate compliance with another diagnostic emission check, or shut down an engine by the end of an operating cycle, or within 24 hours from the time the operator knew of the breakdown or excess emissions, or reasonably should have known, whichever is sooner.
- (f)

- (II) For excess emissions due to breakdowns that result in NO_x or CO emissions greater than the concentrations specified in Table VIII, the operator shall not be considered in violation of this rule if the operator demonstrates the all of the following: (1) compliance with subclause (f)(1)(D)(iii)(I), (2) compliance with the reporting requirements of subparagraph (f)(1)(H), and (3) the engine with excess emissions has no more than three incidences of breakdowns with emissions exceeding Table VIII limits in the calendar quarter.

TABLE VIII EXCESS EMISSION CONCENTRATION THRESHOLDS FOR BREAKDOWNS		
	NO _x (ppmvd) ¹	CO (ppmvd) ¹
Lean-Burn Engines	45	250
Rich-Burn Engines	150	2000
Biogas Engines ²	185	2000

¹ Corrected to 15% oxygen.

² Effective up to the time of compliance with the limits specified in Table III-B, after which the thresholds revert to the applicable lean or rich-burn engine limits.

- (III) Any emission check conducted by South Coast AQMD staff that finds excess emissions will be treated as a violation.
 - (IV) For other problems, such as parameters out-of-range, an operator shall correct the problem and demonstrate compliance with another diagnostic emission check within 48 hours of the operator first knowing of the problem.
 - (iv) If an engine has a NO_x CEMS and does not have a CO CEMS, it is subject to this subparagraph (f)(1)(D) as it pertains to CO only.
- (f)

(E) Operating Log

Maintain a monthly engine operating log that includes:

- (i) Total hours of operation;
- (ii) Type of liquid and/or type of gaseous fuel;
- (iii) Fuel consumption (cubic feet of gas and gallons of liquid);
and
- (iv) Cumulative hours of operation since the last source test required in subparagraph (f)(1)(C).

Facilities subject to Regulation XX may maintain a quarterly log for engines that are designated as a process unit on the facility permit until such time that the facility becomes a former RECLAIM facility. The facility shall maintain a monthly engine log starting in the month that it has become a former RECLAIM facility.

(F) New Non-Emergency Electrical Generating Engines

Operators of engines subject to the requirements of subparagraph (d)(1)(L) shall also meet the following requirements.

- (i) The engine generator shall be monitored with a calibrated electric meter that measures the net electrical output of the engine generator system, which is the difference between the electrical output of the generator and the electricity consumed by the auxiliary equipment necessary to operate the engine generator.
- (ii) For engines monitored with a CEMS, the emissions of the monitored pollutants in ppmvd corrected to 15% O₂, lbs/hr, and lbs/MW_e-hr and the net MW_e-hrs produced shall be calculated and recorded for the four 15-minute periods of each hour of operation. The mass emissions of NO_x shall be calculated based on the measured fuel flow and one of the F factor methods of 40 CFR Part 60, Appendix A, Method 19, or other method approved by the Executive Officer. Mass emissions of CO shall be calculated in the same manner as NO_x, except that the ppmvd CO shall be converted to lb/scf using a conversion factor of 0.727×10^{-7} .
- (f) (iii) For NO_x and CO emissions from engines not monitored with a CEMS and VOC emissions from all engines, the

emissions of NO_x, CO and VOC in lbs/MW_e-hr shall be calculated and recorded whenever the pollutant is measured by a source test or diagnostic emission check. Mass emissions of NO_x and CO shall be calculated in the same manner as the previous clause. Mass emissions of VOC shall be calculated in the same manner, except that the ppmvd VOC as carbon shall be converted to lb/scf using a conversion factor of 0.415×10^{-7} .

- (iv) For engines generating combined heat and power that rely on the EEF to comply with Table IV emission standards, the daily and annual useful heat recovered (MW_{th}-hrs), net electrical energy generated (MW_e-hrs) and EEF shall be monitored and recorded.
- (v) Other methods of calculating mass emissions than those specified, such as by direct measurement of exhaust volume, may be used if approved by the Executive Officer. All monitoring, calculation, and recordkeeping procedures must be approved by the Executive Officer.
- (vi) Operators of combined heat and power engines shall submit to the Executive Officer the reports of the following information within 15 days of the end of the first year of operation, and thereafter within 15 days of the end of each calendar year: the annual net electrical energy generated (MW_e-hrs); the annual useful heat recovered (MW_{th}-hrs), the annual EEF calculated in accordance with clause (d)(1)(L)(ii); and the maximum annual EEF allowed by the operating permit. If the actual annual EEF exceeds the allowed EEF, the report shall also include the time periods and emissions for all instances where emissions exceeded any emission standard in Table IV.

(G) Portable Analyzer Operator Training

- (f) The portable analyzer tests required by the I&M Plan requirements of subparagraph (f)(1)(D) shall only be conducted by a person who has completed an appropriate South Coast AQMD-approved training program in the operation of portable analyzers and has received a certification issued by the District.

(H) Reporting Requirements

- (i) The operator shall report to the Executive Officer, by telephone (1-800-CUT-SMOG or 1-800-288-7664) or other South Coast AQMD-approved method, any breakdown resulting in emissions in excess of rule or permit emission limits within one hour of such noncompliance or within one hour of the time the operator knew or reasonably should have known of its occurrence. Such report shall identify the time, specific location, equipment involved, responsible party to contact for further information, and to the extent known, the causes of the noncompliance, and the estimated time for repairs. In the case of emergencies that prevent a person from reporting all required information within the one-hour limit, the Executive Officer may extend the time for the reporting of required information provided the operator has notified the Executive Officer of the noncompliance within the one-hour limit.
- (ii) Within seven calendar days after the reported breakdown has been corrected, but no later than thirty calendar days from the initial date of the breakdown, unless an extension has been approved in writing by the Executive Officer, the operator shall submit a written breakdown report to the Executive Officer which includes:
 - (I) An identification of the equipment involved in causing, or suspected of having caused, or having been affected by the breakdown;
 - (II) The duration of the breakdown;
 - (III) The date of correction and information demonstrating that compliance is achieved;
 - (IV) An identification of the types of excess emissions, if any, resulting from the breakdown;
 - (V) A quantification of the excess emissions, if any, resulting from the breakdown and the basis used to quantify the emissions;

(f)

- (VI) Information substantiating whether the breakdown resulted from operator error, neglect or improper operation or maintenance procedures;
 - (VII) Information substantiating that steps were immediately taken to correct the condition causing the breakdown, and to minimize the emissions, if any, resulting from the breakdown;
 - (VIII) A description of the corrective measures undertaken and/or to be undertaken to avoid such a breakdown in the future; and
 - (IX) Pictures of any equipment which failed, if available.
- (iii) Within 15 days of the end of each calendar quarter, the operator shall submit to the Executive Officer a report that lists each occurrence of a breakdown, fault, malfunction, alarm, engine or control system operating parameter out of the acceptable range established by an I&M plan or permit condition, or a diagnostic emission check that finds excess emissions. Such report shall be in a South Coast AQMD-approved format, and for each incident shall identify the time of the incident, the time the operator learned of the incident, specific location, equipment involved, responsible party to contact for further information, to the extent known the causes of the event, the time and description of corrective actions, including shutting an engine down, and the results of all portable analyzer NOx and CO emissions checks done before or after the corrective actions. The operator shall also report if no incidents occurred.
- (2) Portable engines:
The operator of any portable engine shall maintain a monthly engine operating log that includes:
- (i) Total hours of operation; or
 - (ii) Type of liquid and/or type of gaseous fuel; and
 - (iii) Fuel consumption (cubic feet of gas and gallons of liquid).
- Facilities subject to Regulation XX may maintain a quarterly log for engines that are designated as a process unit on the facility permit until such time that the facility becomes a former RECLAIM facility.
- (f)

shall maintain a monthly engine log starting in the month that it has become a former RECLAIM facility.

(3) Recordkeeping for All Engines

All data, logs, test reports and other information required by this rule shall be maintained for at least five years and made available for inspection by the Executive Officer.

(g) Test Methods

Testing to verify compliance with the applicable requirements shall be conducted in accordance with the test methods specified in Table IX, or any test methods approved by CARB and EPA, and authorized by the Executive Officer.

TABLE IX TESTING METHODS	
Pollutant	Method
NO _x	South Coast Air Quality Management District Method 100.1
CO	South Coast Air Quality Management District Method 100.1
VOC	South Coast Air Quality Management District Method 25.1* or Method 25.3*

* Excluding ethane and methane

A violation of any standard of this rule established by any of the specified test methods, or any test methods approved by the CARB or EPA, and authorized by the Executive Officer, shall constitute a violation of this rule.

(h) Alternate Compliance Option

(1) In lieu of complying with the applicable emission limits by the effective date specified in Table III-B or subparagraph (d)(1)(F), owners or operators of biogas-fired units may elect to defer compliance in quarterly increments up to one additional year, provided the owner or operator:

(A) Submits an alternate compliance plan and pays a Compliance Flexibility Fee, as provided for in paragraph (h)(2), to the Executive Officer at least 60 days prior to the applicable compliance date in either Table III-B or subparagraph (d)(1)(F) for qualified biogas technology demonstration project engines, and

(B) Maintains on-site a copy of verification of Compliance Flexibility Fee payment and South Coast AQMD approval of the alternate compliance plan that shall be made available upon request to South Coast AQMD staff.

(2) Plan Submittal

The alternate compliance plan submitted pursuant to paragraph (h)(1) shall include:

- (A) A completed South Coast AQMD Form 400A with company name, South Coast AQMD Facility ID, identification that application is for a compliance plan (Section 7a of form), and identification that request is for Rule 1110.2 Compliance Flexibility Fee option (Section 9 of form);
- (B) Attached documentation of unit permit ID, unit rated brake horsepower (bhp), and fee calculation;
- (C) Filing Fee payment; and
- (D) Compliance Flexibility Fee payment as calculated by the following equation:

$$\text{CFF} = \text{bhp} \times \text{R} \times \text{Q}$$

Where,

CFF = Compliance Flexibility Fee, \$

bhp = rated brake horsepower of unit

R = Fee Rate = \$11.75 per brake horsepower per quarter

Q = Number of quarters (up to four)

(3) Usage of Compliance Flexibility Fee funds

The funds collected from the Compliance Flexibility Fee will be applied to South Coast AQMD NOx reduction programs pursuant to protocols approved under South Coast AQMD rules.

(i) Exemptions

(1) The provisions of subdivision (d) shall not apply to:

- (A) All orchard wind machines powered by an internal combustion engine.
- (B) Emergency standby engines, engines used for fire-fighting and flood control, and any other emergency engines approved by the Executive Officer, which have permit conditions that limit operation to 200 hours or less per year as determined by an

elapsed operating time meter, and agricultural emergency standby engines that are exempt from a South Coast AQMD permit and operate 200 hours or less per year as determined by an elapsed operating time meter.

- (C) Laboratory engines used in research and testing purposes.
- (D) Engines operated for purposes of performance verification and testing of engines.
- (E) Auxiliary engines used to power other engines or gas turbines during start-ups.
- (F) Portable engines that are registered under the state registration program pursuant to Title 13, Article 5 of the CCR.
- (G) Nonroad engines, with the exception that subparagraph (d)(2)(A) shall apply to portable generators.
- (H) Engines operating on San Clemente Island.
- (I) Agricultural stationary engines provided that:
 - (i) The operator submits documentation to the Executive Officer by the applicable date in Table V when permit applications are due that the applicable electric utility has rejected an application for an electrical line extension to the location of the engines, or the Executive Officer determines that the operator does not qualify, due to no fault of the operator, for funding authorized by California Health and Safety Code Section 44229; and
 - (ii) The operator replaces the engines, in accordance with the compliance schedule of Table X, with engines certified by CARB to meet the Tier 4 emission standards of 40 CFR Part 1039 Section 1039.101, Table 1. These Tier 4 replacement engines shall be considered to comply with Best Available Control Technology; and
 - (iii) The operator does not operate the Tier 4 engines in a manner that exceeds the not-to-exceed standards of 40 CFR Part 1039 Section 1039.101(e), as determined by the test methods of subdivision (g) of this rule.

(i)

TABLE X COMPLIANCE SCHEDULE FOR INSTALLATION OF NEW TIER 4 STATIONARY AGRICULTURAL ENGINES	
Action Required	Due Date
Submit to the Executive Officer applications for permits to construct engine modifications, control equipment, or replacement engines	March 1, 2013
Initiate construction of engine modifications, control equipment, or replacement engines	September 30, 2013, or 30 days after the permit to construct is issued, whichever is later
Complete construction and comply with applicable requirements	January 1, 2014, or 60 days after the permit to construct is issued, whichever is later
Complete initial source testing	March 1, 2014, or 120 days after the permit to construct is issued, whichever is later

- (J) An engine start-up, until sufficient operating temperatures are reached for proper operation of the emission control equipment or for the tuning of the engine and/or emission control equipment, and an engine shutdown period. The periods shall not exceed 30 minutes, unless the Executive Officer approves in writing a longer period not exceeding two hours for an engine and makes it a condition of the engine permit.
- (K) An engine start-up, after an engine overhaul or major repair requiring removal of a cylinder head or for the installation or the replacement of catalytic emission control equipment, for a period not to exceed four operating hours.
- (L) The initial commissioning of a new engine for a period specified by permit conditions, provided the operator takes measures to reduce emissions and the duration of the commissioning to the extent possible. The commissioning period shall not exceed 150 operating hours.

- (i) (M) An engine used exclusively for electrical generation at remote two-way radio transmission towers where no utility, electricity, or natural gas is available within a ½ mile radius, has a manufacturer’s rating of 100 bhp or less, and is fired exclusively on diesel #2, compressed natural gas, or liquefied petroleum gas.
- (N) Any engine at a RECLAIM or former RECLAIM facility that is subject to a NOx emission limit in a different rule for an industry-specific category defined in Rule 1100 – Implementation Schedule for NOx facilities.
- (O) An engine operated in either the Southern California Coastal Waters or Outer Continental Shelf Waters provided:
 - (i) The engine is used to power a crane;
 - (ii) The engine is certified by CARB to meet the Tier 4 – Final emission standards of 40 CFR Part 1039 Section 1039.101 Table 1;
 - (iii) The engine is operated per the specifications of the engine manufacturer; and
 - (iv) The operator submits an I&M Plan to the Executive Officer for approval and implementation, pursuant to the requirements of subparagraph (f)(1)(D).
- (2) The facility operator of MM PRIMA DESHECHA ENERGY, LLC, or any of its successors, shall not be required to meet the emissions requirements specified in Table III-B if they submit a detailed retirement plan that is approved by the Executive Officer for the permanent shutdown of all equipment subject to Rule 1110.2 by October 1, 2022. The plan shall describe in detail the steps and schedule that will be taken to remove the equipment or render the equipment permanently inoperable by October 1, 2022 and shall require the surrendering of the permits for the equipment by that date. The plan shall be submitted before July 1, 2016 and include:
 - (A) South Coast AQMD Form 400A with company name, South Coast AQMD Facility ID, and permit number(s) for the subject equipment; and
 - (B) Filing Fee payment pursuant to Rule 306.The Executive Officer shall act on the plan before January 1, 2017.

- (i) (3) The provisions of this rule shall not apply to engines~~units~~ located at landfills or publicly owned treatment works that are subject to a NOx emission limit in a Regulation XI rule adopted or amended after November 1, 2019.

ATTACHMENT 1

An I&M Plan submitted to the Executive Officer for approval and implementation, pursuant to the requirements of paragraphs (e)(4) and (e)(6), and subparagraph (f)(1)(D) of the rule, shall include:

- A. Identification of engine and control equipment operating parameters necessary to maintain pollutant concentrations within the rule and permit limits. This shall include, but not be limited to:
 - 1. Procedures for using a portable NO_x, CO and oxygen analyzer to establish the set points of the air-to-fuel ratio controller (AFRC) at 25%, 60% and 95% load (or fuel flow rate), $\pm 5\%$, or the minimum, midpoint and maximum loads that actually occur during normal operation, $\pm 5\%$, or at any one load within the $\pm 10\%$ range that an engine permit is limited to in accordance with clause (f)(1)(C)(ii) of the rule;
 - 2. Procedures for verifying that the AFRC is controlling the engine to the set point during the daily monitoring required by subdivision D of this attachment;
 - 3. Procedures for reestablishing all AFRC set points with a portable NO_x, CO and oxygen analyzer whenever a set point must be readjusted, within 24 hours of an oxygen sensor replacement, and, for rich-burn engines with three way catalysts, between 100 and 150 engine operating hours after an oxygen sensor replacement;
 - 4. For engines with catalysts, the maximum allowed exhaust temperature at the catalyst inlet, based on catalyst manufacturer specifications;
 - 5. For lean-burn engines with selective catalytic control devices, the minimum exhaust temperature at the catalyst inlet required for reactant flow (ammonia or urea), and procedures for using a portable NO_x and oxygen analyzer to establish the acceptable range of reactant flow rate, as a function of load.

Parameter monitoring is not required for diesel engines without exhaust gas recirculation and catalytic exhaust control devices.
- B. Procedures for alerting the operator to emission control malfunctions. Engine control systems, such as air-to-fuel ratio controllers, shall have a malfunction indicator light and audible alarm.
- C. Procedures for diagnostic emission checks conducted by a portable NO_x, CO, and oxygen analyzer per the requirements of clause (f)(1)(D)(ii) of the rule.
- D. Procedures for at least daily monitoring, inspection and recordkeeping of:

1. engine load or fuel flow rate;
2. the set points, maximums and acceptable ranges of the parameters identified by subdivision A of this attachment, and the actual values of the same parameters;
3. the engine elapsed time meter operating hours;
4. the operating hours since the last diagnostic emission check required by clause (f)(1)(D)(ii) of the rule;
5. for rich-burn engines with three-way catalysts, the difference of the exhaust temperatures (ΔT) at the inlet and outlet of the catalyst (changes in the ΔT can indicate changes in the effectiveness of the catalyst);
6. engine control system and AFRC system faults or alarms that affect emissions.

The daily monitoring and recordkeeping may be done in person by the operator, or by remote monitoring.

- E. Procedures for responding to, diagnosing and correcting breakdowns, faults, malfunctions, alarms, diagnostic emission checks finding emissions in excess of rule or permit limits, and parameters out-of-range, per the requirements of clause (f)(1)(D)(iii) of the rule.
- F. Procedures and schedules for preventive and corrective maintenance.
- G. Procedures for reporting noncompliance to the Executive Officer in accordance with subparagraph (f)(1)(H) of the rule.
- H. Procedures and format for the recordkeeping of monitoring and other actions required by the plan.

ATTACHMENT H

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

Final Staff Report

Proposed Rule 1110.3 – Emissions from Linear Generators

Proposed Amended Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines

November 2023

Deputy Executive Officer

Planning, Rule Development, and Implementation
Sarah L. Rees, Ph.D.

Assistant Deputy Executive Officer

Planning, Rule Development, and Implementation
Michael Krause

Planning and Rules Manager

Planning, Rule Development, and Implementation
Michael Morris

Author: Hay Lo – Air Quality Specialist

Contributors: Jason Aspell – Deputy Executive Officer
Christian Aviles – Air Quality Engineer
Rodolfo Chacon – Program Supervisor
Chhai Chorn – Air Quality Engineer
Bahareh Farahani – Program Supervisor
Monica Fernandez-Neild – Supervising Air Quality Engineer
Farzaneh Khalaj, Ph.D. – Assistant Air Quality Specialist
Kate Kim – Senior Air Quality Engineer
Shannon Lee, P.E. – Senior Air Quality Engineering Manager
Tommy Mai – Supervising Air Quality Engineer
Kevin Ni – Acting Program Supervisor, CEQA
Kevin Orellana – Senior Enforcement Manager
Barbara Radlein – Acting Planning and Rules Manager, CEQA
Xian-Liang (Tony) Tian – Program Supervisor
Bill Welch – Source Testing Manager

Reviewed By: Isabelle Shine – Program Supervisor
Stacey Pruitt – Senior Deputy District Counsel

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
GOVERNING BOARD**

Chair: VANESSA DELGADO
Senator (Ret.)
Senate Rules Committee Appointee

Vice-Chair: MICHAEL A. CACCIOTTI
Council Member, South Pasadena
Cities of Los Angeles County/Eastern Region

MEMBERS:

ANDREW DO
Supervisor, First District
County of Orange

CURT HAGMAN
Supervisor, Fourth District
County of San Bernardino

GIDEON KRACOV
Governor's Appointee

PATRICIA LOCK DAWSON
Mayor, Riverside
Cities of Riverside County Representative

LARRY MCCALLON
Mayor, Highland
Cities of San Bernardino County

HOLLY J. MITCHELL
Supervisor, Second District
County of Los Angeles

VERONICA PADILLA-CAMPOS
Speaker of the Assembly Appointee

V. MANUEL PEREZ
Supervisor, Fourth District
County of Riverside

NITHYA RAMAN
Council Member, Fourth District
City of Los Angeles Representative

CARLOS RODRIGUEZ
Council Member, Yorba Linda
Cities of Orange County

JOSÉ LUIS SOLACHE
Council Member, Lynwood
Cities of Los Angeles County/Western Region

EXECUTIVE OFFICER:

WAYNE NASTRI

TABLE OF CONTENTS

EXECUTIVE SUMMARY.....	EX-1
CHAPTER 1: BACKGROUND	
INTRODUCTION.....	1-1
BACKGROUND.....	1-1
REGULATORY HISTORY	1-2
AFFECTED FACILITIES AND EQUIPMENT	1-3
PUBLIC PROCESS	1-3
CHAPTER 2: SUMMARY OF PROPOSAL	
INTRODUCTION	2-1
PROPOSED RULE 1110.3.....	2-1
PROPOSED AMENDED RULE 1110.2.....	2-6
CHAPTER 3: IMPACT ASSESSMENTS	
INTRODUCTION	3-1
COSTS	3-1
EMISSION REDUCTIONS	3-1
COST-EFFECTIVENESS	3-1
INCREMENTAL COST-EFFECTIVENESS	3-1
SOCIOECONOMIC <u>IMPACT</u> ASSESSMENT	3-2
CALIFORNIA ENVIRONMENTAL QUALITY ACT ANALYSIS	3-2
DRAFT FINDINGS UNDER HEALTH AND SAFETY CODE SECTION 40727...	3-2
COMPARATIVE ANALYSIS	3-3
APPENDIX A – LIST OF AFFECTED FACILITIES.....	A-1
APPENDIX B – RESPONSES TO PUBLIC COMMENTS.....	B-1

EXECUTIVE SUMMARY

Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines is a source-specific rule which applies to non-RECLAIM facilities and RECLAIM facilities with engines greater than 50 rated brake horsepower. The rule was last amended in 2019 to implement Control Measure CMB-05 of the Final 2016 Air Quality Management Plan. During the rule development process, linear generators were introduced as an alternative technology to reduce emissions and stakeholders commented on the unique characteristics of linear generators. Unlike internal combustion engines (ICEs), linear generators produce electricity by driving magnets through copper coils in a linear motion. One unique feature of linear generators is that the thermochemical reaction takes place at lower temperatures than ICE, which results in lower emissions without add-on control devices (e.g., selective catalytic reduction). In addition, linear generators utilize a parametric monitoring system that monitors performance and controls emission levels. Linear generators are currently being used for prime power applications but can also be used for emergency backup power, and are considered a technology that can potentially assist in implementing Control Measure L-CMB-04 of the Final 2022 Air Quality Management Plan. In response to stakeholder comments, Proposed Rule 1110.3 – Emissions from Linear Generators (PR 1110.3), is being developed to allow for specific considerations of the technology and capabilities of linear generators.

Currently, a total of six units with Permits to Operate and 82 Permits to Construct will be affected by PR 1110.3. It is possible that the number of units subject to PR 1110.3 in the future might be considerably more as the technology matures. PR 1110.3 establishes emission limits for linear generators as well as source testing, reporting, and recordkeeping requirements. Proposed Amended Rule 1110.2 (PAR 1110.2) will remove provisions currently applicable to linear generators.

PR 1110.3 and PAR 1110.2 were developed through a public process. Staff held three Working Group Meetings on November 9, 2022, December 8, 2022, and February 23, 2023. In addition, a Public Workshop was held on January 25, 2023.

CHAPTER 1: BACKGROUND

INTRODUCTION

BACKGROUND

REGULATORY HISTORY

AFFECTED FACILITIES AND EQUIPMENT

PUBLIC PROCESS

INTRODUCTION

Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines (Rule 1110.2) is source-specific rule which applies to facilities with engines greater than 50 rated brake horsepower. Rule 1110.2 currently regulates linear generators and specifies emission limits and other requirements applicable to linear generators. In response to stakeholder comments, PR 1110.3 is being developed to allow for specific considerations of the technology and capabilities of linear generators. PR 1110.3 will establish emission limits for linear generators, as well as testing, monitoring and reporting, and recordkeeping requirements. In addition, Rule 1110.2 will be amended to remove provisions currently applicable to linear generators.

BACKGROUND

Rule 1110.2 applies to all stationary and portable engines greater than 50 rated brake horsepower. Rule 1110.2 was last amended in 2019 to implement Control Measure CMB-05 of the Final 2016 Air Quality Management Plan (2016 AQMP). During the rule development process, linear generator technology was introduced as an option to further reduce NOx emissions. At that time, it was estimated that emissions from linear generators would approach California Air Resources Board's (CARB) Distributed Generation (DG) levels.

Staff is aware of two manufacturers of linear generators. Unlike ICEs, linear generators produce electricity by driving magnets through copper coils in a linear motion (see Figures 1 and 2). In this process, a mixture of fuel and air are compressed, causing a chemical reaction that drives the linear motion. One of the features that makes linear generators unique is that this thermochemical reaction occurs at lower temperatures than internal combustion engines, resulting in lower NOx and CO emissions. Linear generators also do not need add-on control technologies such as selective catalytic reduction (SCR) to reduce NOx to near-zero emissions. Although some may be equipped with an oxidation catalyst, they are not dependent on this catalyst to reach a destruction temperature and thus, start-up emissions are low. For those linear generators that are equipped with an oxidation catalyst, due to the lower reaction temperatures, the oxidation catalyst's ability to control VOC emissions is limited and its main function is to reduce CO emissions. In addition, linear generators utilize a parametric monitoring system to maintain proper fuel and air injection to meet energy demands. The parametric monitoring system works by monitoring and adjusting air and fuel flow to ensure proper air-to-fuel ratio is achieved, which also ensures emissions are under control. Finally, linear generators have the ability to operate on different fuels without any hardware changes to the equipment. However, staff has only received source test data for natural gas fueled units; source test data was not provided for other fuel types.




Figure 1. Mainspring Linear Generator Components¹




Figure 2. Hyliion Karno Linear Generator Components²

At the time of its introduction, linear generators were being used as a stationary prime power source at facilities, but it is anticipated that they can be configured as portable units and can also be used for emergency applications. In response to stakeholder comments highlighting the unique characteristics of linear generators, PR 1110.3 is being developed to allow for specific considerations of linear generator technology running solely on natural gas. PR 1110.3 establishes emission limits for linear generators as well as testing, reporting, and recordkeeping requirements. PAR 1110.2 will remove provisions currently applicable to linear generators.

REGULATORY HISTORY

Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines

South Coast AQMD Rule 1110.2 was adopted on August 3, 1990 and was last amended on November 1, 2019. Rule 1110.2 applies to stationary and portable engines greater than 50 rated brake horsepower. The 2019 amendment of Rule 1110.2 included concentration limits for new electrical generating devices in addition to the listed emission standards expressed as pounds of NO_x per Megawatt-Hour. Additionally, the 2019 amendments added a provision which allowed new engines installed prior to January 1, 2024 that can achieve NO_x concentration limits at all times with no ammonia emissions from add-on equipment to meet an interim VOC concentration

¹ <https://www.greentechmedia.com/articles/read/mainspring-energys-linear-generators-to-roll-out-through-150m-deal-with-nextera>

² <https://www.hyliion.com/karno/>

limit of 25 parts per million by volume, dry (ppmvd). This provision was added to Rule 1110.2 to account for the introduction of linear generator technology.

In addition to the emission limits, Rule 1110.2 included a cap on the number of units that can be installed while meeting the alternative VOC concentration limit of 25 ppmvd to ensure that the VOC emissions from such engines would not exceed South Coast AQMD's air quality significance threshold for operational VOCs (e.g., 55 pounds per day) under the California Environmental Quality Act (CEQA)³. Based on calculations, staff recommended a total VOC emission cap not to exceed 45 pounds per day of VOC which provided 10 pounds per day to allow for any differences in variables such as generator size and operational hours.

AFFECTED FACILITIES AND EQUIPMENT

PR 1110.3 applies to all linear generators and based on permitting data and South Coast AQMD databases, staff identified 88 applications submitted at 22 facilities that meet the applicability requirements of PR 1110.3. Table 1 contains the facility applications and permits affected by PR 1110.3.

TABLE 1
PR 1110.3 AFFECTED FACILITY APPLICATIONS & PERMITS

Application Status	
Permit to Construct Issued	82
Permit to Operate Granted	6
Applications Cancelled	6
Applications Rejected	2
Total	96

PUBLIC PROCESS

The development of PR 1110.3 and PAR 1110.2 was conducted through a public process. Working Group Meetings were held on November 9, 2022, December 8, 2022, and February 23, 2023. The Working Group Meetings included representatives from affected facilities, environmental and community groups, other agencies, consultants, and interested parties. The purpose of the Working Group Meetings was to discuss details of PR 1110.3 and PAR 1110.2 and to listen to concerns and issues with the objective to build consensus and resolve key issues.

In addition, one Public Workshop was held on January 25, 2023. The purpose of the Public Workshop was to present the proposed amended rule language to the public and to stakeholders and to solicit comments.

³ South Coast AQMD Air Quality Significance Thresholds, March 2023, <http://www.aqmd.gov/docs/default-source/ceqa/handbook/south-coast-aqmd-air-quality-significance-thresholds.pdf>

CHAPTER 2: SUMMARY OF PROPOSAL

INTRODUCTION

PROPOSED RULE 1110.3

PROPOSED AMENDED RULE 1110.2

INTRODUCTION

Linear generators were first considered by South Coast AQMD during the 2019 amendment of Rule 1110.2. Based on staff's evaluation of the technology, and in response to a manufacturer's request, regulatory provisions for linear generators were included in Rule 1110.2 at that time. As such, emissions from linear generators are currently regulated by Rule 1110.2. However, due to the unique characteristics of linear generators, a separate rule, PR 1110.3, will specifically address linear generator technology and establish concentration-based emission limits, as well as other requirements. In addition, Rule 1110.2 will be amended to remove the provisions applicable to linear generators. The following provides a discussion of the various changes proposed in PR 1110.3 and PAR 1110.2.

PROPOSED RULE 1110.3

Subdivision (a) – Purpose

The purpose of PR 1110.3 is to reduce oxides of nitrogen (NO_x), volatile organic compounds (VOCs), and carbon monoxide (CO) from linear generators.

Subdivision (b) – Applicability

PR 1110.3 applies to all linear generators fueled solely by natural gas, both portable and stationary, regardless of size. Linear generators are currently being used as a stationary prime power source at facilities, but it is anticipated that they can be configured as portable units and can also be used for emergency applications.

PR 1110.3 only applies to linear generators fueled solely by natural gas because source test data has not been provided for other fuels. The narrowed applicability will allow the research and development of linear generator technology operating on other fuels like biogas, hydrogen, ammonia, or any other fuels. All existing linear generators in South Coast AQMD are operated solely on natural gas.

Subdivision (c) – Definitions

PR 1110.3 incorporates definitions from other South Coast AQMD rules to define types of facilities, equipment, and other rule terms. New or modified definitions added to PR 1110.3 include:

- **IDENTICAL UNITS** means any Units with the same manufacturer, model, and output rating.
This definition provides clarification for the determination of units that can qualify for pooled source testing under paragraph (f)(10).
- **LINEAR GENERATOR** means any power generation technology that uses a thermochemical reaction to create linear motion that is directly converted into electricity.
With input from stakeholders and South Coast AQMD engineering staff, this definition provides clarification and distinguishes linear generator technology from generators that utilize internal combustion engines to generate electricity.
- **TUNING** means adjusting, optimizing, rebalancing, or other similar action operations to an electric generating Unit or an associated control device or as otherwise defined in the Permit

to Operate. Tuning does not include automatic adjustments made by a unit's control system to meet load fluctuation.

This definition has been modified to provide clarification and address the specific operating conditions of linear generator technology due to the utilization of a parametric monitoring system to control and monitor its operation. For example, adjustments to meet load fluctuations or any adjustment made automatically by the control system would not be considered tuning.

- UNIT means any single linear generator core.

To date, linear generators in operation within South Coast AQMD were installed as a single packaged product that contains two individual identical cores within each package. Each core within the package has thus far been issued a separate Permit to Operate. Despite the current packaged product consisting of two cores, this definition is included to provide clarification that the term Unit refers to a single linear generator core for the purposes of this rule. Based on this definition, a manufacturer expressed interest in obtaining Permits to Operate based on the packaged product instead of individual cores. They also expressed concerns about permitting costs for current and future packaged products that might contain 3 or more cores, resulting in the necessity to obtain separate Permits to Operate for each core. The definition does not preclude South Coast AQMD from permitting linear generators differently in the future (e.g. a single permit for a packaged product with multiple cores).

Subdivision (d) – Emission Limits

Subdivision (d) specifies emission limits in Table 1 of PR 1110.3 (Table 2 in Staff Report) and applies to all natural gas fueled linear generators, both portable and stationary, regardless of size. During the 2019 amendment of Rule 1110.2, staff and stakeholders had concerns about the performance of the equipped oxidation catalyst and its ability to impactfully reduce VOC emissions. As a result, a limited number of linear generators were allowed to comply with a VOC limit of 25 ppmvd for an interim period. However, beginning January 1, 2024, all new units are required to meet the emission limits in Table IV of Rule 1110.2. During this phase-in period, VOC emissions in excess of 10 ppmvd are tabulated by South Coast AQMD staff and the total VOC emissions are not to exceed 45 pounds per day.

During the PR 1110.3 rule making process, staff held meetings with stakeholders to discuss Rule 1110.2 emission limits. Source test data for natural gas fueled units were provided by a manufacturer showing that linear generators are able to comply with the emission limits in Table 2 of the Staff Report. A manufacturer also indicated that the oxidation catalyst contribution to achieving VOC emission reductions were negligible due to the lower reaction temperatures, and VOC emissions are primarily controlled through the parametric monitoring system. After further discussion, it was determined that the 25 ppmvd VOC limit was not necessary and thus, those provisions were not carried over from Rule 1110.2. The emission limits in Table 2 of the Staff Report will take effect upon adoption of PR 1110.3 and will apply to all units with Permits to Operate issued on or after the date of adoption.

**TABLE 2
CONCENTRATION LIMITS FOR LINEAR GENERATORS**

Units with a Permit to Operate Issued on or after [Date of Adoption]			
Fuel Type	NO_x (ppmv)¹	CO (ppmv)¹	VOC (ppmv)²
Natural Gas	2.5	12	10

¹ Parts per million by volume, corrected to 15% oxygen on a dry basis and averaged over 15 minutes.

² Parts per million by volume, measured as carbon, corrected to 15% oxygen on a dry basis, and averaged over the sampling time required by the test method.

In addition, emissions from various fuel types were also discussed and preliminary data provided by a manufacturer indicated that emissions from the different fuel types were compliant with the same emissions limits. However, staff has only received source test data for natural gas fueled units; source test data was not provided for other fuel types.

Subdivision (e) – Maintenance Requirements

Paragraphs (e)(1) and (e)(2) are intended to ensure that owners and operators of linear generators perform scheduled maintenance per manufacturer’s recommendations. In addition, a copy of the manufacturer’s operating and maintenance manual is required to be kept and made available for inspection to verify that maintenance is indeed being performed.

Subdivision (f) – Source Testing

Similar to Rule 1110.2, paragraph (f)(1) requires non-pooled units to be source tested periodically for NO_x, VOC reported as carbon, and CO concentrations. Staff originally proposed a frequency of at least once every two years from the date of the previous test, or every 8,760 operating hours, whichever occurs first. Due to the low NO_x and CO emissions from linear generators, the utilization of a parametric monitoring system to control emissions, and the cost of source testing, stakeholders questioned the necessity of the proposed frequency and requested a reduced source testing frequency of at least once every five years. Additionally, one manufacturer explained that the procedures for performing the emissions checks required them to override their safety protocol in order to access the testing ports. Source test data for natural gas fueled units was provided to substantiate their request. An initial source test will be required within six months of installation of a Unit or within six months of not meeting the eligibility requirements for pooled source testing. Subsequently, source testing shall be conducted once every five years from the date of the previous source test, no later than the last day of the calendar month that the test is due.

PR 1110.3 also references to a generic source test protocol in several rule provisions. A generic source testing protocol is one in which an owner or operator submits a protocol for review and once it has been reviewed and approved, can be used for subsequent source testing on identical units without the need to submit separate protocols for review.

Stakeholders also expressed concerns about the necessity, cost, and logistics of source testing multiple Units that are identical and located within the same facility. In response to these concerns, staff has proposed the allowance of pooled initial source testing for facilities with six or more identical units. The allowance for pooled testing reduces the source testing costs and logistical concerns.

Under the pooled testing schedule, specified in paragraph (f)(10), at least one-third of the units are required to be initially source tested. Subsequent source testing shall be conducted on a different one-third of the Units from the previous source test. Source testing for pooled units is required to be conducted at least once every three years from the date of the previous source test, no later than the last day of the calendar month that the test is due.

Subparagraph (f)(10)(B) specifies that units installed after the initial source test are subject to the subsequent pooled emission testing schedule. Units installed after the initial source test that are not identical to the units in the pool are required to be source tested separately as required in paragraph (f)(1). PR 1110.3 defines the term identical units. If additional identical units are installed, the required one-third of units to be source tested will be based on the new total number of units. For example, if a facility initially installed nine identical units, and later installed 15 more identical units, an owner or operator would be required to source test eight units out of 24 identical units total to comply with the requirement to source test at least one-third of pooled units. Furthermore, the source test schedule for additional identical units will be based on date of the last source test. For example, if a source test for pooled units was conducted in March 2023 and then new identical units were installed in 2024, then the next source test would be required by March 2026.

If any unit subject to the pooled source testing exceeds any of the emission limits, the owner or operator will be required to repair the unit and repeat the source test within 60 days of repair. In this event, additional source tests will also be required to be conducted on an additional one-third of the pooled units.

Based on the one-third testing schedule, staff expects all of the pooled units to be source tested within a period of nine years, at the latest. For example, a facility installing 10 identical units under this proposed testing schedule will be required to test four units during the initial source test in order to meet the one-third source testing criteria. The next pool of source tests is required to occur on four different units after three years. Then, after another three years, the remaining two units and two units that were source tested in the first pool are required to source test.

Subdivision (g) – Monitoring, Recordkeeping, and Reporting

Ensuring that the parametric monitoring system is functioning properly is of utmost importance, as its main function is to ensure that the unit is operating within specified parameters and that emissions are controlled. In order to ensure the performance and robustness of the parametric

monitoring system, staff is proposing diagnostic emissions checks by a portable NO_x, CO, and oxygen analyzer at least once every two years from the date of the previous emissions test, no later than the last day of the calendar month that the test is due. A previous emissions test includes both source tests as well as diagnostic emission checks. The diagnostic emission testing would be conducted in accordance with South Coast AQMD's Combustion Gas Periodic Monitoring Protocol for the Periodic Monitoring of Nitrogen Oxides, Carbon Monoxide, and Oxygen from Combustion Sources Subject to Rules 1110.2, 1146, and 1146.1. This protocol for portable analyzer testing was first approved on February 1, 2008, and most recently updated on May 15, 2020. The portable analyzer testing shall also be conducted by a person who has completed an appropriate South Coast AQMD-approved training program and has received a certification issued by the South Coast AQMD.

Paragraph (g)(1) requires owners and operators of linear generators to maintain a revenue grade net output meter that meets ANSI C12.20 or an equivalent standard and a parametric monitoring system. It also requires the inspection and maintenance of the parametric monitoring system, as well as sensors and meters, per manufacturer's recommendations.

In response to comments from stakeholders, staff modified provisions in subparagraph (g)(1)(D), which requires the owner or operator to maintain a parametric monitoring system including the associated components necessary to maintain a proper air-to-fuel ratio. Lastly, owners or operators are required to monitor and record the parametric monitoring system at least daily. These provisions were added in lieu of requiring the submittal of a separate Inspection and Monitoring (I & M), as is required in Rule 1110.2.

Records play an important role in verifying compliance with PR 1110.3. Subparagraph (g)(2)(A) requires monthly records to be kept for various parameters. In addition, records to demonstrate compliance with other rule provisions are also required to be maintained for a period of five years and made available to the South Coast AQMD upon request for compliance verification.

Subparagraph (g)(3) requires owners and operators to submit source test results within 60 days of completion of the test.

In the normal course of operation, there is potential for complex equipment such as linear generators to experience malfunctions. Staff's primary concern during these events are emissions that exceed rule limits or permit conditions. South Coast AQMD Rule 430 – Breakdown Provisions contains requirements during breakdowns that units subject to PR 1110.3 would be required to comply with.

Subdivision (h) – Exemptions

This subdivision was created to capture future considerations and applications for linear generators. Staff anticipates that there will be expansion and adoption of linear generator technologies into various industrial sectors and these provisions will provide allowances for the research and development of linear generators that could ensure durability and robustness of the technology.

Paragraph (h)(1) provides an exemption from subdivision (d) and subparagraph (g)(1)(A) for linear generators used in a laboratory for testing and research purposes and paragraph (h)(2) provides an

exemption from subdivision (f) and subparagraph (g)(1)(A) for emergency standby units, units used for fire-fighting and flood control, or any other emergency unit approved by the Executive Officer, which have permit conditions that limit operation to 200 hours or less per year as determined by an operational non-resettable totalizing time meter.

PROPOSED AMENDED RULE 1110.2

Subdivision (c) – Definitions

PAR 1110.2 incorporates definitions from other South Coast AQMD rules to define types of facilities, equipment, and other rule terms. One existing definition was amended and a single new definition was added to PAR 1110.2:

- ENGINE is any spark- or compression-ignited internal combustion engine, including engines used for control of VOCs, but not including Linear Generators or engines used for self-propulsion.

This definition was amended to include “linear generators” as to exclude them from any applicability when the term “engine” is referenced in this rule.

- LINEAR GENERATOR means any power generation technology that uses a thermochemical reaction to create linear motion that is directly converted into electricity.

This definition was created with input from stakeholders and South Coast AQMD engineering staff and provides clarification and distinguishes linear generator technology from internal combustion engines.

Subdivision (d) – Requirements

Clause (d)(1)(L)(i) subjects new non-emergency electrical generators to the NO_x, CO, and VOC emission limits in Table IV. Table IV contains a column that reflects emission standards, in concentration limits, for new non-emergency electrical generators, which was specifically added for linear generators.

PAR 1110.2 will update Table IV to remove the concentration limit column, and applicable footnotes, as it was originally created for linear generators. The emission limits in Table 3 will take effect upon adoption of PAR 1110.2.

**TABLE 3
UPDATED EMISSION STANDARDS**

TABLE IV EMISSION STANDARDS FOR NEW ELECTRICAL GENERATION DEVICES	
Pollutant	Emission Standard (lbs/MW-hr)¹
NO _x	0.070
CO	0.20
VOC	0.10 ²

¹ The averaging time of the emission standard for VOC is the sampling time required by the test method.

² Mass emissions of VOC shall be calculated using a ratio of 16.04 pounds of VOC per lb-mole of carbon.

Clause (d)(1)(L)(vii) allows units installed prior to January 1, 2024 that can achieve NO_x concentration limits at all times with no ammonia emissions from add-on control equipment to meet an interim VOC concentration limit of 25 ppmvd. Additionally, Rule 1110.2 includes a cap on the number of units that can be installed meeting the alternative VOC concentration limit of 25 ppmvd. The total VOC emission cap from these units are not to exceed 45 pounds per day of VOC. This provision was included to ensure that the emissions from such engines would not exceed South Coast AQMD's Air Quality Significance Threshold under CEQA for operational VOC emissions.

PAR 1110.2 will remove this clause, as it will be obsolete and no longer applicable.

Subdivision (f) – Monitoring, Testing, Recordkeeping and Reporting

Subparagraph (f)(1)(D) requires operators to submit an I & M Plan to the Executive Officer for approval. Since linear generators utilize a parametric monitoring system to control emissions, it was proposed by stakeholders that this system would be a substitute for periodic portable analyzer testing. As a result, there were concerns from stakeholders as to how linear generator operators can meet the specific requirements of this subparagraph. In response to this request, subclause (f)(1)(D)(i)(1) was added to provide operators with flexibility and allowed them to submit an alternative I&M Plan for the Executive Officer's consideration.

PAR 1110.2 will be updated to remove the provision allowing for I&M plan flexibility, as it was an allowance added specifically for linear generator operators.

Subclause (f)(1)(D)(ii)(V) requires that the portable analyzer be calibrated, maintained and operated in accordance with the manufacturer's specifications and recommendations and the Protocol for the Periodic Monitoring of Nitrogen Oxides, Carbon Monoxide, and Oxygen from Stationary Engines Subject to South Coast Air Quality Management District Rules 1110.2, 2, 1146, and 1146.1. Since the protocol was amended on May 15, 2020, the reference to the protocol was updated to reflect the current title.

Subdivision (i) – Exemptions

This subdivision in Rule 1110.2 does not currently contain any exemptions specifically for linear generators. PAR 1110.2 will amend paragraph (i)(3) to change “units” to “engines” to provide clarification that the provisions of Rule 1110.2 do not apply to linear generators located at landfills or Publicly Owned Treatment Works, as those units would be subject to Rule 1110.3. The use of the term “engine” is deliberate and is intended to differentiate and distinguish linear generator technology from internal combustion engines.

CHAPTER 3: IMPACT ASSESSMENTS

INTRODUCTION

COSTS

EMISSION REDUCTIONS

COST-EFFECTIVENESS

INCREMENTAL COST-EFFECTIVENESS

SOCIOECONOMIC IMPACT ASSESSMENT

CALIFORNIA ENVIRONMENTAL QUALITY ACT ANALYSIS

**DRAFT FINDINGS UNDER HEALTH AND SAFETY CODE SECTION
40727**

COMPARATIVE ANALYSIS

INTRODUCTION

Impact assessments were conducted during PR 1110.3 and PAR 1110.2 rule development to assess the environmental and socioeconomic implications of these rules. Health and Safety Code requirements for cost-effectiveness analysis and incremental cost-effectiveness analysis were evaluated during rule development of PR 1110.3 and PAR 1110.2. Draft findings and comparative analyses were prepared pursuant to Health and Safety Code Sections 40727 and 40727.2, respectively. ~~Staff is currently reviewing PR 1110.3 and PAR 1110.2 to determine if it will result in any potential adverse environmental impacts. Appropriate CEQA documentation will be prepared based on this analysis.~~

COSTS

The provisions in PR 1110.3 and PAR 1110.2 are not expected to impose additional costs. In comparison to current Rule 1110.2 source testing requirements, PR 1110.3 includes a new emission testing schedule to help alleviate costs associated with source testing. Based on the new emission testing schedule, and an estimated cost of \$10,000 per source test, staff calculates the cost of source testing each unit to be approximately \$30,000 over a 15-year period. The new emission testing schedule translates to over 60% cost savings over the originally proposed source test frequency for units currently subject to Rule 1110.2. Facilities with ~~three~~six or more units may elect to conduct pooled source testing to further alleviate costs.

EMISSION REDUCTIONS

Any emission reductions from PR 1110.3 are expected to be negligible. Potentially, there could be a slight decrease in VOC emissions, as the interim VOC limit of 25 ppmvd for units installed prior to January 1, 2024 is proposed for removal from PAR 1110.2 and PR 1110.3 does not include an interim VOC limit for these units. All units with a Permit to Operate issued on and after *[Date of Adoption]* will be required to meet 10 ppmvd VOC under PR 1110.3.

COST-EFFECTIVENESS

~~The Health and Safety Code Section 40920.6 requires a cost-effectiveness analysis when establishing BARCT requirements. However, PR 1110.3 and PAR 1110.2 does not~~neither include new BARCT requirements nor ~~is it~~are expected to impose any additional costs. Therefore, this provision ~~neither does not~~applies apply to PR 1110.3 ~~nor~~and PAR 1110.2.

INCREMENTAL COST-EFFECTIVENESS

Health and Safety Code Section 40920.6 requires an incremental cost-effectiveness analysis for BARCT rules or emission reduction strategies when there is more than one control option which would achieve the emission reduction objective of PR 1110.3 and PAR 1110.2, relative to ozone, CO, SO_x, NO_x, and their precursors. PR 1110.3 and PAR 1110.2 neither include new BARCT requirements nor include any requirements for additional control options. Thus, there is no more

stringent control option upon which an incremental cost-effectiveness would be calculated. Therefore, this provision neither applies to PR 1110.3 nor PAR 1110.2.

SOCIOECONOMIC IMPACT ASSESSMENT

Implementation of PR 1110.3 and PAR 1110.2 will not result in any significant changes in air quality or emission limitations. Therefore, a socioeconomic impact assessment per Health and Safety Code Sections 40440.8 and 40728.5 is not required. PR 1110.3 and PAR 1110.2 would result in a cost savings to affected facilities due to a reduced source testing frequency and are not expected to result in any adverse socioeconomic impacts. The “Costs” section on page 3-1 of this Staff Report includes a discussion about the net savings associated with PR 1110.3 and PAR 1110.2.

CALIFORNIA ENVIRONMENTAL QUALITY ACT ANALYSIS

Pursuant to the California Environmental Quality Act (CEQA) Guidelines Sections 15002(k) and 15061, the proposed project (PR 1110.3 and PAR 1110.2) is exempt from CEQA pursuant to CEQA Guidelines Section 15061(b)(3). A Notice of Exemption ~~will be~~ has been prepared pursuant to CEQA Guidelines Section 15062, and if the proposed project is approved, the Notice of Exemption will be filed for posting with the county clerks of Los Angeles, Orange, Riverside, and San Bernardino counties, and with the State Clearinghouse of the Governor’s Office of Planning and Research.

DRAFT FINDINGS UNDER HEALTH AND SAFETY CODE SECTION 40727

Requirements to Make Findings

Health and Safety Code Section 40727 requires that prior to adopting, amending or repealing a rule or regulation, the South Coast AQMD Governing Board shall make findings of necessity, authority, clarity, consistency, non-duplication, and reference based on relevant information presented at the public hearing and in the staff report. The draft findings are as follows:

Necessity

PR 1110.3 is needed to establish emission limits and other requirements for linear generators. PAR 1110.2 is needed provide non-duplication of South Coast AQMD requirements by exempting linear generators.

Authority

The South Coast AQMD obtains its authority to adopt, amend, or repeal rules and regulations pursuant to Health and Safety Code Sections 39002, 39616, 40000, 40001, 40440, 40702, 40725 through 40728, 40920.6, and 41508, as well as the federal Clean Air Act.

Clarity

PR 1110.3 and PAR 1110.2 are written or displayed so that its meaning can be easily understood by the persons directly affected by them.

Consistency

PR 1110.3 and PAR 1110.2 are in harmony with and not in conflict with or contradictory to, existing statutes, court decisions or state or federal regulations.

Non-Duplication

PR 1110.3 and PAR 1110.2 will not impose the same requirements as any existing state or federal regulations. PR 1110.3 and PAR 1110.3 are necessary and proper to execute the powers and duties granted to, and imposed upon, the South Coast AQMD.

Reference

In adopting PR 1110.3 and PAR 1110.2, the following statutes which the South Coast AQMD hereby implements, interprets or makes specific are referenced: Health and Safety Code Sections 39002, 40001, 40702, 40440(a), and 40725 through 40728.5, and the federal Clean Air Act.

COMPARATIVE ANALYSIS

Under Health and Safety Code Section 40727.2, the South Coast AQMD is required to perform a comparative written analysis when adopting, amending, or repealing a rule or regulation. The comparative analysis is relative to existing federal air pollution control requirements, existing or proposed South Coast AQMD rules and regulations, and all air pollution control requirements and guidelines which are applicable to the same equipment or source type. A comparative analysis is presented in Table 3-1.

**TABLE 3-1
PR 1110.3 & PAR 1110.2 COMPARATIVE ANALYSIS**

Rule Element	PR 1110.3	PAR 1110.2	CCR, Title 17, Division 3, Chapter 1, Subchapter 8, Article 3
Applicability	All linear generators fueled solely by natural gas are subject to this rule.	All stationary and portable engines over 50 rated brake horsepower (bhp) are subject to this rule.	Any DG Unit manufactured after January 1, 2003, for sale, lease, use, or operation in the State of California or any new DG Unit sold or leased, or offered for sale or lease, for use or operation in the State of California after January 1, 2003, shall be certified by the Air Resources Board unless the DG Unit: (a) does not emit an air contaminant when operated, (b) is portable, (c) is used only when electrical or natural gas service fails or for emergency pumping of water for fire protection or flood relief, (d) is not exempt from an air pollution control district or air quality management district’s permitting requirements, (e) is part of a research operation that has been approved in writing by the Executive Officer prior to commencement of operations, or (f) is operated by the manufacturer at the manufacturing facility prior to sale or lease for the purpose of quality-assurance testing.
Requirements	<p>An owner or operator of a Unit with a Permit to Operate issued on or after [Date of Adoption] shall not operate it in a manner that exceeds the NOx, CO, and VOC emission limits listed in Table 1:</p> <ul style="list-style-type: none"> • NOx: 2.5 ppmvd corrected to 15% oxygen and averaged over 15 minutes • CO: 12 ppmvd corrected to 15% oxygen and averaged over 15 minutes • VOC: 10 ppmvd corrected to 15% oxygen and averaged over sampling time required by test method <p>Maintenance Requirements</p> <p>(1) An owner or operator of a Unit shall perform maintenance per manufacturer’s recommendations as specified in the operating and maintenance manual.</p> <p>(2) An owner or operator of a Unit shall keep a copy of the manufacturer’s operating and maintenance manual and make it available to South Coast AQMD upon request.</p> <p>Source Testing</p> <p>(1) An owner or operator of a Unit that is not pooled pursuant to paragraph (f)(10) shall conduct source testing for NOx, VOC reported as carbon, and CO concentrations (concentrations in ppm by volume, corrected to 15 percent oxygen on dry basis):</p>	<p>(C) The operator of any stationary engine fired by landfill or digester gas (biogas) shall not operate the engine in a manner that exceeds the emission concentration limits of Table III-A, provided that the facility monthly average biogas usage by the biogas engine is 90% or more, based on the higher heating value of the fuels used. The calculation of the monthly facility biogas use percentage may exclude natural gas fired during: any electrical outage at the facility; a Stage 2 or higher electrical emergencies called by the California Independent System Operator Corporation; and when a sewage treatment plant activates an Emergency Operations Center or Incident Command System, as part of an emergency response plan, because of either high influent flows caused by precipitation or a disaster.</p> <p>Table IIIB- Concentration Limits for Landfill and Digester Gas (Biogas)-Fired Engines- Effective January 1, 2017 (Concentration limits @ 15% O2):</p> <ul style="list-style-type: none"> • NOx: 11 ppmvd averaged over 15 minutes • VOC: 30 ppmvd averaged over sampling time required by test method • CO: 250 ppmvd averaged over 15 minutes <p>(D) Notwithstanding the provisions of subparagraph (d)(1)(B), the operator of any stationary engine fired by landfill or digester gas (biogas) shall not operate the engine in a manner that exceeds the emission concentration limits of Table III.</p>	<p>(a) On or after January 1, 2003, any DG Unit subject to this regulation must be certified pursuant to section 94204 to one of the following sets of emission standards in Table 1.</p> <p>(1) DG Unit not integrated with combined heat and power, DG Unit not Integrated with Combined Heat and Power (1):</p> <ul style="list-style-type: none"> • NOx: 0.5 lb/mW-hr • CO: 6.0 lb/MW-hr • VOC: 1.0 lb/MW-hr • PM: an emission limit corresponding to natural gas with fuel sulfur content of no more than 1 grain/100scf <p>(b) On or after January 1, 2007, any DG Unit subject to this regulation fueled by a fossil fuel must be certified pursuant to section 94204 to the following set of emission standards in Table 2.</p> <ul style="list-style-type: none"> • NOx: 0.07 lb/mW-hr • CO: 0.10 lb/MW-hr • VOC: 0.2 lb/MW-hr <p>(c) Any DG Unit subject to this regulation and fueled by digester gas, landfill gas, or oil-field waste gas must be certified pursuant to section 94204 to the emission standards in Table 3.</p> <p>On or after January 1, 2008:</p> <ul style="list-style-type: none"> • NOx: 0.5 lb/mW-hr • CO: 6.0 lb/MW-hr

Rule Element	PR 1110.3	PAR 1110.2	CCR, Title 17, Division 3, Chapter 1, Subchapter 8, Article 3								
	<p>(A) Initially, within six months of installation of a Unit or within six months of not meeting the eligibility requirements for pooled source testing in paragraph (f)(10); and</p> <p>(B) Subsequently, at least once every five years from the date of the previous source test, no later than the last day of the calendar month that the test is due.</p> <p>(2) An owner or operator of a Unit shall conduct the source test by using a contractor that is approved under South Coast AQMD's Laboratory Approval Program (LAP) for the test methods specified in Table 2, or any test methods approved by CARB and U.S. EPA, and authorized by the Executive Officer.</p> <p>Table 2: Testing Methods</p> <table border="1" data-bbox="262 516 814 625"> <thead> <tr> <th>Pollutant</th> <th>Method</th> </tr> </thead> <tbody> <tr> <td>NOx</td> <td>South Coast AQMD Method 100.1</td> </tr> <tr> <td>CO</td> <td>South Coast AQMD Method 100.1</td> </tr> <tr> <td>VOC</td> <td>South Coast AQMD Method 25.1* or Method 25.3*</td> </tr> </tbody> </table> <p>*Excluding ethane and methane</p> <p>(3) An owner or operator of a Unit shall submit a source test protocol to the Executive Officer for written approval at least 60 days before the scheduled date of the test. The source test protocol shall include, but is not limited to the following:</p> <p>(A) Name, address, and phone number of the Unit operator and a South Coast AQMD-approved source testing contractor that will conduct the test;</p> <p>(B) Application number(s), permit number(s), and emission limits;</p> <p>(C) Description of the Unit(s) to be tested and the test methods and procedures to be used;</p> <p>(D) Number of tests to be conducted and under what loads; and</p> <p>(E) Required minimum sampling time for the VOC test, based on the analytical detection limit and expected VOC levels.</p> <p>(4) An owner or operator of a Unit with an approved generic source test protocol or other valid approved source test protocol shall conduct the source test within 90 days after a written approval of the source test protocol by the Executive Officer is electronically distributed.</p> <p>(5) An owner or operator of a Unit with an approved generic protocol, or with a previously approved source test protocol, shall submit a subsequent protocol if the Unit has been altered in a manner that requires a permit modification, if emission limits for the Unit have changed since the previous source test, or if requested by the Executive Officer.</p>	Pollutant	Method	NOx	South Coast AQMD Method 100.1	CO	South Coast AQMD Method 100.1	VOC	South Coast AQMD Method 25.1* or Method 25.3*	<p>(G) Once an engine complies with the concentration limits as specified in Table III-B, there shall be no limit on the percentage of natural gas burned.</p> <p>(L) New Non-Emergency Electrical Generators</p> <p>(i) All new non-emergency engines driving electrical-generators shall comply with the following emission standards in lbs/MW-hr:</p> <p>Table IV- Emissions Standards for New Electrical Generation Devices Concentration limits for low-use engines.</p> <p>(Concentration limits calculated using a 40% engine efficiency and no applied thermal credit, corrected to 15% O₂):</p> <ul style="list-style-type: none"> • NOx: 2.5 ppmvd • CO: 12 ppmvd • VOC: 10 ppmvd <p>(vii) Owners and operators of new engines installed prior to January 1, 2024 with no ammonia emissions from add-on control equipment and where NOx emissions meet the concentration limit of Table IV at all times may elect to apply for and comply with the concentration limits of Table IV, expressed in ppmvd, except an alternative VOC concentration limit that is equal to or less than 25 ppmvd may be complied with. The Executive Officer shall accumulate daily VOC emissions in excess of the concentration limit of Table IV based on the permitted VOC limits from each such engine and shall not approve any additional permit for such engine that will cause the total accumulated daily VOC emissions to exceed 45 lbs per day. Any new installation on or after January 1, 2024 shall comply with the VOC concentration limit in Table IV in ppmvd.</p> <p>(e)(4) Stationary Engine Inspection and Monitoring (I&M) Plans:</p> <p>The operator of stationary engines subject to the I&M plan provisions of subparagraph (f)(1)(D) shall:</p> <p>(A) By August 1, 2008, submit an initial I&M plan application to the Executive Officer for approval;</p> <p>(B) By December 1, 2008, implement an approved I&M plan or the I&M plan as submitted if the plan is not yet approved. Any operator of 15 or more stationary engines subject to the I&M plan provisions shall comply with the above schedule for at least 50% of engines, and for the remaining engines shall:</p> <p>(C) By February 1, 2009, submit an initial I&M plan application to the Executive Officer for approval;</p> <p>(D) By June 1, 2009, implement an approved I&M plan or the I&M plan as submitted if the plan is not yet approved.</p>	<ul style="list-style-type: none"> • VOC: 1.0 lb/MW-hr <p>On or after January 1, 2013:</p> <ul style="list-style-type: none"> • NOx: 0.07 lb/mW-hr • CO: 0.10 lb/MW-hr • VOC: 0.2 lb/MW-hr <p>(e) By July 2005, the ARB staff must complete an electrical generation technology review to evaluate if the requirements in (b) and (d) above and section 94207 should be modified and report its findings to the Board.</p>
Pollutant	Method										
NOx	South Coast AQMD Method 100.1										
CO	South Coast AQMD Method 100.1										
VOC	South Coast AQMD Method 25.1* or Method 25.3*										

Rule Element	PR 1110.3	PAR 1110.2	CCR, Title 17, Division 3, Chapter 1, Subchapter 8, Article 3
	<p>(6) An owner or operator of a Unit shall provide the Executive Officer at least 30 days prior notice of any source test to afford the Executive Officer the opportunity to have an observer present. If, after the 30 days prior notice is given, there is a delay (due to operational problems, etc.) in conducting the scheduled source test, the owner or operator of a Unit shall notify the Executive Officer as soon as possible of any delay in the original test date, either by providing notice of the rescheduled date of the source test at least seven days prior, or by arranging a rescheduled date mutually agreed upon with the Executive Officer.</p> <p>(7) An owner or operator of a Unit shall provide source testing facilities as follows:</p> <p>(A) Sampling ports adequate for the applicable test methods. This includes constructing the air pollution control system and stack or duct such that pollutant concentrations can be accurately determined by applicable test methods;</p> <p>(B) Safe sampling platform(s), scaffolding or mechanical lifts, including safe access, that comply with California General Safety Orders; and</p> <p>(C) Utilities for sampling and testing equipment.</p> <p>(8) The LAP contractor shall not conduct a source test within 1 week of any Unit servicing or Tuning.</p> <p>(9) The LAP contractor shall conduct source testing for at least 30 minutes during normal operation (actual duty cycle). This test shall not be conducted under a steady-state condition unless it is the normal operation. The LAP contractor shall not conduct any pre-tests for compliance.</p> <p>(10) In lieu of meeting the requirements in paragraph (f)(1), an owner or operator of six or more Identical Units located at the same facility may elect to conduct pooled initial source testing, for NOx, VOC reported as carbon, and CO concentrations (concentrations in ppm by volume, corrected to 15 percent oxygen on dry basis), pursuant to the following:</p> <p>(A) At least one-third of the Units shall be source tested during the initial source test and all subsequent source testing shall be conducted on a different one-third of the Units. Source testing of pooled Units shall be conducted at least once every three years from the date of the previous source test, no later than the last day of the calendar month that the test is due;</p> <p>(B) Identical Units installed after the initial source test has been performed shall be included with the Units subject to the</p>	<p>(6) New Stationary Engines The operator of any new stationary engine issued a permit to construct after February 1, 2008 shall comply with the applicable I&M or CEMS requirements of this rule when operation commences. If applicable, the operator shall provide the required information in subparagraph (f)(1)(D) to the Executive Officer prior to the issuance of the permit to construct so that the I&M procedures can be included in the permit. A separate I&M plan application is not required.</p> <p>(7) Biogas Engines For any biogas engine for which the operator applies to the Executive Officer by April 1, 2008 for a change of permit conditions for ECF-corrected emission limits, or the approval to burn more than 10 percent natural gas in accordance with subparagraph (d)(1)(C), the biogas engine shall not be subject to the initial concentration limits of Tables II or III until August 1, 2008, provided the operator continues to comply with all emission limits in effect prior to February 1, 2008.</p>	

Rule Element	PR 1110.3	PAR 1110.2	CCR, Title 17, Division 3, Chapter 1, Subchapter 8, Article 3
	<p>pooled subsequent emissions testing pursuant to subparagraph (f)(10)(A);</p> <p>(C) If any Unit subject to the pooled source testing exceeds any emissions standards in Table 1, the owner or operator shall repair the Unit that failed, repeat the source test within 60 days of repair, and conduct source testing on an additional one-third Units;</p> <p>(D) All pooled Units at a facility shall be source tested at least once every nine years.</p>		
Monitoring	<p>(A) An owner or operator of a Unit shall conduct diagnostic emission checks by a portable NOx, CO, and oxygen analyzer at least once every two years from the date of the previous emissions test, no later than the last day of the calendar month that the test is due and comply with the following requirements:</p> <p>(i) No Unit or control system maintenance or tuning may be conducted within 1 week prior to the diagnostic emission check, unless it is an unscheduled, required repair,</p> <p>(ii) The portable analyzer shall be calibrated, maintained and operated in accordance with the manufacturer’s specifications and recommendations and in accordance with South Coast AQMD’s Combustion Gas Periodic Monitoring Protocol of Nitrogen Oxides, Carbon Monoxide, and Oxygen from Combustion Sources subject to South Coast Air Quality Management District Rules 1110.2, 1146, and 1146.1, or subsequent protocol approved by U.S. EPA and the Executive Officer,</p> <p>(iii) The portable analyzer tests required in subparagraph (g)(1)(A) shall only be conducted by a person who has completed an appropriate South Coast AQMD-approved training program in the operation of portable analyzers and has received a certification issued by South Coast AQMD, and</p> <p>(iv) A source test pursuant to paragraphs (f)(1) and (f)(10) shall be an acceptable substitute diagnostic emission check to satisfy subparagraph (g)(1)(A)..</p> <p>(B) If a diagnostic emission check results in finding emissions in excess of rule or permit limits, an owner or operator shall correct the exceedance as soon as possible and demonstrate compliance with another diagnostic emission check pursuant to (g)(1)(A).</p> <p>(C) An owner or operator of a Unit shall maintain a net output meter that is revenue grade compliant with ANSI C12.20 or equivalent.</p>	<p>(f) Monitoring, Testing, Recordkeeping and Reporting</p> <p>(1) Stationary engines: The operator of any engine subject to the provisions of paragraph (d)(1) of this rule shall meet the following requirements:</p> <p>(B) Elapsed Time Meter Maintain an operational non-resettable totalizing time meter to determine the engine elapsed operating time.</p> <p>(C) Source Testing</p> <p>(i) Effective August 1, 2008, conduct source testing for NOx, VOC reported as carbon, and CO concentrations (concentrations in ppm by volume, corrected to 15 percent oxygen on dry basis) at least once every two years from the date of the previous source test, no later than the last day of the calendar month that the test is due, or every 8,760 operating hours, whichever occurs first. Relative accuracy tests required by Rule 218.1 or 40 CFR Part 75 Subpart E shall satisfy this requirement for those pollutants monitored by a CEMS. The above source test frequency may be reduced to once every three years if the engine has operated less than 2,000 hours since the last source test. If the engine has not been operated before the date a source test is due, the source test shall be conducted by the end of seven consecutive days or 15 cumulative days of resumed operation. The operator of the engine shall keep sufficient operating records to demonstrate that it meets the requirements for extension of the source testing deadlines.</p> <p>(ii) Conduct source testing for at least 30 minutes during normal operation (actual duty cycle). This test shall not be conducted under a steady-state condition unless it is the normal operation. In addition, conduct source testing for NOx and CO emissions for at least 15 minutes at: an engine’s actual peak load, or the maximum load that can be practically achieved during the test, and; at actual minimum load, excluding idle, or the minimum load that can be practically achieved during the test. These</p>	<p>(a) Sampling methodology used must conform to ARB testing procedures. Alternate or modified test methods may be used if approved in writing by the Executive Officer prior to use for certification. Testing shall be conducted in accordance with the following methods, which are incorporated by reference herein: NOx, CO, and Oxygen: ARB Test Method 100 (as adopted on July 28, 1997) VOC: South Coast AQMD Method 25.3 (as published in March 2000) Gas Velocity and Flow Rate: ARB Test Methods 1, 2, 3, and 4 (as adopted on July 1, 1999)</p> <p>(b) Only natural gas, LPG, digester gas, landfill gas, or oil-field waste gas, as defined in section 94202, meeting the requirements of section 94207(d)(7) shall be used for certification testing. Other fuels may be used upon the written approval of the Executive Officer.</p> <p>(c) The DG Unit shall be configured as it will be marketed, including any additional control equipment or other devices that affect emissions.</p> <p>(d) Testing parameters.</p> <p>(1) A minimum of three valid test runs must be conducted. Tests are to be run consecutively. Justification for invalid test runs or time gaps between runs must be included in the test report.</p> <p>(2) Testing commences after the DG Unit has reached stable operation.</p> <p>(3) Each run must be conducted at 100 percent of generator net output.</p> <p>(A) A load bank may be used to establish the load.</p> <p>(B) The DG Unit must be operated for a sufficient period of time to demonstrate stability in the emission readings at constant load and to ensure the collection of representative and quantifiable samples.</p>

Rule Element	PR 1110.3	PAR 1110.2	CCR, Title 17, Division 3, Chapter 1, Subchapter 8, Article 3
	<p>(D) An owner or operator of a Unit shall maintain a parametric monitoring system and its associated components necessary to maintain a system that measures air-to-fuel ratio.</p> <p>(E) An owner or operator of a Unit shall inspect and maintain all sensors and meters used by the parametric monitoring system per manufacturer’s recommendations as specified in the operating manual.</p> <p>(F) An owner or operator of a Unit shall develop and implement procedures for at least daily monitoring of the parametric monitoring system.</p>	<p>additional two tests are not required if the permit limits the engine to operating at one defined load, ± 10%. No pre-tests for compliance are permitted. The emission test shall be conducted at least 40 operating hours, or at least 1 week, after any engine servicing or tuning. If an emission exceedance is found during any of the three phases of the test, that phase shall be completed and reported. The operator shall correct the exceedance, and the source test may be immediately resumed. Relative accuracy tests required by Rule 218.1 or 40 CFR Part 75 Subpart E shall satisfy this requirement for those pollutants monitored by a CEMS for all applicable operating loads specified in this clause (f)(1)(C)(ii).</p> <p>(iii) Use a contractor to conduct the source testing that is approved by the Executive Officer under the Laboratory Approval Program for the necessary test methods.</p> <p>(iv) Submit a source test protocol to the Executive Officer for written approval at least 60 days before the scheduled date of the test. The source test protocol shall include the name, address and phone number of the engine operator and a South Coast AQMD-approved source testing contractor that will conduct the test, the application and permit number(s), emission limits, a description of the engine(s) to be tested, the test methods and procedures to be used, the number of tests to be conducted and under what loads, the required minimum sampling time for the VOC test, based on the analytical detection limit and expected VOC levels, and a description of the parameters to be measured in accordance with the I&M plan required by subparagraph (f)(1)(D). The source test protocol shall be approved by the Executive Officer prior to any testing. The operator is not required to submit a protocol for approval if: there is a previously approved protocol that meets these requirements; the engine has not been altered in a manner that requires a permit alteration; and emission limits have not changed since the previous test. If the operator submits the protocol by the required date, and the Executive Officer takes longer than 60 days to approve the protocol, the operator shall be allowed the additional time needed to conduct the test.</p> <p>(v) Provide the Executive Officer at least 30 days prior notice of any source test to afford the Executive Officer the opportunity to have an observer present. If after 30 days notice for an initially scheduled performance test, there is a delay (due to operational problems, etc.) in conducting the scheduled performance test, the engine operator shall notify the Executive Officer as soon as</p>	<p>(4) Generator output (MW-hr), based on net output, shall be measured during each valid test run. A calibrated electric meter shall be used for the measurements. The meter shall meet the American National Standards Institute’s Code for Electricity Metering (ANSI C12.1-as of July 9, 2001).</p> <p>(5) Recovered heat shall be measured using a water loop device, measuring the water flow rate, inlet temperature, and outlet temperature.</p> <p>(6) The emission rate shall be expressed in lb/MW-hr.</p> <p>(7) Certification Fuels (A) Natural gas. (B) LPG that meets the standards of HD-5 propane. (C) Surrogate digester gas that is composed of 60 to 65 percent methane and 35 to 40 percent CO₂, by volume. (D) Surrogate landfill gas that is composed of 42 to 46 percent methane, 34 to 38 percent CO₂, and 18 to 22 percent N₂, by volume. (E) Surrogate oil-field waste gas that is composed of 63 to 71 percent methane, 6 to 8 percent ethane, 9 to 11 percent propane, 7 to 9 percent CO₂, and 7 to 8 percent carbon compounds with four or more carbon atoms per molecule, by volume. (e) Alternative testing procedures may be used upon written approval of the Executive Officer, if alternative procedures are deemed to be equivalent or more accurate than the prescribed procedures.</p>

Rule Element	PR 1110.3	PAR 1110.2	CCR, Title 17, Division 3, Chapter 1, Subchapter 8, Article 3
		<p>possible of any delay in the original test date, either by providing at least seven days prior notice of the rescheduled date of the performance test, or by arranging a rescheduled date with the Executive Officer by mutual agreement.</p> <p>(vi) Submit all source test reports, including a description of the equipment tested, to the Executive Officer within 60 days of completion of the test.</p> <p>(vii) By February 1, 2009, provide, or cause to be provided, source testing facilities as follows:</p> <p>(I) Sampling ports adequate for the applicable test methods. This includes constructing the air pollution control system and stack or duct such that pollutant concentrations can be accurately determined by applicable test methods;</p> <p>(II) Safe sampling platform(s), scaffolding or mechanical lifts, including safe access, that comply with California General Safety Orders. Agricultural stationary engines are excused from this subclause if they are in remote locations without electrical power;</p> <p>(III) Utilities for sampling and testing equipment. Agricultural stationary engines are exempt from this subclause if they are on wheels and moved to storage during the off season.</p> <p>(D) Inspection and Monitoring (I&M) Requirements</p> <p>(i) I&M Plan. The operator shall:</p> <p>(I) Submit to the Executive Officer for written approval an I&M plan. One plan application is required for each facility that does not have a NOx and CO CEMS for each engine. The I&M plan shall include all items listed in Attachment 1. The owner or operator may request an alternative item(s) in Attachment 1 that is determined by the Executive Officer to be equivalent in meeting the same objectives.</p> <p>(II) Upon written approval by the Executive Officer, implement the I&M plan as approved.</p> <p>(III) Submit an I&M plan for approval to the Executive Officer for a plan revision before any change in I&M plan operations can be implemented. The operator shall apply for a plan revision prior to any change in emission limits or control equipment.</p> <p>(f)(F) New Non-Emergency Electrical Generating Engines</p> <p>Operators of engines subject to the requirements of subparagraph (d)(1)(L) shall also meet the following requirements.</p> <p>(i) The engine generator shall be monitored with a calibrated electric meter that measures the net electrical output of the engine generator system, which is the difference between the electrical output of the generator and the electricity consumed by</p>	

Rule Element	PR 1110.3	PAR 1110.2	CCR, Title 17, Division 3, Chapter 1, Subchapter 8, Article 3
		<p>the auxiliary equipment necessary to operate the engine generator.</p> <p>(g) Test Methods Testing to verify compliance with the applicable requirements shall be conducted in accordance with the test methods specified in Table IX, or any test methods approved by CARB and EPA, and authorized by the Executive Officer.</p> <p>TABLE IX- TESTING METHODS NOx- South Coast Air Quality Management District Method 100.1 CO- South Coast Air Quality Management District Method 100.1 VOC- South Coast Air Quality Management District Method 25.1* or Method 25.3* * Excluding ethane and methane</p> <p>A violation of any standard of this rule established by any of the specified test methods, or any test methods approved by the CARB or EPA, and authorized by the Executive Officer, shall constitute a violation of this rule.</p>	
Reporting	An owner or operator of a Unit shall submit all source test reports to the Executive Officer within 60 days of completion of the test..	<p>(f)(D)(iii) Requirements for responding to, diagnosing and correcting breakdowns, faults, malfunctions, alarms, diagnostic emission checks finding emissions in excess of rule or permit limits, and parameters out-of-range.</p> <p>(I) For any diagnostic emission check or breakdown that results in emissions in excess of those allowed by this rule or a permit condition, the operator shall correct the problem as soon as possible and demonstrate compliance with another diagnostic emission check, or shut down an engine by the end of an operating cycle, or within 24 hours from the time the operator knew of the breakdown or excess emissions, or reasonably should have known, whichever is sooner.</p> <p>(H) Reporting Requirements (i) The operator shall report to the Executive Officer, by telephone (1-800-CUT-SMOG or 1-800-288-7664) or other South Coast AQMD-approved method, any breakdown resulting in emissions in excess of rule or permit emission limits within one hour of such noncompliance or within one hour of the time the operator knew or reasonably should have known of its occurrence. Such report shall identify the time, specific location, equipment involved, responsible party to contact for further information, and to the extent known, the causes of the</p>	None

Rule Element	PR 1110.3	PAR 1110.2	CCR, Title 17, Division 3, Chapter 1, Subchapter 8, Article 3
		<p>noncompliance, and the estimated time for repairs. In the case of emergencies that prevent a person from reporting all required information within the one-hour limit, the Executive Officer may extend the time for the reporting of required information provided the operator has notified the Executive Officer of the noncompliance within the one-hour limit.</p> <p>(ii) Within seven calendar days after the reported breakdown has been corrected, but no later than thirty calendar days from the initial date of the breakdown, unless an extension has been approved in writing by the Executive Officer, the operator shall submit a written breakdown report to the Executive Officer which includes:</p> <ul style="list-style-type: none"> (I) An identification of the equipment involved in causing, or suspected of having caused, or having been affected by the breakdown; (II) The duration of the breakdown; (III) The date of correction and information demonstrating that compliance is achieved; (IV) An identification of the types of excess emissions, if any, resulting from the breakdown; (V) A quantification of the excess emissions, if any, resulting from the breakdown and the basis used to quantify the emissions; (VI) Information substantiating whether the breakdown resulted from operator error, neglect or improper operation or maintenance procedures; (VII) Information substantiating that steps were immediately taken to correct the condition causing the breakdown, and to minimize the emissions, if any, resulting from the breakdown; (VIII) A description of the corrective measures undertaken and/or to be undertaken to avoid such a breakdown in the future; and (IX) Pictures of any equipment which failed, if available. <p>(iii) Within 15 days of the end of each calendar quarter, the operator shall submit to the Executive Officer a report that lists each occurrence of a breakdown, fault, malfunction, alarm, engine or control system operating parameter out of the acceptable range established by an I&M plan or permit condition, or a diagnostic emission check that finds excess emissions. Such report shall be in a South Coast AQMD-approved format, and for each incident shall identify the time of the incident, the time the operator learned of the incident, specific location, equipment involved, responsible party to contact for further information, to the extent known the causes of</p>	

Rule Element	PR 1110.3	PAR 1110.2	CCR, Title 17, Division 3, Chapter 1, Subchapter 8, Article 3
		the event, the time and description of corrective actions, including shutting an engine down, and the results of all portable analyzer NOx and CO emissions checks done before or after the corrective actions. The operator shall also report if no incidents occurred.	
Recordkeeping	<p>An owner or an operator of a Unit shall retain all data logs, source test reports, and other records required by this rule for at least five years and be made available to the Executive Officer upon request.</p> <p>(A) The owner or operator of a Unit shall maintain records, on a monthly basis, for the following parameters(s) or item(s):</p> <ul style="list-style-type: none"> (i) Quantity of fuel consumption (e.g., cubic feet of gas); (ii) Date of last emissions test required in subdivision (f) and subparagraph (g)(1)(A); (iii) Megawatt-hours of electricity produced; and (iv) Air-to-Fuel system faults, alarms, and any other related emission control malfunctions. <p>(B) An owner or operator of a Unit shall keep records to demonstrate compliance with paragraphs (e)(1), (f)(1), (f)(8), (f)(10), and (g)(1).</p>	<p>(E) Operating Log</p> <p>Maintain a monthly engine operating log that includes:</p> <ul style="list-style-type: none"> (i) Total hours of operation; (ii) Type of liquid and/or type of gaseous fuel; (iii) Fuel consumption (cubic feet of gas and gallons of liquid); and (iv) Cumulative hours of operation since the last source test required in subparagraph (f)(1)(C). 	<ul style="list-style-type: none"> (a) The Applicant must retain all information used for the certification application. (b) Upon request of the Executive Officer, the Applicant will submit information to the ARB on the number and location of certified DG Units in California. (c) The Applicant shall maintain a log identifying the components listed pursuant to section 94204(a)(6) that are replaced, the date of replacement, and the hours of operation each replaced component was used. (d) All records maintained pursuant to this certification program must be retained for a period of five years after the certification has expired. (e) All records maintained pursuant to this certification program shall be submitted to the ARB upon request of the Executive Officer.

APPENDIX A: LIST OF AFFECTED FACILITIES

Table A-1: Facilities Affected by PR 1110.3

Facility ID	Facility Name
8582	Southern California Gas Company
189493	Mainspring Energy, Incorporated/Food 4 Less
193535	Mainspring Energy, Incorporated/Lineage Logistics
193650	Mainspring Energy, Incorporated/Ralphs
193671	Mainspring Energy, Incorporated/Ralphs
193675	Mainspring Energy, Incorporated/Food 4 Less
193716	Mainspring Energy, Incorporated/Ralphs
193748	Mainspring Energy, Incorporated/Ralphs
193871	Mainspring Energy, Incorporated/Ralphs
194969	Mainspring Energy, Incorporated/Ralphs
194970	Mainspring Energy, Incorporated/Ralphs
194986	Mainspring Energy, Incorporated/Food 4 Less
195671	Mainspring Energy, Incorporated/Ralphs
195672	Mainspring Energy, Incorporated/Food 4 Less
197093	Mainspring Energy, Incorporated/Ralphs
197094	Mainspring Energy, Incorporated/Food 4 Less
197144	Mainspring Energy, Incorporated/Food 4 Less
197710	Mainspring Energy, Incorporated/Lineage Logistics
197890	Mainspring Energy, Incorporated/Food 4 Less
197925	Mainspring Energy, Incorporated/Lineage Logistics
198042	Mainspring Energy, Incorporated/Lineage Logistics
198085	Mainspring Energy, Incorporated/Lineage Logistics
198227	Mainspring Energy, Incorporated/Ralphs
198228	Mainspring Energy, Incorporated/Ralphs
198645	Prologis Denker

APPENDIX B – RESPONSES TO PUBLIC COMMENTS

Public Workshop Comments**Public Workshop Commenter #1: Alison Torres- Southern California Alliance of Publicly Owned Treatment Works**

The commenter expressed the following:

- a) Concerned about linear generators fueled with biogas reliably meeting emissions limits over the life of the equipment due to the lack of emissions data.
- b) Concerned about the proposed rule emission limits potentially hindering the adoption of linear generator technology by publicly owner treatment works and requested the same emission limits as Rule 1179.1 for biogas fueled linear generators.

Staff Response to Public Workshop Commenter #1:

- a) Staff acknowledged the lack of emissions data for biogas fueled linear generators. Staff will continue to work with manufacturers to obtain emissions data as well as address concerns regarding durability of the equipment.
- b) Staff is narrowing the applicability of PR 1110.3 to units fueled solely by natural gas. Units fueled with biogas will be evaluated by South Coast AQMD engineering staff to determine the appropriate emission limits as emission data becomes available.

Public Workshop Commenter #2: Dan McGivney- Southern California Gas Company

The commenter expressed the following:

- a) Due to linear generator technology being fairly new, questioned the timing of submittal of PR 1110.3 to U.S. EPA for inclusion into the State Implementation Plan (SIP) and suggested that staff delay submittal until more emissions data for biogas fueled units was received.

Staff Response to Public Workshop Commenter #2:

- a) Staff narrowed the applicability of PR 1110.3 to only include natural gas fueled linear generators. PR 1110.3 will be submitted for inclusion into the SIP.

Public Workshop Commenter #3: Adam Simpson- Mainspring Energy, Incorporated

The commentor expressed looking forward to continued engagement on the rulemakings and thanked the Working Group.

Staff Response to Public Workshop Commenter #3:

Staff likewise looks forward to continued public engagement throughout this rule development.

Public Workshop Commenter #4: Bipul Saraf- Yorke Engineering

The commenter expressed the following:

- a) Asked if source tests were the only acceptable compliance test in PR 1110.3.

- b) Concern over linear generator technology meeting emission limits over the life of the equipment.

Staff Response to Public Workshop Commenter #4:

- a) PR 1110.3 contains both source testing and portable analyzer testing requirements. Staff updated the source test frequency and monitoring requirements in PR 1110.3. The proposed source test frequency is every five years.
- b) Staff is working with the technology manufacturers to determine the durability of the equipment over time as it relates to emissions.

Email Comments**Email Comment #1: Corrie Zuppo- Mainspring Energy, Incorporated**

Attached are Mainspring Energy's comments to South Coast AQMD Proposed Rule 1110.3.

(Adopted TBD)

V012023

**PROPOSED
RULE 1110.3**

EMISSIONS FROM LINEAR GENERATORS

(a) Purpose

The purpose of this rule is to reduce emissions of Oxides of Nitrogen (NO_x), Volatile Organic Compounds (VOCs), and Carbon Monoxide (CO) from linear generators.

(b) Applicability

This rule shall apply to linear generators fueled on natural gas, landfill gas, ~~or digester gas, or hydrogen or propane gas~~, with the exception of those units exempt under Section (h). ~~All linear generators are subject to this rule.~~

1-1

(c) Definitions

(1) BREAKDOWN means a physical or mechanical failure or malfunction of a linear generator, air pollution control equipment, or related operating equipment that is not the result of operator error, neglect, improper operation or improper maintenance procedures, which ~~results in~~ may lead to excess emissions beyond rule related emission limits or permit conditions.

1-2

(2) DAILY means the time period starting at 12 midnight and continuing through 11:59 p.m.

(3) DIGESTER GAS means gas that is produced by anaerobic decomposition of organic material.

(4) EMERGENCY STANDBY UNIT means any Linear Generator which operates as a temporary replacement for primary ~~mechanical or~~ electrical power during periods of fuel or energy shortage or while the primary power supply is under repair.

1-3

(5) FACILITY means any source or group of sources or other air contaminant emitting activities which are located on one or more contiguous properties within the South Coast AQMD, in actual physical contact or separated solely by a public roadway or other public right-of-way, and are owned or operated by the same person (or by persons under common control), or an outer continental shelf (OCS) source as determined in Section 55.2 of Title 40, Part 55 of the Code of Federal Regulations (40 CFR Part 55). Such above-described groups, if noncontiguous, but connected only by land carrying a pipeline, shall not be considered one

- facility. Sources or installations involved in crude oil and gas production in Southern California Coastal or OCS Waters and transport of such crude oil and gas in Southern California Coastal or OCS Waters shall be included in the same facility which is under the same ownership or use entitlement as the crude oil and gas production facility on-shore.
- (6) LANDFILL GAS means any gas derived through a natural process from the decomposition of waste deposited in an MSW Landfill.
- (7) LINEAR GENERATOR means any power generation technology that uses a thermochemical reaction to create linear motion that is directly converted into electricity.
- (8) MUNICIPAL SOLID WASTE or MSW LANDFILL means an entire disposal facility in a contiguous geographical space where solid waste is placed in or on land. An MSW Landfill may be active, inactive, or closed.
- (A) Active MSW Landfill means a Municipal Solid Waste Landfill that has received solid waste on or after November 8, 1987.
- (B) Inactive MSW Landfill means a Municipal Solid Waste Landfill that has not accepted solid waste after November 8, 1987 and subsequently no further solid waste disposal activity has been conducted within the disposal facility.
- (C) Closed MSW Landfill means a Municipal Solid Waste Landfill that has ceased accepting solid waste for disposal and the closure was conducted in accordance with all applicable federal, state and local statutes, regulations, and ordinances in effect at the time of closure.
- (9) NATURAL GAS means a mixture of gaseous hydrocarbons, with at least 80 percent methane by volume, and of pipeline quality, such as the gas sold or distributed by any utility company regulated by the California Public Utilities Commission.
- (10) ~~OPERATING CYCLE means a period of time within which a round of regularly recurring events is completed, and cannot be stopped without the risk of endangering public safety or health, causing material damage to the equipment or product, or cannot be stopped due to technical constraints. Economic reasons alone will not be sufficient to extend this time period. The Operating Cycle includes batch processes that may start and finish several times within a twenty-four hour period, in which case each start to finish interval is considered a complete cycle.~~

- (11) OXIDES OF NITROGEN (NO_x) means the sum of nitric oxides and nitrogen dioxides emitted, collectively expressed as nitrogen dioxide emissions.
- (12) STANDARDIZED SOURCE TEST PROTOCOL means a source test protocol specific to the make and model of the equipment that is approved by the South Coast AQMD and may be used for all source tests on linear generators of the same make and model. 1-5
- (13) TUNING means adjusting, optimizing, rebalancing, or other similar operations to an electric generating Unit or an associated control device or as otherwise defined in the Permit to Operate. Tuning does not include normal operations to meet load fluctuations.
- (14) UNIT means, for purposes of this rule, any linear generator. 1-6
- (15) VOLATILE ORGANIC COMPOUND (VOC) as defined in Rule 102 – Definition of Terms.

(d) Emission Limits

- (1) An owner or operator of a Unit shall not operate the Unit in a manner that exceeds the NO_x, CO, and VOC emission limits listed in Table 1: Concentration Limits for Linear Generators, pursuant to subdivision (f):

Table 1: Concentration Limits for Linear Generators

Units with a Permit to Operate Issued on and after [Date of Adoption]			
Fuel Type	NO_x (ppmv)¹	CO (ppmv)¹	VOC (ppmv)²
Natural Gas, Propane Gas , Hydrogen Gas, Landfill Gas, and Digester Gas	2.5	12	10

¹ Parts per million by volume, corrected to 15% oxygen on a dry basis and averaged over 15 minutes.

² Parts per million by volume, measured as carbon, corrected to 15% oxygen on a dry basis, and averaged over the sampling time required by the test method.

- (2) In the event of a potential breakdown that results in emissions in excess of those allowed by Table 1, the Unit’s Inspection and Monitoring Plan will be adhered to. 1-8
- (3) ~~An owner or operator shall shut down a Unit having a Breakdown that results in~~ 1-9

- ~~emissions in excess of those allowed by Table 1 by the end of an Operating Cycle, or within 24 hours from the time the owner or operator knew of the Breakdown or excess emissions, or reasonably should have known, whichever is sooner.~~
- (4) ~~Maintenance Requirements~~
- (5) An owner or operator of a Unit shall perform maintenance per manufacturer's recommendations as specified in the operating and maintenance manual.
- (6) An owner or operator of a Unit shall keep a copy of the manufacturer's operating manual and be made available to the Executive Officer upon request.
- (e) **Certification**
- (1) The manufacturer shall obtain confirmation from an independent testing laboratory prior to applying for certification that each unit model complies with the applicable requirements of subdivision (d). This confirmation shall be based upon emission tests of a randomly selected unit of each model, and the agreed upon **standardized** source test protocol shall be adhered to during the confirmation testing of all units subject to this rule.
- (2) When applying for unit(s) certification, the manufacturer shall submit to the Executive Officer the following:
- (A) A statement that the model is in compliance with subdivision (d). The statement shall be signed and dated, and shall attest to the accuracy of all statements;
- (B) General Information
- (i) Name and address of manufacturer,
- (ii) Brand name, and
- (iii) Model number
- (C) A description of each model being certified; and
- (D) A source test report verifying compliance with the emission limits in subdivision (d) for each model to be certified. The source test report shall be prepared by the confirming independent testing laboratory. The source test shall have been conducted no more than ninety (90) days prior to the date of submittal of a certification application to the Executive Officer.
- (3) When applying for unit certification, the manufacturer shall submit the items identified in paragraph (f)(2) no more than ninety (90) days after the date of the source test identified in subparagraph (f)(2)(D) and at least 120 days prior to the date of the proposed sale of the units.
- (4) The Executive Officer shall certify a unit model which complies with the

1-9 cont'd

1-10

1-11

- provisions of subdivision (d) and of paragraphs (f)(1), (f)(2), and (f)(3) within 30 days of receipt of the items identified in paragraph (f)(2).
- (5) Certification status shall be valid for three years from the date of approval by the Executive Officer. After the third year, recertification may be required according to the requirements of paragraphs (f)(1) and (f)(2). 1-11 cont'd
- (f) Source Testing
- (1) An owner or operator of a Unit shall conduct source testing for NO_x, VOC reported as carbon, and CO concentrations (concentrations in ppm by volume, corrected to 15 percent oxygen on dry basis) at least once every ~~three~~ ~~two~~ years from the date of the previous source test, no later than the last day of the calendar month that the test is due, ~~or every 8,760 operating hours, whichever occurs first.~~ The source test schedule may be changed under the following circumstances: 1-12
- ~~An owner or operator of a Unit may elect to reduce the source test frequency to once every three years if the Unit has operated less than 2,000 hours since the last source test, or~~ 1-13
- (A) An owner or operator of a Unit that has not been operated before the date a source test is due, shall conduct a source test by the end of ~~90~~ ~~seven~~ ~~consecutive days or 15 cumulative days~~ of resumed operation. 1-14
- (B) In lieu of a source test every three years, a diagnostic emission check for NO_x and CO concentrations (concentrations in ppm by volume, corrected to 15 percent oxygen on dry basis) may be conducted using a portable analyzer or equivalent measurement device. The operator shall measure NO_x and CO concentrations as outlined in an approved Inspection and Monitoring Plan. If emissions are found to exceed the emissions limits in Table 1, the operator shall conduct a source test. 1-15
- (2) An owner or operator of a Unit shall conduct the source test by using a contractor that is approved under the South Coast AQMD's Laboratory Approval Program (LAP) for the test methods specified in Table 2: Testing Methods, or any test methods approved by CARB and EPA, and authorized by the Executive Officer.

Table 2: Testing Methods

Pollutant	Method
NO _x	South Coast AQMD Method 100.1

CO	South Coast AQMD Method 100.1
VOC	South Coast AQMD Method 25.1* or Method 25.3*

*Excluding ethane and methane

- (3) An owner or operator of a Unit shall submit a source test protocol to the Executive Officer for written approval at least 60 days before the scheduled date of the test. The source test protocol shall include, but not limited to the following:
 - (A) Name, address, and phone number of the Unit operator and a South Coast AQMD-approved source testing contractor that will conduct the test;
 - (B) Application number(s), permit number(s), and emission limits;
 - (C) Description of the Unit(s) to be tested and the test methods and procedures to be used;
 - (D) Number of tests to be conducted and under what loads; and
 - (E) Required minimum sampling time for the VOC test, based on the analytical detection limit and expected VOC levels.
- (4) An owner or operator of a Unit shall conduct the source test within 90 days after a written approval of the source test protocol by the Executive Officer is electronically distributed.
- (5) An owner or operator of a Unit subject to a previously approved **standardized** source test protocol shall submit a subsequent protocol if the Unit has been altered in a manner that requires a permit alteration, if emission limits for the Unit have changed since the previous source test, or if requested by the Executive Officer.
- (6) An owner or operator of a Unit shall provide the Executive Officer at least 30 days prior notice of any source test to afford the Executive Officer the opportunity to have an observer present. If, after the 30 days prior notice is given, there is a delay (due to operational problems, etc.) in conducting the scheduled source test, the owner or operator of a Unit shall notify the Executive Officer as soon as possible of any delay in the original test date, either by providing notice of the rescheduled date of the source test at least seven days prior, or by arranging a rescheduled date mutually agreed upon with the Executive Officer.
- (7) An owner or operator of a Unit shall provide source testing facilities as follows:
 - (A) Sampling ports adequate for the applicable test methods. This includes constructing the air pollution control system and stack or duct such that

- pollutant concentrations can be accurately determined by applicable test methods;
- (B) Safe sampling platform(s), scaffolding or mechanical lifts, including safe access, that comply with California General Safety Orders; and
 - (C) ~~Utilities for sampling and testing equipment.~~
- (8) The LAP contractor shall conduct source testing for at least 30 minutes during normal operation (actual duty cycle). This test shall not be conducted under a steady-state condition unless it is the normal operation. ~~In addition, the LAP contractor shall conduct source testing for NOx and CO emissions for at least 15 minutes at: a Unit’s actual peak load, or the maximum load that can be practically achieved during the test, and at actual minimum load, excluding idle, or the minimum load that can be practically achieved during the test. These additional two tests are not required if the permit limits the Unit to operating at one defined load ± 10%. The LAP contractor shall not conduct any pre-tests for compliance. If an emission exceedance is found during any of the three phases of the test, that phase shall be completed and reported. An operator shall correct the exceedance, and the source test may be immediately resumed.~~
- (9) ~~The LAP contractor shall conduct the source test at least 40 operating hours, or at least 1 week, whichever occurs later, after any Unit servicing or tuning.~~
- (10) A Unit certified in accordance with subdivision (e), Certification, shall be exempt from the requirements of subdivision (f) for the period of the certification.
- (g) Monitoring, Recordkeeping, and Reporting
- (1) Monitoring
 - (A) ~~An owner or operator of a Unit shall maintain an operational non-resettable totalizing time meter to determine the elapsed operating time of the Unit.~~
 - (B) An owner or operator of a Unit shall maintain a utility grade calibrated electric meter that measures the net electrical output of the Unit, which is the difference between the electrical output and the electricity consumed by the auxiliary equipment necessary to operate the Unit.
 - (C) An owner or operator of a Unit shall maintain a District approved parametric monitoring system ~~consisting of an air-to-fuel ratio controller (AFRC), an oxygen sensor, a fuel flow meter, and an air flow meter, which has a malfunction indicator light and audible alarm.~~

- (D) An owner or operator of a Unit shall inspect ~~and~~; maintain, ~~and replace~~ all sensors and meters used by the parametric monitoring system per manufacturer's recommendations as specified in the operating manual. 1-24
- (E) An owner or operator of a Unit shall ~~develop and implement procedures for at least daily monitoring of the parametric monitoring system. monitor and record at least daily the following:~~
- (i) ~~fuel flow rate;~~
 - (ii) ~~elapsed time meter operating hours;~~
 - (iii) ~~AFRC system faults, alarms, and any other related emission control malfunctions; and~~
 - (iv) ~~operating hours since the last source test required by subdivision (f).~~
- 1-25
- (2) Recordkeeping
- An owner or operator of a Unit shall retain all data logs, source test reports, and other records required by this rule for at least five years and be made available to the Executive Officer upon request.
- (A) The owner or operator of a Unit shall maintain records, on a monthly basis, for the following parameters(s) or item(s):
- (i) Total hours of operation;
 - (ii) Type of fuel and quantity of fuel consumption (e.g., cubic feet of gas);
~~Cumulative hours of operation since the last source test required in subdivision (f);~~
 - (iii) Megawatt-hours of electricity produced; and
 - (iv) ~~Air-to-Fuel~~AFRC system faults, alarms, and any other related emission control malfunctions.
- 1-26
- (B) An owner or operator of a Unit shall keep records to demonstrate compliance with paragraphs (e)(1), (f)(1), ~~and (f)(9).~~ 1-27
- (C) An owner or operator of a Unit shall keep sufficient operating records to demonstrate that it meets the requirements for extension of the source testing deadlines, pursuant to paragraph (f)(1).
- (3) Reporting
- (A) ~~In the event of a breakdown, the operator shall follow the procedures in Rule 430 for reporting of the breakdown. The operator shall report to the Executive Officer, by telephone (1-800-CUT-SMOG or 1-800-288-7664) or other South Coast AQMD approved method, any Breakdown resulting~~
- 1-28

~~in emissions in excess of rule or permit emission limits within one hour of such noncompliance or within one hour of the time the operator knew or reasonably should have known of its occurrence. Such report shall identify the time, specific location, equipment involved, responsible party to contact for further information, and to the extent known, the causes of the noncompliance, and the estimated time for repairs. In the case of emergencies that prevent a person from reporting all required information within the one-hour limit, the Executive Officer may extend the time for the reporting of required information provided the operator has notified the Executive Officer of the noncompliance within the one-hour limit.~~

- (B) ~~Within seven calendar days after the reported Breakdown has been corrected, but no later than thirty calendar days from the initial date of the Breakdown, unless an extension has been approved in writing by the Executive Officer, the owner or operator shall submit a written Breakdown report to the Executive Officer which includes:¶¶~~
- ~~(i) An identification of the equipment involved in causing, or suspected of having caused, or having been affected by the Breakdown;¶¶~~
 - ~~(ii) The duration of the Breakdown;¶¶~~
 - ~~(iii) The date of corrective action and information demonstrating that compliance is achieved;¶¶~~
 - ~~(iv) An identification of the types of excess emissions, if any, resulting from the Breakdown;¶¶~~
 - ~~(v) A quantification of the excess emissions, if any, resulting from the Breakdown and the basis used to quantify the emissions;¶¶~~
 - ~~(vi) Information substantiating whether the Breakdown resulted from operator error, neglect or improper operation or maintenance procedures;¶¶~~
 - ~~(vii) Information substantiating that steps were immediately taken to correct the condition causing the Breakdown, and to minimize the emissions, if any, resulting from the Breakdown;¶¶~~
 - ~~(viii) A description of the corrective measures undertaken and/or to be undertaken to avoid such a Breakdown in the future; and¶¶~~
- (C) ~~Pictures of any equipment which failed, if available.~~
- (D) An owner or operator of a Unit shall submit all source test reports,

1-28 cont'd

- ~~including a description of the equipment tested,~~ to the Executive Officer within 60 days of completion of the test. 1-29
- (h) Exemptions
- (1) The requirements of Section (g) shall not apply to linear generators that have been certified under Section (f). 1-30
- (2) The provisions of this rule shall not apply to linear generators that have received a California Air Resources Board Executive Order issued under the Distributed Generation (DG) Certification Regulation
- (3) The provisions of subdivisions (d) shall not apply to:
- (A) Laboratory Units used for testing and research purposes; and
 - (B) Units operating pursuant to Rule 441 with a valid experimental research operations permit to operate, operated for the purposes of performance verification and testing of such Units.
- (4) The provisions of subdivisions (f) shall not apply to:
- (A) Emergency Standby Units, Units used for fire-fighting and flood control, and any other emergency Unit approved by the Executive Officer, which have permit conditions that limit operation to 200 hours or less per year as determined by an elapsed operating time meter.

Staff Responses to Email Comment #1:*Response to Email Comment 1-1:*

Staff narrowed the applicability of PR 1110.3 to natural gas fueled linear generators only. Source test data was provided for natural gas fueled units which verified the achievability of the proposed emission limits. Since no source test data was provided for any fuel besides natural gas, other fuels are not included in PR 1110.3 applicability.

Response to Email Comment 1-2:

Staff removed this definition from PR 1110.3. Units subject to PR 1110.3 will be subject to the breakdown provisions in Rule 430.

Response to Email Comment 1-3:

Staff updated the definition to reflect this edit and to further streamline the definition.

Response to Email Comment 1-4:

Staff updated this provision to reflect the suggested edit.

Response to Email Comment 1-5:

Staff is not including the proposed definition because South Coast AQMD recognizes the source test protocol submitted by the equipment manufacturer as a generic source test protocol rather than a standardized source test protocol. Standardized source test protocols are available to the public through the South Coast AQMD website, whereas generic source test protocols are not publicly available. PR 1110.3 includes verbiage to reference generic source test protocols in subdivision (f) and the staff report provides clarity on what a generic protocol is.

Response to Email Comment 1-6:

Staff updated subdivision (c) of PR 1110.3 to clarify that the definitions provided are for the purposes of the rule. In addition, the definition of Unit was updated to clarify that a Unit means any single linear generator core.

Response to Email Comment 1-7:

Please see Response to Email Comment 1-1. In addition, Table 1 has been updated to reflect the updated applicability in PR 1110.3.

Response to Email Comment 1-8:

Please see Response to Email Comment 1-2. Staff did not include the proposed provision for allowing the Unit's Inspection and Monitoring Plan to be adhered to in the event of a breakdown in PR 1110.3, as it could potentially conflict with the requirements set forth in Rule 430 clause (b)(3)(A)(iv).

Response to Email Comment 1-9:

Staff updated the provision to reflect the suggested edit.

Response to Email Comment 1-10:

Staff will keep maintenance requirements as a separate subdivision from emission limits.

Response to Email Comment 1-11:

Staff did not include the proposed rule language as U.S. EPA indicated that the provisions related to a South Coast AQMD certification program would likely be disapproved since the certification program has not been developed. Staff commits to begin the development of a South Coast AQMD certification program for linear generators within 90 days of the adoption of PR 1110.3 and initiate a rule development process after finalizing a South Coast AQMD certification program for linear generators.

Response to Email Comment 1-12:

Staff updated the source testing frequency for non-pooled units to every five years to address concerns about source test frequency. In addition, an option to pool test facilities with six or more identical units has been added to further reduce source testing burdens.

Response to Email Comment 1-13:

Staff updated this provision to reflect the suggested edit.

Response to Email Comment 1-14:

Staff will require that the source test be conducted within 90 days as requested.

Response to Email Comment 1-15:

This proposal is not acceptable as the emission measurements taken from portable analyzers by a facility operator are not enforceable. U.S. EPA would likely not approve PR 1110.3 into the SIP without an enforceable mechanism to determine compliance with emission limits. In addition, source testing can be done for all pollutants regulated by PR 1110.3 (i.e. NO_x, CO, and VOC), whereas portable analyzer testing would not measure VOC emissions.

Response to Email Comment 1-16:

Please see Response to Email Comment 1-5.

Response to Email Comment 1-17:

Consistent with other rules with source testing requirements, this provision is necessary to ensure that LAP contractors have access to needed utilities to conduct source tests.

Response to Email Comment 1-18:

Staff updated this provision to reflect the suggested edit.

Response to Email Comment 1-19:

Staff retained and clarified this provision, as is important to ensure that units are not tuned prior to testing, thus ensuring the integrity and validity source test data.

Response to Email Comment 1-20:

Please see Response to Email Comment 1-11.

Response to Email Comment 1-21:

Staff updated the rule to remove this provision.

Response to Email Comment 1-22:

Staff updated this to a net output meter that is compliant with ANSI C12.20 or equivalent.

Response to Email Comment 1-23:

Staff does not believe that it is necessary to have a specific District approved parametric monitoring system. However, staff recognizes the variation of parametric monitoring systems and thus, the provision has been updated to be more general in the event of potential design changes.

Response to Email Comment 1-24:

Staff updated this provision to reflect the suggested edits.

Response to Email Comment 1-25:

Staff updated this provision to reflect the suggested edits.

Response to Email Comment 1-26:

Staff removed this provision and has updated PR 1110.3 subparagraph (g)(2)(A) to reflect the suggested edits.

Response to Email Comment 1-27:

Please see Response to Email Comment 1-19. Recordkeeping requirements are necessary to verify compliance with maintenance and emission testing requirements in PR 1110.3.

Response to Email Comment 1-28:

Staff deleted the breakdown reporting requirements in PR 1110.3, as requested. Rule 430 will apply to units regulated under PR 1110.3. Staff did not include the proposed language to directly reference Rule 430 for reporting of breakdown requirements.

Response to Email Comment 1-29:

Staff updated this provision to reflect the suggested edits, since the source test protocol contains requirements to submit source test reports that include a description of the equipment tested.

Response to Email Comment 1-30:

Please see Response to Email Comment 1-11. Staff discussed the proposal to provide an exemption for units certified under the California Air Resources Board (CARB) Distributed Generation (DG) Certification Regulation with U.S. EPA. U.S. EPA expressed concerns about establishing an exemption from PR 1110.3 for units with CARB DG certifications when the CARB DG Certification Regulation is not SIP approved.

Email Comment #2: Corrie Zuppo- Mainspring Energy, Incorporated

Hay Lo

From: Corrie Zupo <corrie.zupo@mainspringenergy.com>
Sent: Monday, February 6, 2023 5:00 PM
To: Hay Lo
Cc: Isabelle Shine; Michael Morris; Michael Krause; Adam Simpson; Scott Weaver; Melicia Charles
Subject: PR 11110.3 tuning and breakdown reporting

Good afternoon Hay,

As an additional follow-up to last week's PR 1110.3 call, we wanted to provide further comments on the definition of tuning and breakdown reporting. The definition of tuning suggestions is from SoCal Gas, who have been champions of linear generator technology. The breakdown reporting language is a condensed version of our current I&M Plan process.

Section c(13) Tuning:

TUNING means adjusting, optimizing, **rebalancing**, or other similar **action operations** to an electric generating Unit or an associated control device or otherwise defined in the Permit to Operate. Tuning does not include normal operations, **for example, adjustments to meet load fluctuations or any adjustment made automatically by the control system.**

2-1

Section g(3) Reporting:

- (A) In the event of a breakdown, the operator shall follow the procedures in Rule 430 for reporting of the breakdown.
- (B) A remote audit will commence upon notification of potential evidence of the emissions limits. If it is determined that there was an exceedance event, the operator will make any necessary adjustments to get the operation within the emissions limits. If the operator is unsuccessful in achieving and maintaining operation within the emission limits within 72 hours of the remote audit, the unit will be shut down until an onsite inspection can occur and the unit is operating below the emission limits.
- (C) In the event of a breakdown, the operator shall follow the procedures in Rule 430 for reporting of a breakdown.
- (D) An owner or operator of a Unit shall submit all source test reports to the Executive Officer within 60 days of completion of the test.

2-2

Please let me know if you have any questions and/or would like to discuss this further.

Best regards,

Corrie Zupo | Environmental Manager Permitting & Compliance | [Mainspring](#) | (c) 424-241-8959

Need to chat? Here's access to my [calendar](#) to set up an invite.

Staff Responses to Email Comment #2:*Response to Email Comment 2-1:*

Staff provided additional clarity as to what is considered tuning, which incorporates most of the suggested language. Staff did not include the term “action operations” as it was not clearly defined from other operations.

Response to Email Comment 2-2:

Please see Response to Email Comments 1-28. The proposed rule language referred to as section (g)(3)(B) was not included in Proposed Rule 1110.3, as it seems to conflict with Rule 430 requirements.

Email Comment #3: Corrie Zuppo- Mainspring Energy, Incorporated

Hay Lo

From: Corrie Zupo <corrie.zupo@mainspringenergy.com>
Sent: Monday, February 6, 2023 4:33 PM
To: Hay Lo
Cc: Isabelle Shine; Michael Morris; Adam Simpson; Scott Weaver; Melicia Charles; Michael Krause
Subject: PR 1110.3 testing follow-up

Good afternoon Hay,

Mainspring appreciates the SCAQMD staff’s work on the PR1110.3 proposed rule language. In our meeting on February 2, we discussed Mainspring’s proposal to update rule language to allow for annual NOx and CO emission testing with a portable analyzer in lieu of performing a source test every three years. Just to clarify, our proposal is to require testing using a portable analyzer, and if the results are above the permit limits, then we would take corrective action and then perform a source test. Our hope is that this will address the enforceability concerns.

3-1

With respect to the timing of any testing (source or portable analyzer), Mainspring would strongly prefer the test schedule to be tied to operating hours rather than calendar months or years. We have a lot of projects in the pipeline that only operate 40-70% of the time (e.g., solar paired or EV charging), and having testing based on calendar months or years puts these projects at an economic disadvantage relative to projects that operate continuously.

3-2

We discussed this on the call, but we want to reiterate that Mainspring remains concerned about the disparate treatment of the linear generator technology when compared to other non-emergency electrical generation technologies of comparable rating (i.e., microturbines and fuel cells). As shown in the table below, emissions of NOx and CO from linear generators are comparable to those of microturbines and fuel cells. However, there are no source testing requirements for microturbines (permitted or registered) or registered fuel cells. The District’s proposal to require source tests on linear generators causes a significant regulatory disparity, especially given the similar emissions profiles.

Table 1. Emission Comparison			
Pollutant	Emissions (lb/MWhr)^{1,2}		
	Linear Generator	Fuel Cell	Microturbine
NOx	0.06	0.07	0.07
CO	0.02	0.10	0.10

1. Based on Montrose Source Test Report for Colton location. Test date: 4/1/21.
 2. Microturbne and Fuel Cell emissions based on CARB Distributed Generation Executive Orders: <https://ww2.arb.ca.gov/our-work/programs/dqcert/exec-orders>

3-3

Requiring source testing also causes a competitive disadvantage when compared to those other distributed generation technologies. A 15-year cost comparison, under the current permitting rules, of these technologies is presented below.

Table 2. Source Test Cost Comparison

3-4

Fee/Cost	Linear Generator	Fuel Cell	Microturbine (Registered)	Microturbine (permitted)
SCAQMD source test protocol review ¹	\$471.83	\$0.00	\$0.00	\$0.00
SCAQMD source test report review (15 yrs) ^{2,3}	\$14,231.25	\$0.00	\$0.00	\$0.00
Cost of source test (15 yrs) ^{3,4}	\$150,000	\$0.00	\$0.00	\$0.00
Total	\$164,703.08	\$0.00	\$0.00	\$0.00
<ol style="list-style-type: none"> 1. Rule 306(m)(1). Based on a 5 hr evaluation. Fees are increased on an hourly basis beyond 5 hrs. However, the SCAQMD source test engineer stated that the protocol evaluation typically takes 5 hrs. 2. Based on invoice # 4082044, reference #PR220000, for 8 hours of source test review billed at \$948,75 per review. 3. Assumes source test is required upon startup and every year thereafter. 4. Assumes \$10,000 per source test for a single unit project/site. 				

3-4
cont'd

Even at a 3-year source test interval, costs are drastically disproportional. The District has suggested requiring source tests because this is a new technology. However, several of these units have been operating within the District and in BAAQMD for multiple years. A growing number of source tests have been performed, all demonstrating compliance with the emission limits in PR1110.3. The lack of variation in the equipment performance should provide the District with the needed assurance that the emissions will not vary from unit to unit. Mainspring is respectfully requesting that the District reconsiders and adopt Mainspring’s proposal to allow for portable analyzer testing in lieu of source tests.

Please let me know if you have any questions and/or would like to discuss this further.

Best regards,

Corrie Zupo | Environmental Manager Permitting & Compliance | [Mainspring](#) | (c) 424-241-8959

Need to chat? Here's access to my [calendar](#) to set up an invite.

Staff Responses to Email Comment #3:*Response to Email Comment 3-1:*

Please see Response to Email Comment 1-15.

Response to Email Comment 3-2:

Staff updated PR 1110.3 to remove the requirements for a non-resettable hour meter and thus, emission testing frequencies will be determined by calendar dates. Please see Response to Email Comment 1-12.

Response to Email Comment 3-3:

Although linear generator emission profiles are similar to those of microturbines and fuel cells, staff believes that emission testing is necessary. Some microturbines and fuel cells carry CARB Certifications for specific units, meeting CARB's Distributed Generation standards. The proposed emissions testing requirements will provide staff with assurances of the durability and robustness of the technology.

Response to Email Comment 3-4:

Staff proposed a new emissions testing schedule to help alleviate costs associated with emission testing. Based on the new testing schedule and an estimated cost of \$10,000 per source test, staff calculates the cost of source testing each unit to be approximately \$30,000 over a 15-year period. The new test schedule translates to over 60% cost savings over the originally proposed source test frequency that units are currently subject to in R1110.2. In addition, staff has also incorporated pooled initial source testing for facilities with six or more identical units. Since the pooled source testing will allow for testing of one-third of the Units, this provision will further reduce source testing costs.

Email Comment #4: Steve Jepsen- Southern California Alliance of Publicly Owned Treatment Works

Please find a comment letter and rule redlines attached from SCAP/Clean Water SoCal. We appreciate the opportunity to comment.

PROPOSED CHANGES TO PR 1110.3-
CLEANWATER SOCAL REDLINES 2/8/23

(Adopted TBD)

V120822

**PROPOSED
RULE 1110.3 EMISSIONS FROM LINEAR GENERATORS**

- (a) Purpose
The purpose of this rule is to reduce emissions of Oxides of Nitrogen (NO_x), Volatile Organic Compounds (VOCs), and Carbon Monoxide (CO) from Linear Generators.
- (b) Applicability
All Linear Generators are subject to this rule.
- (c) Definitions
- (1) BREAKDOWN means a physical or mechanical failure or malfunction of a Linear Generator, air pollution control equipment, or related operating equipment that is not the result of operator error, neglect, improper operation or improper maintenance procedures, which may lead to excess emissions beyond rule related emission limits or permit conditions.
 - (2) DAILY means the time period starting at 12 midnight and continuing through 11:59 p.m.
 - (3) DIGESTER GAS means gas that is produced by anaerobic decomposition of organic material.
 - (4) DUAL FUEL UNIT is any Unit subject to this rule permitted to fire digester gas and another fuel
 - ~~(4)~~(5) FACILITY means any source or group of sources or other air contaminant emitting activities which are located on one or more contiguous properties within the South Coast AQMD, in actual physical contact or separated solely by a public roadway or other public right-of-way, and are owned or operated by the same person (or by persons under common control), or an outer continental shelf (OCS) source as determined in Section 55.2 of Title 40, Part 55 of the Code of Federal Regulations (40 CFR Part 55). Such above-described groups, if noncontiguous, but connected only by land carrying a pipeline, shall not be considered one Facility.
 - ~~(5)~~(6) LANDFILL GAS means any gas derived through a natural process from the decomposition of waste deposited in an MSW Landfill.
 - ~~(6)~~(7) LINEAR GENERATOR means any power generation technology that uses a thermochemical reaction to create linear motion that is directly converted into electricity.

4-1

PR 1110.3 - 1

PROPOSED CHANGES TO PR 1110.3-
CLEANWATER SOCIAL REDLINES 2/8/23

Proposed Rule 1110.3 (Cont.)

(Adopted TBD)

- ~~(7)~~(8) MUNICIPAL SOLID WASTE or MSW LANDFILL means an entire disposal Facility in a contiguous geographical space where solid waste is placed in or on land. An MSW Landfill may be active, inactive, or closed.
- (A) Active MSW Landfill means a Municipal Solid Waste Landfill that has received solid waste on or after November 8, 1987.
- (B) Inactive MSW Landfill means a Municipal Solid Waste Landfill that has not accepted solid waste after November 8, 1987 and subsequently no further solid waste disposal activity has been conducted within the disposal Facility.
- (C) Closed MSW Landfill means a Municipal Solid Waste Landfill that has ceased accepting solid waste for disposal and the closure was conducted in accordance with all applicable federal, state and local statutes, regulations, and ordinances in effect at the time of closure.
- ~~(8)~~(9) NATURAL GAS means a mixture of gaseous hydrocarbons, with at least 80 percent methane by volume, and of pipeline quality, such as the gas sold or distributed by any utility company regulated by the California Public Utilities Commission.
- (10) OPERATING CYCLE means a period of time within which a round of regularly recurring events is completed, and cannot be stopped without the risk of endangering public safety or health, causing material damage to the equipment or product, or cannot be stopped due to technical constraints. Economic reasons alone will not be sufficient to extend this time period. The Operating Cycle includes batch processes that may start and finish several times within a twenty-four hour period, in which case each start to finish interval is considered a complete cycle.
- ~~(9)~~(11) PUBLICLY OWNED TREATMENT WORKS FACILITY OR POTW FACILITY is a wastewater treatment or reclamation plant owned or operated by a public entity, including all operations within the boundaries of the wastewater and sludge treatment plant.
- ~~(10)~~(12) OXIDES OF NITROGEN (NO_x) means the sum of nitric oxides and nitrogen dioxides emitted, collectively expressed as nitrogen dioxide emissions.
- ~~(11)~~(13) TUNING means adjusting, optimizing, rebalancing, or other similar operations to an electric generating Unit or an associated control device or as otherwise defined in the Permit to Operate. Tuning does not include normal operations to meet load fluctuations.
- ~~(12)~~(14) UNIT means any Linear Generator.

4-2

PR 1110.3 - 2

**PROPOSED CHANGES TO PR 1110.3-
CLEANWATER SOCIAL REDLINES 2/8/23**

Proposed Rule 1110.3 (Cont.)

(Adopted TBD)

~~(13)~~(15) VOLATILE ORGANIC COMPOUND (VOC) as defined in Rule 102 – Definition of Terms.

(d) Emission Limits

(1) An owner or operator of a Unit shall not operate it in a manner that exceeds the NO_x, CO, and VOC emission limits listed in Table 1: Concentration Limits for Linear Generators, pursuant to subdivision (f):

Table 1: Concentration Limits for Linear Generators

<u>Table 1A: Units Installed on and after [Date of Adoption]</u>			
Fuel Type	NO _x (ppmv) ¹	CO (ppmv) ¹	VOC (ppmv) ²
Natural Gas, Propane Gas, Hydrogen Gas, Landfill Gas, and <u>Digester Gas</u>	2.5	12	10
<u>Table 1B Interim Limits</u>			
<u>Digester Gas, or Dual Fuel</u> ³	<u>11</u>	<u>250</u>	<u>30</u>

4-3

¹ Parts per million by volume, corrected to 15% oxygen on a dry basis and averaged over 15 minutes.

² Parts per million by volume, measured as carbon, corrected to 15% oxygen on a dry basis, and averaged over the sampling time required by the test method.

³Table 1B Emission Limits shall continue to apply unless amended or otherwise superseded following a technology assessment referenced in Rule 1110.3 (d)(2).

(2) The concentration limits in Table 1A shall become effective for digester and dual fuel Units provided the Executive Officer conducts a technology assessment that confirms that the limits are achievable and reports to the Governing Board by July 2024, at a regularly scheduled public meeting. Interim concentration limits effective upon rule adoption are listed in Table 1B.

4-4

~~(2)~~(3) An owner or operator shall shut down a Unit having a Breakdown that results in emissions in excess of those allowed by Table 1 by the end of an Operating Cycle, or within 24 hours from the time the operator knew of the Breakdown or excess emissions, or reasonably should have known, whichever is sooner.

[PROPOSED CHANGES TO PR 1110.3-
CLEANWATER SOCAL REDLINES 2/8/23](#)

Proposed Rule 1110.3 (Cont.)**(Adopted TBD)**

- (e) Maintenance Requirements
- (1) An owner or operator of a Unit shall perform maintenance per manufacturer's recommendations as specified in the operating and maintenance manual.
 - (2) An owner or operator of a Unit shall keep a copy of the manufacturer's operating manual and make it available to South Coast AQMD upon request.
- (f) Source Testing
- (1) An owner or operator of a Unit shall conduct source testing for NOx, VOC reported as carbon, and CO concentrations (concentrations in ppm by volume, corrected to 15 percent oxygen on dry basis) at least once every two years from the date of the previous source test, no later than the last day of the calendar month that the test is due, or every 8,760 operating hours, whichever occurs first. The source test schedule may be changed under the following circumstances:
 - (A) An owner or operator of a Unit may elect to reduce the source test frequency to once every three years if the Unit has operated less than 2,000 hours since the last source test; and
 - (B) An owner or operator of a Unit that has not been operated before the date a source test is due, shall conduct a source test by the end of seven consecutive days or 15 cumulative days of resumed operation.
 - (2) An owner or operator of a Unit shall conduct the source test by using a contractor that is approved under the South Coast AQMD's Laboratory Approval Program (LAP) for the test methods specified in Table 2: Testing Methods, or any test methods approved by CARB and EPA, and authorized by the Executive Officer.

Table 2: Testing Methods

Pollutant	Method
NOx	South Coast AQMD Method 100.1
CO	South Coast AQMD Method 100.1
VOC	South Coast AQMD Method 25.1* or Method 25.3*

*Excluding ethane and methane

- (3) An owner or operator of a Unit shall submit a source test protocol to the Executive Officer for written approval at least 60 days before the scheduled date of the test. The source test protocol shall include, but not limited to the following:
 - (A) Name, address, and phone number of the Unit operator and a South Coast

PR 1110.3 - 4

PROPOSED CHANGES TO PR 1110.3-
CLEANWATER SOCIAL REDLINES 2/8/23

Proposed Rule 1110.3 (Cont.)

(Adopted TBD)

- AQMD-approved source testing contractor that will conduct the test;
- (B) Application number(s), permit number(s), and emission limits;
 - (C) Description of the Unit(s) to be tested and the test methods and procedures to be used;
 - (D) Number of tests to be conducted and under what loads; and
 - (E) Required minimum sampling time for the VOC test, based on the analytical detection limit and expected VOC levels.
- (4) An owner or operator of a Unit shall conduct the testing after the receipt of source test protocol approval from the Executive Officer. If an owner or operator submits the protocol by the required date, and the Executive Officer takes longer than 60 days to approve the protocol, the owner or operator shall be allowed the additional time needed to conduct the test.
- (5) In lieu of meeting the requirements in paragraph (f)(3), an owner or operator of a Unit may elect not to submit a source test protocol for approval if:
- (A) There is a previously approved protocol for the Unit that meets the requirements in subparagraphs (f)(3)(A) through (f)(3)(E); and
 - (B) The Unit has not been altered in a manner that requires a permit modification.
- (6) An owner or operator of a Unit shall provide South Coast AQMD at least 30 days prior notice of any source test to afford South Coast AQMD the opportunity to have an observer present. If, after the 30 days prior notice is given, there is a delay (due to operational problems, etc.) in conducting the scheduled source test, the owner or operator of a Unit shall notify South Coast AQMD as soon as possible of any delay in the original test date, either by providing notice of the rescheduled date of the source test at least seven days prior, or by arranging a rescheduled date mutually agreed upon with South Coast AQMD.
- (7) An owner or operator of a Unit shall provide source testing facilities as follows:
- (A) Sampling ports adequate for the applicable test methods. This includes constructing the air pollution control system and stack or duct such that pollutant concentrations can be accurately determined by applicable test methods;
 - (B) Safe sampling platform(s), scaffolding or mechanical lifts, including safe access, that comply with California General Safety Orders; and
 - (C) Utilities for sampling and testing equipment.
- (8) The LAP contractor shall conduct source testing for at least 30 minutes during

PR 1110.3 - 5

PROPOSED CHANGES TO PR 1110.3-
CLEANWATER SOCAL REDLINES 2/8/23

Proposed Rule 1110.3 (Cont.)

(Adopted TBD)

normal operation (actual duty cycle). This test shall not be conducted under a steady-state condition unless it is the normal operation. In addition, the LAP contractor shall conduct source testing for NO_x and CO emissions for at least 15 minutes at: a Unit's actual peak load, or the maximum load that can be practically achieved during the test, and at actual minimum load, excluding idle, or the minimum load that can be practically achieved during the test. These additional two tests are not required if the permit limits the Unit to operating at one defined load $\pm 10\%$. The LAP contractor shall not conduct any pre-tests for compliance. If an emission exceedance is found during any of the three phases of the test, that phase shall be completed and reported. An operator shall correct the exceedance, and the source test may be immediately resumed.

- (9) The LAP contractor shall conduct the source test at least 40 operating hours, or at least 1 week, after any Unit servicing or Tuning.
- (g) Monitoring, Recordkeeping, and Reporting
 - (1) Monitoring
 - (A) An owner or operator of a Unit shall maintain an operational non-resettable totalizing time meter to determine the elapsed Unit operating time.
 - (B) An owner or operator of a Unit shall maintain a calibrated electric meter that measures the net electrical output of the Unit, which is the difference between the electrical output and the electricity consumed by the auxiliary equipment necessary to operate the Unit.
 - (C) An owner or operator of a Unit shall maintain a parametric monitoring system consisting of an air-to-fuel ratio controller (AFRC), an oxygen sensor, a fuel flow meter, and an air flow meter, which has a malfunction indicator light and audible alarm.
 - (D) An owner or operator of a Unit shall inspect, maintain, and replace all sensors and meters used by the parametric monitoring system per manufacturer's recommendations as specified in the operating manual.
 - (E) An owner or operator of a Unit shall develop and implement procedures for at least Daily monitoring and inspection of:
 - (i) fuel flow rate;
 - (ii) elapsed time meter operating hours;
 - (iii) AFRC system faults, alarms, and any other related emission control malfunctions; and
 - (iv) operating hours since the last source test required by subdivision (f).

PR 1110.3 - 6

[PROPOSED CHANGES TO PR 1110.3-
CLEANWATER SOCAL REDLINES 2/8/23](#)

Proposed Rule 1110.3 (Cont.)

(Adopted TBD)

- (2) Recordkeeping
- An owner or an operator of a Unit shall retain all data logs, source test reports, and other records required by this rule for at least five years and be made available to South Coast AQMD upon request.
- (A) The owner or operator of a Unit shall maintain records, on a monthly basis, for the following parameters(s) or item(s):
- (i) Total hours of operation;
 - (ii) Type of fuel and quantity of fuel consumption (cubic feet of gas);
 - (iii) Cumulative hours of operation since the last source test required in subdivision (f);
 - (iv) Megawatt-hours of electricity produced; and
 - (v) AFRC system faults, alarms, and any other related emission control malfunctions.
- (B) An owner or operator of a Unit shall keep records to demonstrate compliance with paragraphs (e)(1) and (f)(9).
- (C) An owner or operator of a Unit shall keep sufficient operating records to demonstrate that it meets the requirements for extension of the source testing deadlines, pursuant to paragraph (f)(1).
- (3) Reporting
- (A) The operator shall report to South Coast AQMD, by telephone (1-800 CUT-SMOG or 1-800-288-7664) or other Executive Officer approved method, any Breakdown resulting in emissions in excess of rule or permit emission limits within one hour of such noncompliance or within one hour of the time the operator knew or reasonably should have known of its occurrence. Such report shall identify the time, specific location, equipment involved, responsible party to contact for further information, and to the extent known, the causes of the noncompliance, and the estimated time for repairs. In the case of emergencies that prevent a person from reporting all required information within the one-hour limit, the Executive Officer may extend the time for the reporting of required information provided the operator has notified South Coast AQMD of the noncompliance within the one-hour limit.
- (B) Within seven calendar days after the reported Breakdown has been corrected, but no later than thirty calendar days from the initial date of the Breakdown, unless an extension has been approved in writing by the

PROPOSED CHANGES TO PR 1110.3-
CLEANWATER SOCIAL REDLINES 2/8/23

Proposed Rule 1110.3 (Cont.)

(Adopted TBD)

Executive Officer, the operator shall submit a written Breakdown report to South Coast AQMD which includes:

- (i) An identification of the equipment involved in causing, or suspected of having caused, or having been affected by the Breakdown;
 - (ii) The duration of the Breakdown;
 - (iii) The date of corrective action and information demonstrating that compliance is achieved;
 - (iv) An identification of the types of excess emissions, if any, resulting from the Breakdown;
 - (v) A quantification of the excess emissions, if any, resulting from the Breakdown and the basis used to quantify the emissions;
 - (vi) Information substantiating whether the Breakdown resulted from operator error, neglect or improper operation or maintenance procedures;
 - (vii) Information substantiating that steps were immediately taken to correct the condition causing the Breakdown, and to minimize the emissions, if any, resulting from the Breakdown;
 - (viii) A description of the corrective measures undertaken and/or to be undertaken to avoid such a Breakdown in the future; and
 - (ix) Pictures of any equipment which failed, if available.
- (C) An owner or operator of a Unit shall submit all source test reports, including a description of the equipment tested, to South Coast AQMD within 60 days of completion of the test.

Staff Responses to Email Comment #4*Response to Email Comment 4-1*

Staff updated the applicability of PR 1110.3 to only include natural gas fueled units, as staff has only received source test data for natural gas fired units. Please see Response to Email Comment 1-1. Rule amendments can be made in the future as more emission data for various fuels is available.

Response to Email Comment 4-2:

The proposed rule language is not necessary at this time, as the applicability of PR1110.3 was narrowed to natural gas fueled units. Please see Response to Email Comment 1-1.

Response to Email Comment 4-3:

Please see Response to Email Comment 4-2.

Response to Email Comment 4-4:

Please see Response to Email Comment 4-2.

Email Comment #5: Corrie Zuppo- Mainspring Energy, Incorporated

Attached are our minor staff report proposed updates.

Citation	Proposed Amended Language	Comments	
Executive Summary, Page EX-1, Paragraph 1	Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines is source-specific rule which applies to non-RECLAIM facilities and RECLAIM facilities with engines greater than 50 rated brake horsepower. The rule was last amended in 2019 to implement Control Measure CMB-05 of the Final 2016 Air Quality Management Plan. During the rule development process, linear generators were introduced as an alternative technology to reduce emissions and stakeholders commented on the unique characteristics of linear generators. Unlike traditional internal combustion engines (ICEs), linear generators produce electricity by driving magnets through copper coils in a linear motion. One unique feature of linear generators is that the combustion thermochemical reaction takes place at lower temperatures than traditional ICE, which results in lower emissions without add-on control devices (e.g., selective catalytic reduction). In addition, linear generators utilize a parametric monitoring system that monitors performance and controls emission levels. Linear generators are currently being used for prime power applications but can be used for emergency backup power to implement Control Measure L-CMB-04 of the Final 2022 Air Quality Management Plan. In response to stakeholder comments, Proposed Rule 1110.3 – Emissions from Linear Generators (PR 1110.3), is being developed to allow for specific considerations of the technology and capabilities of linear generators.	1. Linear Generators are not internal combustion engines. The use of the word "traditional" provides a comparison that is inaccurate. Therefore we are requesting removal of the word "traditional" from the staff report. 2. The reaction that takes place is a thermochemical reaction, not a combustion reaction. Please remove the word "combustion" wherever it is used to describe Linear Generator operation.	5-1
Chapter 1: Background, Page 1-1 Paragraph 2	Unlike traditional combustion engines, linear generators produce electricity by driving magnets through copper coils in a linear motion (Figure 1). In this reaction, a mixture of fuel and air are compressed, causing a chemical combustion reaction that drives the magnets through the copper coils. One of the features that makes linear generators unique is that this combustion-thermochemical reaction takes place in the "reaction zone" and occurs at lower temperatures than traditional engines, resulting in lower NOx and CO emissions. Linear generators also do not utilize add-on control technologies such as selective catalytic reduction (SCR) to control NOx emissions. Although they are equipped with an oxidation catalyst, they are not dependent on this catalyst to reach a destruction temperature and thus, start-up emissions are low. As a result of the lower combustion reaction temperatures of linear generators, the oxidation catalyst's ability to control VOC emissions is limited and its main function is to reduce CO emissions. In addition, linear generators utilize a parametric monitoring system to maintain fuel and air injection proper- combustion to meet energy demands. The parametric monitoring system works by monitoring and adjusting air and fuel flow to ensure proper air-to-fuel ratio is achieved, which also ensures emissions are under control. Finally, linear generators are also unique in that, based-on-stakeholder-comments , they have the ability to operate on different fuels without any hardware changes to the equipment.	1. Linear Generators are not internal combustion engines. The use of the word "traditional" provides a comparison that is inaccurate. Therefore we are requesting removal of the word "traditional" from the staff report. 2. The reaction that takes place is a thermochemical reaction, not a combustion reaction. Please remove the word "combustion" wherever it is used to describe Linear Generator operation. 3. Linear Generators do have the ability to operate on different fuels. This statement should not be tied to stakeholder comments	5-2
Chapter 2. Proposed Rule 1110.3, Subdivision (b) - Applicability, Page 2-1	PR 1110.3 applies to all linear generators, both portable and stationary, regardless of size and fuel-type fueled by natural gas, landfill gas, digester gas, or hydrogen, with the exception of those units exempt under Section (h) of Rule 1110.3.	Mainspring is requesting the rule specify the listed fuels. Additionally, Mainspring is recommending that the provisions of the rule not apply to linear generators certified under the California Air Resources Board Distributed Generation Certification Regulation.	5-3
Chapter 2. Proposed Rule 1110.3, Subdivision (c) - Definitions, Page 2-1	With input from stakeholders and South Coast AQMD engineering staff, this definition provides clarification and distinguishes linear generator technology from generators that utilize traditional -internal combustion engines to generate electricity	Linear Generators are not internal combustion engines. The use of the word "traditional" provides a comparison that is inaccurate. Therefore we are requesting removal of the word "traditional" from the staff report.	5-4
Chapter 2. Proposed Rule 1110.3, Subdivision (d) - Emission Limits, Page 2-1	Paragraph (d)(1) specifies emission limits in Table 1 of PR 1110.3 (Table 2 in Staff Report) and applies to all linear generators, both portable and stationary, regardless of size and fuel-type fueled by natural gas, landfill gas, digester gas, or hydrogen, with the exception of those units exempt under Section (h) of Rule 1110.3.	Mainspring is requesting the rule specify the listed fuels. Additionally, Mainspring is recommending that the provisions of the rule not apply to linear generators certified under the California Air Resources Board Distributed Generation Certification Regulation.	5-5
Chapter 2. Proposed Rule 1110.3, Subdivision (d) - Emission Limits, Page 2-2	The manufacturer also indicated that the oxidation catalyst contribution to VOC reductions were negligible due to the lower combustion temperatures, and VOC emissions are primarily controlled through the parametric monitoring system.	The reaction that takes place is a thermochemical reaction, not a combustion reaction. Please remove the word "combustion" wherever it is used to describe Linear Generator operation.	5-6
Chapter 2. Proposed Rule 1110.3, Subdivision (g) - Monitoring, Recordkeeping, and Reporting, Page 2-3	In addition, records to demonstrate compliance with other rule provisions are also required to be kept and maintained on-site for a period of 5 years and made available to the South Coast AQMD upon request for compliance verification	The Linear Generators are operated remotely. The rule language is written with that understanding, and states: <i>"An owner or operator of a Unit shall retain all data logs, source test reports, and other records required by this rule for at least five years and be made available to the Executive Officer upon request"</i> The staff report should be updated to reflect that there will be no requirement to keep the records on-site.	5-7
Chapter 2. Proposed Amended Rule 1110.2, Subdivision (c) - Definitions, Page 2-4	This definition was created with input from stakeholders and South Coast AQMD engineering staff, and provides clarification and distinguishes linear generator technology from engines that utilize traditional internal combustion engines to produce electricity	Linear Generators are not internal combustion engines. The use of the word "traditional" provides a comparison that is inaccurate. Therefore we are requesting removal of the word "traditional" from the staff report.	5-8
Chapter 3. Table 3-1, PR1110.3 Column	Table 1110.3	Update language based on feedback provided by Mainspring Energy to SCAQMD on 1/27/23, and included here as Attachment B	5-9

Staff Responses to Email Comment #5*Response to Email Comment 5-1:*

The staff report has been updated to reflect these corrections.

Response to Email Comment 5-2:

The staff report has been updated to reflect these corrections.

Response to Email Comment 5-3:

Please see Response to Email Comment 1-1.

Response to Email Comment 5-4:

The staff report has been updated to reflect these corrections.

Response to Email Comment 5-5:

Please see Response to Email Comment 1-1.

Response to Email Comment 5-6:

The staff report has been updated to reflect these corrections.

Response to Email Comment 5-7:

Staff has made the corrections as records may be maintained electronically at a remote location.

Response to Email Comment 5-8:

The staff report has been updated to reflect these corrections.

Response to Email Comment 5-9:

Please see Response to Email Comment 1-1.

Email Comment #6: Robert Benz- Benz Air Engineering Co

Hay Lo

From: Robert Benz <RBenz@benzaireng.com>
Sent: Sunday, March 19, 2023 2:59 PM
To: Michael Morris; hio1@aqmd.gov; Isabelle Shine; Sarah Rees; Michael Krause
Cc: Erwin dela Cruz; support+id15706@gobiz.zendesk.com; Jason Aspell; Wayne Nastri; Patrica Spiritus; Jason Aspell; Christian Aviles; cchron@aqmd.gov; Bahareh Farahani; mferandez@aqmd.gov; Shannon Lee; Tommy Mai; Kevin Orellana; Barbara Radlein; Bill Welch; michael@therechargeoasis.com; Mark Nair; Andrew Newman; Dietrich Hartmann; d.mac@omstaff.com; Shelby Benz; Shelby Benz
Subject: PR1110.3 - A Proposed Rule based on a Fictional Narrative.
Follow Up Flag: Follow up
Flag Status: Flagged

The fictional justification of Proposed Rule 1110.3 – Emissions from Linear Generators Proposed Amended Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines

Dear Mr. Morris and Fellow Staff of AQMD.

The proposed rule 1110.3 in its entirety serves no useful purpose other than to provide regulatory relief to one specific manufacturer. The central premise of the modification of 1110.2 and the proposed rule 1110.3 is predicated on a fiction that the linear generator is not a compression ignition engine – which in no uncertain terms categorically false. Based on nothing more than a sales brochure, the AQMD has been duped into believing that one specific linear generator is unlike internal combustion engines – in fact not an engine at all. The PR1110.3 and the accompanying PAR 1110.2 then defines the linear generator as using a “thermochemical reaction” which is the oxidation of fuel with oxygen in air, and defining all other engines in 1110.2 as one using either spark or compression ignition- the latter being precisely the ignition being used in the linear generator – a nonsense distinction without difference. The stakeholder posits that their technology is based on a mystical chemical reaction that is somehow “different” than the thermochemical oxidation reaction of fuel and air that occurs within the “reaction zone” of any spark ignited or compression ignited engine.

6-1

The linear generator deserves no special consideration and regulatory relief as prescribed by PR1110.3. Quite the contrary, a cursory review of the underlying combustion technology of the linear generator and the substantially complex control needed to maintain homogenous charge combustion ignition leaves little doubt that the technology requires more stringent monitoring. Unfortunately, the AQMD staff were erroneously led to believe by one stakeholder that the subject linear generator is different than any other engine, hence the reliance of only the stakeholder’s claims and no wonder. So far as I know, there simply isn’t any peer reviewed technical paper describing the stakeholder’s technology, the only mention of successful commercialization in a paper “Recent progress on performance and control of linear engine generator” <https://journals.sagepub.com/doi/full/10.1177/14680874221118014>. Interestingly, this paper describes the subject linear generator as “high compression ratio natural gas-powered ODP (Opposed piston dual power) LEG employs low-temperature combustion to achieve chemical to mechanical energy conversion, and the piston assembly motion is electrically controlled.”

6-2

A review of PR1110.3 reveals significant problems. Specifically,

1. As defined, “any power generation technology that uses a thermochemical reaction to create linear motion that is directly converted into electricity” includes all linear generators be they spark ignited, or compression ignition as all combustion processes are a “thermochemical reaction.”

6-3

2. PR1110.3 less frequent source testing (Rule 1110.2, paragraph (f)(1)) favors one manufacture over all others. The stakeholder’s claim that “performing the emissions checks required them to override their safety protocol in order to access the testing ports” is a red herring statement having no factual basis whatsoever. 6-4
3. Pooled testing - paragraph (f)(10) provides economic favoritism to one manufacturer over all other generator manufacturers and suppliers. Irrespective of Stakeholders concerns of cost or logistics, there is no logical reason supporting that source testing a third of a number of generators located a certain location or within a certain distance from another generator would somehow convey emission compliance. Likewise significantly increasing the time between periodic source testing from 2 years or 8760 hours, whichever occurs first to 5 years or 24000hours whichever comes first, grants one specific manufacturer a significant favor over all other manufacturers and suppliers of “thermochemical reaction” engine generators. As the Staff Draft Report makes abundantly clear, the linear generator is a new technology that has minimal collective run time hours compared with other engine generators. Therefore, allowing this particular manufacture of this new product less restrictive source testing requirements over the plethora of other engine generator manufacturers is without an reasonable explanation. 6-5
4. Amending PAR 1110.2 definition of “ENGINE is any spark- or compression-ignited internal combustion engine, including engines used for control of VOCs, but not including Linear Generators” is a distinction without a difference for the subject linear generator of PR1110.3 is a compression ignition engine. The linear generator subject to PR1110.3 is not some “new” type of chemistry rather a well-known and significantly researched combustion process called “homogeneous charge compression ignition.” 6-6

Disclosure, we are a company that provides a Combined Heat and Power system based on a reciprocating engine that is proven to yield over 90 percent net thermal efficiency. So its no wonder we are miffed to why the AQMD is providing special status to one particular engine manufacture. To be sure, the linear generator has received substantial funding in excess of \$800million. Nevertheless, we expect that air pollution regulations will be applied evenly regardless be it spark or compression ignition based technology. So please understand this special status afforded a technology that has no special benefits to either air pollution or efficiency indicates that the SCAQMD is picking favorites. Unfortunately, as the Staff Draft Report documents, these linear generators (otherwise known as engines) high single cycle efficiency have little or no waste heat to be otherwise used in combined heat and power application. Indeed, the particular stakeholder’s technology currently has no capability at all. So its little wonder the stakeholder seeks permitting relief for there is less of an economic advantage to their engine. 6-7

Background: The linear generator is an internal combustion engine that utilizes HCCI to operate during a portion of its duty cycle. For years, HCCI has been a holy grail for some prominent contemporary heat-engine research and development programs.
<http://www.engr.wisc.edu/news/archive/2009/Aug03.html> <http://magazine.sae.org/12aeid0403> <http://www.sae.org/mags/aei/6635> Yet, this feat had already been demonstrated in the early 1950’s before the term HCCI was coined when an undergraduate student in engineering at MIT constructed a simple free-piston internal combustion engine and operated it with HCCI.

The HCCI combustion process and consequences can be summarized as follows. HCCI shares characteristics with the two familiar combustion processes in common use in existing internal combustion engines. These processes are (1) homogeneous charge spark ignition (gasoline engines) and (2) heterogeneous charge compression ignition (diesel engines). As in (1), HCCI mixes the fuel and air together prior to ignition but it does not use an electric discharge (spark) to ignite a portion of the mixture and rely on that small flame to propagate into and inflame the bulk. Rather, in HCCI, the whole charge is inflamed at once by compressing the mixture sufficiently to raise its density and temperature until the entire flammable mass ignites spontaneously producing an avalanche of combustion reactions as in an explosion. Thus, HCCI resembles the diesel combustion process in that the charge is heated above the auto-ignition temperature of the fuel by compression. But that is where the similarity ends. In the diesel, the compressed charge consists solely of air with combustion occurring only in the wakes of the fuel droplets as they are injected in to the compression-heated air. In HCCI, the fuel and air are premixed and homogenized before they are compressed together until combustion occurs throughout the charge as a strictly vapor-phase reaction.

The defining characteristic of HCCI is simultaneous ignition at many places throughout a compressed and pre-mixed fuel-air charge. Such multi-point ignition makes the fuel-air mixture burn very rapidly. However, since there is no definite trigger for timing the combustion event (like in a spark or fuel pulse), the process is spontaneous, i.e. timed by circumstances. These circumstances are inherently challenging to control in an intermittent combustion engine cycle. Consequently, sophisticated microprocessors and instrumentation have been brought to bear to control the various parameters affecting the physics of the ignition process. When appropriate timing has been achieved, gasoline engine-like emissions with diesel engine-like thermal efficiencies are attained. HCCI engines have demonstrated extremely low levels of nitrogen oxides (NOX) and particulate matter (PM) emissions in the laboratory. However, the exhaust still contains products of incomplete combustion (unburned hydrocarbon and carbon monoxide) at levels comparable to gasoline engines. Advantages attributed to HCCI engine operation include the following:

- Lower emissions and fuel consumption.
- Reduced peak combustion temperatures for reduced NO_x formation.
- Leaner premixed charges avoid soot production.
- Compression-ignite and lean-burn various fuels without detonation including gasoline, diesel and most alternative fuels.
- Higher compression ratios and leaner mixtures without throttling improve thermal efficiency at partial loads.
- Simplified after-treatment of exhaust gases to reduce particulate and oxides of nitrogen emissions using catalytic oxidation only.

These accomplishments have given rise to expectations that the need for expensive and bulky exhaust gas after-treatment equipment (e.g. catalytic converter and particle filter) can be eliminated. But the residual combustion fragments will require oxidation catalysts to meet automotive emission regulations and the current Rule 1110.2. The HCCI mode of engine operation promises superior thermal single cycle efficiency and reduced emissions with cheaper fuels and without expensive fuel injection or ignition equipment. It perfects the more thermodynamically efficient Otto Cycle while enhancing the use of the simpler and safer distillate fuels without problematic spark ignition, direct ultra-high-pressure cylinder injection or loss-prone inlet throttling. That the stakeholder has perfected HCCI is impressive, but without any peer reviewed technical paper published by SAE or ASME, who knows?

Initially HCCI combustion is familiar only as a symptom of engine distress, such as that which occurs during severe overheating due to inadvertent coolant loss. Then, it is experienced as “run-on” after spark ignition has been turned off. The symptoms of noise, smoke and odor associated with this experience are hard to reconcile with recent laboratory results to the contrary. Schwartzman’s free-piston engine research at MIT is a rare example of deliberate HCCI engine operation <http://www.freepatentsonline.com/4860702.html>. But it is significant background for permitting because it demonstrated ignition control by compression ratio variation. The unrestrained travel of the free piston permitted compression to proceed on each stroke until ignition occurred. The attainment of whatever clearance volume or “reaction volume” as claimed in Staff Draft report, is required on each compression stroke to produce auto-ignition of the entire charge is a challenge for an engine that uses a fixed-center-of-rotation slider-crank mechanism having a fixed stroke. On the other hand, a mechanical output is a challenge for a free piston engine which apparently the stakeholder has developed. Again, what isn’t known to either the SCAQMD or anyone else for that matter, is technical peer review paper that verifies that result. The stakeholder has provided to the SCAQMD staff nothing but source tests which are point of time data without any peer reviewed paper to substantiate the leeway in permitting provided by PR1110.1. Given the challenge of the problem maintain HCCI there is simply no way SCAQMD Staff can conclude that the technology warrants such benefits as significantly long period between source testing.

6-8

To that point, HCCI combustion occurs in a sufficiently homogeneous mixture of vaporous fuel and air when conditions throughout the mixture are favorable for auto-ignition of the whole combustible charge at once, molecule by molecule. To produce such ignition and combustion repetitively with sufficient reliability for continuous internal combustion engine operation, “duds” and “bombs” must be avoided. HCCI operation occurs in the narrow region between misfire (“duds”) and detonation (“bombs”). This accomplishment requires a uniform charge with a prescribed composition after which it is necessary to control the reactivity of the charge from cycle to cycle. To be successful, an HCCI engine must obtain positive control of charge reactivity with sufficient effectiveness and transient response to

6-9

avoid these ignition failures altogether. It only takes one misfire to utterly defeat the best emission after-treatment system. And no engine endures for long with detonation in the combustion chamber. Regardless of the stakeholders claim of their “parametric monitoring system” to maintain the precise air fuel ratio, the extremely tight air fuel ratio control given the substantial transients of weather alone requires transmitters of high accuracy which simply is over the heads of most owners upon which PR1110.3 relies for compliance. Its simply absurd to assume owners of facilities to be sufficiently cognizant in analyzing whether the large data set of analog to digital transmitters having extremely high resolution to effectuate an extremely complex control of proper air fuel ratio needed of HCCI combustion based on multiple dependent variables.

6-9 cont’d.

Conclusion: PR1110.3 in its entirety is not needed. It serves no purpose other than granting regulatory relief without justification to one particular manufacturer.

6-10

Please provide the proper channels to put this on the next agenda in the hearing process involving PR1110.3 and PAR1110.2. Furthermore, I would like to copy all the commissioners and if need be provide a comprehensive technical presentation outlining the significant problems with PR1110.3. Obviously, I would welcome any questions the AQMD staff may have.

6-11

Very Respectfully,

Robert Benz PE
209-602-1019 cell
Benz Air Engineering Co
531 Cypress Ave
Hermosa Beach, CA 90254



Staff Responses to Email Comment #6*Response to Email Comment 6-1:*

Staff is currently aware of two linear generator manufacturers and PR 1110.3 will apply to both manufacturers, as well as any other manufacturers of the technology. While fuel and air are compressed in linear generators, there is no flame or burning, and the resulting chemical reaction drives magnets through copper coils in a linear motion to produce electricity. Therefore, linear generators have differences from internal combustion engines. In addition, linear generators are able to achieve near-zero NO_x emissions without the need for aftertreatment devices. Due to these unique characteristics, PR 1110.3 is being developed to allow for specific considerations of linear generator technology running solely on natural gas.

Response to Email Comment 6-2:

Please see response to Email Comment 6-1.

Response to Email Comment 6-3:

PR 1110.3 was developed through a public process and the definition of linear generator was developed with input from multiple stakeholders, including two different linear generator manufacturers.

Response to Email Comment 6-4:

Please see response to Email Comment 6-1.

Response to Email Comment 6-5:

Please see response to Email Comment 6-1.

Response to Email Comment 6-6:

Please see response to Email Comment 6-1. PR 1110.3 specifies requirements for linear generators and thus, the proposed amendments to Rule 1110.2 are necessary for the purpose of clarity and non-duplication.

Response to Email Comment 6-7:

Please see response to Email Comments 6-1.

Response to Email Comment 6-8:

Please see response to Email Comment 6-1. Staff established emission limits for natural gas fueled linear generations based on achieved in practice source test data. Technical peer reviewed papers of a technology are not a pre-requisite for South Coast AQMD to develop rules and regulations.

Response to Email Comment 6-9:

Although parametric monitoring is required in PR 1110.3, it is not relied upon for compliance determination for emission limits. PR 1110.3 requires periodic source testing to verify

compliance with emission limits. Additionally, PR 1110.3 contains requirements for diagnostic emission checks.

Response to Email Comment 6-10

Please see response to Email Comment 6-1.

Response to Email Comment 6-11:

PR 1110.3 and PAR 1110.2 are scheduled for a Set Hearing on October 6, 2023 and a Public Hearing on November 3, 2023. Public comments will be taken at both the Set Hearing and Public Hearing.

Comment Letters

Comment Letter #1: Steve Jepsen- Clean Water SoCal



February 8, 2023

Mr. Mike Morris, Planning and Rules Manager
South Coast Air Quality Management District
21865 Copley Drive
Diamond Bar, California 91765

Comments on Proposed Rule 1110.3 - Emissions from Linear Generators

Dear Mr. Morris:

Clean Water SoCal, formerly known as SCAP, represents over 80 public water/wastewater agencies in Southern California. Clean Water SoCal members provide essential water supply and wastewater treatment for approximately 20 million people in Los Angeles, Orange, San Diego, Santa Barbara, Riverside, San Bernardino, and Ventura counties. Clean Water SoCal's wastewater members provide environmentally sound, cost-effective management of more than two billion gallons of wastewater each day and, in the process, convert wastewater into resources for beneficial uses such as recycled water and renewable energy.

Clean Water SoCal appreciates the opportunity to provide comments on Proposed Rule 1110.3 - Emissions from Linear Generators (PR1110.3). While we understand the need to establish a source specific rule for linear generators, we remain concerned with the proposed emission limits for digester gas units (biogas) at wastewater facilities. In the absence of completed demonstration projects to verify the viability of the technology on biogas, we're concerned that the proposed emission limits in PR1110.3 will preclude wastewater facilities from pursuing this new technology using biogas. Our members are always seeking opportunities to beneficially use biogas at wastewater facilities in a way that utilizes sustainable and best available technologies, and we are encouraged by this new emerging technology. However, it should be demonstrated in practice while using biogas prior to establishing stringent emission limits in a source specific rule. Until such time, we believe that it is appropriate to adopt Rule 1179.1 biogas engine limits to biogas fueled linear generators.

1-1

Attached for your review and consideration please find proposed redline changes to PR1110.3. The proposed revisions essentially apply Rule 1179.1 biogas engine limits to biogas fueled linear generators until a technology demonstration on biogas units is complete.

1-2

P.O Box 231565
Encinitas, CA 92024

email: info@scap1.org
phone: 760.415.4332



We appreciate you considering our comments and would be happy to meet to discuss in more detail. If there are any questions or concerns regarding this transmittal, please contact:

Alison Torres, Clean Water SoCal Air Quality Committee Co-Vice Chair torresa@emwd.org, or

David Rothbart, Clean Water SoCal Air Quality Committee Chair drothbart@lacsdsd.org

Sincerely,

Steve Jepsen

A handwritten signature in blue ink that reads "Steve Jepsen". The signature is fluid and cursive, with the first name being more prominent.

Executive Director – Clean Water SoCal

Cc:

Hay Lo, hlo1@aqmd.gov

Isabelle Shine, ishine@aqmd.gov

P.O Box 231565
Encinitas, CA 92024

email: info@scap1.org
phone: 760.415.4332

Staff Response to Comment Letter #1:*Response to Comment Letter 1-1:*

Your concerns have been noted. Staff has decided to narrow the focus of the proposed rule to natural gas fueled linear generators at this time. Please see Response to Email Comment 4-1. Staff agrees that the achievability of meeting emission limits be demonstrated in practice before establishing emission limits in a rule. For this reason, we believe that it is also not appropriate to include Rule 1179.1 emission limits for biogas fueled linear generators.

Response to Comment Letter 1-2:

Please see responses to Email Comments 4-1 through 4-4.

Comment Letter #2: Chris Chavez- Coalition for Clean Air



March 1, 2023

Susan Rees, Deputy Executive Officer
 Michael Krause, Assistant Deputy Executive Officer
 South Coast Air Quality Management District
 1865 Copley Drive
 Diamond Bar, CA 91765

Re: Proposed Rule 1110.3

Dear Ms. Rees and Mr. Krause:

Coalition for Clean Air is writing in support of Proposed Rule 1110.3, which would streamline permitting requirements for linear generators. Establishing a supportive framework for emerging technologies, such as linear generators, creates opportunities to replace polluting generators with cleaner alternatives.

2-1

The South Coast Air Basin is the nation's smog capital, and diesel particulate matter is the number one air toxic contaminant in our air. Meanwhile, the number of diesel backup generators jumped by 22 percent from 2020 to 2021. Given concerns about grid reliability, increasingly severe summer and winter weather due to the climate crisis and the impacts of California's longstanding air quality crisis, we cannot continue to rely on diesel combustion. Linear generators, along with other low-emitting and zero-emissions technologies, can yield significant emission reductions while also providing the same functions as a diesel generator.

2-12

Though we support the deployment of clean end-use technologies, we urge SCAQMD to work with all stakeholders to promote the use of clean, renewable fuels. Additionally, we urge SCAQMD to work with potential customers to ensure the deployment of the cleanest available application-appropriate technology.

Thank you for your time and consideration of this important rule.

Sincerely,

A handwritten signature in black ink that reads "Chris Chavez".

Chris Chavez
 Deputy Policy Director

Cc:
 Mike Morris, Manager
 Hay Lo, Air Quality Specialist
 Isabelle Shine, Air Quality Specialist

Staff Response to Comment Letter #2:*Response to Comment Letter 2-1:*

PR 1110.3 was developed to allow for specific considerations of the technology and capabilities of linear generators. PR 1110.3 does not exempt linear generators from any permitting requirements. South Coast AQMD Rule 219 – Equipment Not Requiring a Written Permit Pursuant to Regulation II identifies equipment, processes, or operations that do not require a written permit.

Response to Comment Letter 2-2:

Staff appreciates support of PR 1110.3.

Comment Letter #3- Julia Levin- Bioenergy Association of California and Katrina M. Fritz- California Hydrogen Business Council



March 1, 2023

Wayne Natri, Executive Officer
South Coast Air Quality Management District
1865 Copley Drive
Diamond Bar, CA 91765

Re: Proposed Rule 1110.3

Dear Mr. Natri:

The Bioenergy Association of California (BAC) and the California Hydrogen Business Council (CHBC) are writing to commend South Coast Air Quality Management District (SCAQMD) for its development of Proposed Rule 1110.3 to streamline permitting requirements for linear generators.

3-1

Linear generators provide many air quality and emissions reduction benefits that are critical to SCAQMD’s mission. In addition to being fuel-flexible and fully dispatchable, linear generators have extremely low criteria pollutant emissions. In the SCAQMD, the number of diesel backup generators jumped by 22 percent from 2020 to 2021.¹ Linear generators can serve as a low emissions replacement for emissions-intensive diesel generation. Linear generators can also help reduce emissions in the marine ports by powering electric truck fleets using low and zero-carbon fuels, such as hydrogen.

3-12

While we understand and support SCAQMD’s need for sufficient data to ensure the safe operation of linear generators, we urge SCAQMD to remove any costly or onerous permitting and compliance requirements that discourage deployment of this clean technology. Doing so will risk slowing the installation of linear generators that can provide significant environmental benefits to the South Coast region.

3-23

Thank you for your time and consideration of this important rule.

¹ Steven Moss and Andy Bilich, M.Cubed, “Diesel Back-Up Generator Population Grows Rapidly in the Bay Area and Southern California” (2020). <https://bit.ly/34gOr0b>. BUGs have reached 7,360 MW of capacity in the South Coast AQMD and 4,840 MW of capacity in the Bay Area AQMD based on information for BAAQMD and SCAQMD. The report estimates an average capacity of 0.543 MW for units in SCAQMD and 0.628-0.642 MW for units in BAAQMD.

Sincerely,

/s/

Julia Levin, Executive Director, Bioenergy Association of California

Katrina M. Fritz, Executive Director, California Hydrogen Business Council

Cc:

Vanessa Delgado, Chair of the Board

Michael A. Cacciotti, Vice-Chair of the Board

Andrew Do, Board Member

Curt Hagman, Board Member

Gideon Kracov, Board Member

Larry McCallon, Board Member

Holly J. Mitchell, Board Member

Veronica Padilla-Campos, Board Member

V. Manuel Perez, Board Member

Nithya Raman, Board Member

Carlos Rodriguez, Board Member

Staff Response to Comment Letter #3:

Response to Comment Letter 3-1:

Please see response to Comment Letter 2-1.

Response to Comment Letter 3-2:

Staff appreciates support of PR 1110.3 and your concerns have been noted.

Response to Comment Letter 3-23:

South Coast AQMD Rule 219 – Equipment Not Requiring a Written Permit Pursuant to Regulation II identifies equipment, processes, or operations that do not require a written permit. Linear generators were evaluated during the rule development process for the April 7, 2023 amendment to Rule 219 and it was determined that linear generators would not be exempt from permitting requirements. PR 1110.3 includes a new source testing schedule to help alleviate compliance costs associated with source testing. Based on the new source testing schedule and an estimated cost of \$10,000 per source test, staff calculates the cost of source testing each unit to be approximately \$30,000 over a 15-year period. The new source test schedule translates to approximately 60% cost savings over the originally proposed source test frequency that units are currently subject to in Rule 1110.2. In addition, facilities with six or more identical units may elect to do pooled source testing further alleviating costs.

Comment Letter #4- Corrie Zuppo- Mainspring Energy, Inc.



Michael Krause
 Assistant Deputy Executive Officer
 Planning, Rule Development and Implementation
 South Coast Air Quality Management District
 21865 Copley Dr.
 Diamond Bar, CA 91765
MKrause@aqmd.gov

Proposed Rule 1110.3

Request for Rulemaking Delay to Reconsider Proposed Rule Language

Dear Mr. Krause,

At the South Coast Air Quality Management District (SCAQMD or District) Governing Board meeting held on March 3, 2023, District Staff proposed to set a public hearing for Proposed Rule (PR) 1110.3, Emissions from Linear Generators. The Staff's proposed language for PR1110.3 at the time of the Governing Board meeting included the following agreed exemptions for certified equipment:

- An exemption from PR1110.3 for linear generators which become certified under the California Air Resources Board (CARB) Distributed Generation Executive Order program, and
- An exemption from PR1110.3 source testing requirements for linear generators which become certified under a SCAQMD certification program.

4-1

4-2


These two pathways for certified equipment would result in regulatory treatment similar to other, comparably scaled distributed generation (DG) technologies (e.g., microturbines, fuel cells).

On the basis of the draft PR1110.3 language that was publicly available on March 3, Mainspring was supportive of the rule and provided such a public comment during the Governing Board meeting. Unfortunately, the rule language contained in the 30-day package released on March 7 did not include the above provisions.

Since those provisions are absolutely critical to ensuring that linear generators receive regulatory treatment equivalent to other low emissions distributed generation technologies, Mainspring respectfully urges SCAQMD to delay the PR1110.3 schedule for Governing Board consideration until the Staff and stakeholders can further consider options for CARB and SCAQMD pathways for linear generator certification.

Please feel free to contact me at corrie.zupo@mainspringenergy.com or (424) 241-8959 with any questions or comments.

Best regards,



Corrie Zupo

Environmental Manager Permitting & Compliance

*CC: Wayne Nastri, SCAQMD
Susan Nakamura, SCAQMD
Dr. Sarah Rees, SCAQMD
Michael Morris, SCAQMD
ClearkofBoard@aqmd.gov
Adam Simpson, Mainspring Energy, Inc.
Scott Weaver, Ramboll US Consulting*

4-3

Staff Response to Comment Letter #4:*Response to Comment Letter 4-1:*

Staff was informed by U.S. EPA that an exemption for CARB Distributed Generation certified units would not be acceptable for SIP approval, and thus, was removed from PR 1110.3.

Response to Comment Letter 4-2:

Staff cannot include this provision since a South Coast AQMD certification program has not been developed. Once developed, a South Coast AQMD certification program would need to be submitted to U.S. EPA for SIP approval.

Response to Comment Letter 4-3:

The Public Hearing for PR 1110.3 and PAR 1110.2 was delayed from April 7, 2023 to November 3, 2023.

Comment Letter #5: Chris Chavez- Coalition for Clean Air

October 23, 2023

The Honorable Vanessa Delgado
 Chair of the Governing Board
 South Coast Air Quality Management District
 1865 Copley Drive
 Diamond Bar, CA 91765

Re: Proposed Rule 1110.3 – Emissions from Linear Generators: SUPPORT

Dear Chair Delgado,

Coalition for Clean Air is writing in support of Proposed Rule 1110.3, relating to linear generators. This rule, along with previously passed rules, will both create a regulatory framework and streamline permitting requirements for linear generators.

5-1

Southern California must transition away from diesel combustion. The South Coast Air Basin is the smoggiest region in the country, and diesel particulate matter is the number one air toxic contaminant in our air. Yet, despite this the number of diesel backup generators jumped by 22% from 2020 to 2021 and 14 percent from 2021 to 2022. With our increasingly extreme summer and winter weather threatening grid reliability, we must look for alternatives to diesel generators.

Linear generators powered by clean fuels provide many air quality benefits that are critical to public health and SCAQMD's mission. In addition to being fuel-flexible and fully dispatchable, linear generators have extremely low criteria pollutant emissions. Linear generators can serve as a low-emissions replacement for emissions-intensive diesel generation as well as serve in other applications, such as marine ports by powering electric truck fleets and cargo handling equipment.

5-2

Just as we support the deployment of clean end-use technologies, we believe the cleanest available fuel must also be used. SCAQMD and other agencies should work with all stakeholders to promote the use of application-appropriate clean, renewable fuels for linear generators. We also support the district's commitment to introduce a District Certification program in the near future.

Thank you for your consideration of our comments.

Sincerely,



Chris Chavez
 Deputy Policy Director

Cc:
 SCAQMD Governing Board Members
 Wayne Nastri, SCAQMD Executive Officer

Staff Response to Comment Letter #5:

Response to Comment Letter 5-1:

Please see response to Comment Letter 2-1.

Response to Comment Letter 5-2:

Staff appreciates support of PR 1110.3.

Comment Letter #6- Marc Carrel- Breathe Southern California



BreatheSoCal.org

5858 Wilshire Blvd., Suite 300
Los Angeles, CA 90036
P: (323) 935-8050
F: (323) 935-1873

October 19, 2023

Wayne Nastri, Executive Officer
South Coast Air Quality Management District
1865 Copley Drive
Diamond Bar, CA 91765

Re: Proposed Rule 1110.3

Dear Mr. Nastri:

Breathe Southern California is writing to commend South Coast Air Quality Management District (SCAQMD) for its development of Proposed Rule 1110.3 to streamline permitting requirements for linear generators.

6-1

Linear generators provide many air quality and emissions reduction benefits that are critical to SCAQMD's mission. In addition to being fuel-flexible and fully dispatchable, linear generators have extremely low criteria pollutant emissions. In the SCAQMD, the number of diesel backup generators jumped by 14 percent from 2021 to 2022.¹ Linear generators can serve as a low-emissions replacement for emissions-intensive diesel generation. Linear generators can also help reduce emissions in the marine ports by powering electric truck fleets using low and zero-carbon fuels, such as hydrogen.

6-2

We appreciate that the Proposed Rule improves the permitting and compliance requirements for low-emitting linear generators. We also appreciate that the District is committing to continue to improve this Rule by introducing a District Certification program in the near future.

Thank you for your time and consideration of this important rule.

Sincerely,


Marc Carrel
President & CEO
Breathe Southern California

¹ Steven Moss and Andy Bilich, M.Cubed, "Back-up Generator Populations in Bay Area, South Coast Continue to Grow; San Diego Home to a Significant Number of Generators, Mostly Diesel- Power" (December, 2022). BUGs have reached 7,455 MW of capacity in the South Coast AQMD SCAQMD. Available at: <https://efiling.energy.ca.gov/GetDocument.aspx?tn=248863-2&DocumentContentId=83404>

Breathe Easier.™

Cc:

Vanessa Delgado, Chair of the Board
Michael A. Cacciotti, Vice-Chair of the Board
Andrew Do, Board Member
Curt Hagman, Board Member
Gideon Kracov, Board Member
Larry McCallon, Board Member
Holly J. Mitchell, Board Member
Veronica Padilla-Campos, Board Member
V. Manuel Perez, Board Member
Nithya Raman, Board Member
Carlos Rodriguez, Board Member

Staff Response to Comment Letter #6*Response to Comment Letter 6-1*

Please see response to Comment Letter 2-1.

Response to Comment Letter 6-2

Staff appreciates support of PR 1110.3. Please see response to Comment Letter 2-1.

ATTACHMENT I



**South Coast
Air Quality Management District**

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

SUBJECT: NOTICE OF EXEMPTION FROM THE CALIFORNIA ENVIRONMENTAL QUALITY ACT

PROJECT TITLE: PROPOSED RULE 1110.3 – EMISSIONS FROM LINEAR GENERATORS, AND PROPOSED AMENDED RULE 1110.2 – EMISSIONS FROM GASEOUS - AND LIQUID-FUELED ENGINES

Pursuant to the California Environmental Quality Act (CEQA) Guidelines, the South Coast Air Quality Management District (South Coast AQMD), as Lead Agency, has prepared a Notice of Exemption pursuant to CEQA Guidelines Section 15062 – Notice of Exemption for the project identified above.

If the proposed project is approved, the Notice of Exemption will be filed for posting with the County Clerks of Los Angeles, Orange, Riverside, and San Bernardino Counties. The Notice of Exemption will also be electronically filed with the State Clearinghouse of the Governor’s Office of Planning and Research for posting on their CEQAnet Web Portal, which may be accessed via the following weblink: <https://ceqanet.opr.ca.gov/search/recent>. In addition, the Notice of Exemption will be electronically posted on the South Coast AQMD’s webpage which can be accessed via the following weblink: <http://www.aqmd.gov/nav/about/public-notices/ceqa-notices/notices-of-exemption/noe---year-2023>.

**NOTICE OF EXEMPTION FROM THE
CALIFORNIA ENVIRONMENTAL QUALITY ACT (CEQA)**

To: County Clerks for the Counties of Los Angeles, Orange, Riverside and San Bernardino; and Governor's Office of Planning and Research – State Clearinghouse	From: South Coast Air Quality Management District 21865 Copley Drive Diamond Bar, CA 91765
--	---

Project Title: Proposed Rule 1110.3 – Emissions from Linear Generators, and Proposed Amended Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines

Project Location: The proposed project is located within the South Coast Air Quality Management District's (South Coast AQMD) jurisdiction, which includes the four-county South Coast Air Basin (all of Orange County and the non-desert portions of Los Angeles, Riverside, and San Bernardino counties), and the Riverside County portion of the Salton Sea Air Basin, and the non-Palo Verde, Riverside County portion of the Mojave Desert Air Basin.

Description of Nature, Purpose, and Beneficiaries of Project: The current version of Rule 1110.2 applies to facilities with engines greater than 50 rated brake horsepower; however, Rule 1110.2 also contains emission limits and other requirements applicable to linear generators. Unlike internal combustion engines (ICEs), linear generators produce electricity by driving magnets through copper coils in a linear motion and the thermochemical reaction takes place at lower temperatures than ICEs, which results in lower emissions without the need for add-on air pollution control devices. In order to have a rule with dedicated requirements specific to the technology and capabilities of linear generators, Proposed Rule 1110.3 (PR 1110.3) has been developed with updated emission limits and new provisions which incorporate existing requirements for linear generators from Rule 1110.2 into PR 1110.3. Specifically, PR 1110.3: 1) establishes the rule's applicability to include all linear generators fueled solely by natural gas; 2) defines linear generator and other terms to provide context and clarity; 3) establishes concentration-based emission-limits for nitrogen oxides (NOx), volatile organic compounds (VOC), and carbon monoxide (CO); and 4) establishes requirements for conducting maintenance, source testing, monitoring, reporting, and recordkeeping. PR 1110.3 also includes limited exemptions for: 1) laboratory units used for testing and research purposes; and 2) emergency standby units, units used for fire-fighting and flood control, or any other emergency unit approved by the Executive Officer which have permit conditions that limit operation(s) to 200 hours or less per year as determined by an operational non-resettable totalizing time meter. With requirements for linear generators established in PR 1110.3 in lieu of Rule 1110.2, Proposed Amended Rule 1110.2 (PAR 1110.2) contains changes that would: 1) remove all requirements applicable to linear generators; 2) provide clarifications to the definition of an engine; and 3) define linear generator for the purpose of exempting this technology from Rule 1110.2. By providing separate and distinct requirements for linear generators and engines in PR 1110.3 and PAR 1110.2, respectively, stakeholders will benefit from having improved clarity when implementing the applicable requirements.

Public Agency Approving Project:
South Coast Air Quality Management District

Agency Carrying Out Project:
South Coast Air Quality Management District

Exempt Status:
CEQA Guidelines Section 15061(b)(3) – Common Sense Exemption

NOTICE OF EXEMPTION FROM CEQA (concluded)

Reasons why project is exempt: South Coast AQMD, as Lead Agency, has reviewed the proposed project (PR 1110.3 and PAR 1110.2) pursuant to: 1) CEQA Guidelines Section 15002(k) – General Concepts, the three-step process for deciding which document to prepare for a project subject to CEQA; and 2) CEQA Guidelines Section 15061 – Review for Exemption, procedures for determining if a project is exempt from CEQA. The proposed project transfers existing requirements from Rule 1110.2 into PR 1110.3 and contains other revisions in PAR 1110.2 to improve clarity and enforceability, but without requiring physical modifications. Thus, it can be seen with certainty that implementing PR 1110.3 and PAR 1110.2 would not cause a significant adverse effect on the environment. Therefore, the proposed project is exempt from CEQA pursuant to CEQA Guidelines Section 15061(b)(3) – Common Sense Exemption.

Date When Project Will Be Considered for Approval (subject to change):

South Coast AQMD Governing Board Public Hearing: November 3, 2023

CEQA Contact Person: Farzaneh Khalaj, Ph.D.	Phone Number: (909) 396-3022	Email: fkhalaj@aqmd.gov	Fax: (909) 396-3982
---	--	---	-------------------------------

PR 1110.3 and PAR 1110.2 Contact Person: Hay Lo	Phone Number: (909) 396-2450	Email: hlo1@aqmd.gov	Fax: (909) 396-3982
---	--	---	-------------------------------

Date Received for Filing: _____

Signature: _____

(Signed and Dated Upon Board Approval)

Kevin Ni
Acting Program Supervisor, CEQA
Planning, Rule Development, and
Implementation

Proposed Rule 1110.3 – Emissions from Linear Generators and Proposed Amended Rule 1110.2 – Emissions from Gaseous- and Liquid- Fueled Engines

Board Meeting
November 3, 2023

Background

Proposed Rule 1110.3 – Emissions from Linear Generators will establish emission limits for linear generators, as well as provisions for source testing, monitoring, reporting, and recordkeeping

Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines (Rule 1110.2) regulates engines rated over 50 brake horsepower (bhp) and was last amended in 2019 where provisions and emission standards for linear generators were initially established

Proposed Amended Rule 1110.2 will remove provisions currently applicable to linear generators, which will be addressed in Proposed Rule 1110.3 due to the unique characteristics of the technology


Unique Characteristics of Linear Generators

Electricity Production via Electromagnetic Induction

- Magnets are driven through copper coils in a linear motion to produce electricity

Low Emissions Profile

- Lower reaction temperatures results in lower NOx and CO emissions
- Low NOx emissions achieved without add-on pollution control equipment
- No catalyst heating required, which results in low NOx levels at startup
- No ammonia slip, which results in lower PM levels



Overview of Proposed Changes

Proposed Amended Rule 1110.2 (PAR 1110.2)

- Defines Linear Generator
- Remove emission limits and provisions for linear generators
- Add exemption for linear generators

Proposed Rule 1110.3 (PR 1110.3)

- Applies to linear generators fueled solely by natural gas
- Establishes NO_x, VOC, and CO emission limits
- Includes source testing, monitoring, reporting, and recordkeeping requirements

Proposed Rule 1110.3

Emission Limits

Table 1: Concentration Limits for Linear Generators

**Units with a Permit to Operate Issued on or after
*[Date of Adoption]***

Fuel Type	NOx (ppmv) ¹	CO (ppmv) ¹	VOC (ppmv) ²
Natural Gas	2.5	12	10

¹ Parts per million by volume, corrected to 15% oxygen on a dry basis and averaged over 15 minutes.

² Parts per million by volume, measured as carbon, corrected to 15% oxygen on a dry basis, and averaged over the sampling time required by the test method.

- Emission limits mirror the requirements in Rule 1110.2 and are already achieved in practice

- Existing linear generators subject to VOC limit of 25 ppmv

- Upon rule adoption, all newly permitted units will be subject to concentration limits in Table 1

Other Proposed Provisions in PR 1110.3

Maintenance Requirements

- Inspect and maintain sensors, meters, and oxidation catalyst per manufacturer's requirements

Source Testing

- Conduct source testing every 5 years
- Pooled testing option for 6 or more units located at a single facility
 - Pooled testing conducted on one-third of units every 3 years

Monitoring


- Portable analyzer testing every 2 years
- Maintain ANSI C12.20 net output meter
- Parametric monitoring system

Recordkeeping and Reporting

Commitment to Develop Certification Program

Resolution directs staff to develop a South Coast AQMD certification program for linear generators

Initiate development of the certification program within 90 days of rule adoption



Initiate rule development process after finalizing a certification program*

Stakeholders support approach

*Certification program subject to U.S. EPA approval

Impacts and Key Issues

Costs

- PR 1110.3 and PAR 1110.2 will result in a cost savings to affected facilities
- No adverse socioeconomic impacts

Environmental Impacts

- No significant adverse environmental impacts are expected
- A Notice of Exemption from CEQA has been prepared

Key Issues

- Staff is not aware of any remaining key issues

Staff Recommendations

Adopt resolution:

- Determining that Proposed Rule 1110.3 and Proposed Amended Rule 1110.2 are exempt from the requirements of the California Environmental Quality Act
- Adopting Rule 1110.3 and Amending Rule 1110.2

