


Proposed Updates to BACT Guidelines

BACT Scientific Review Committee Meeting #1

June 24, 2021

Join Zoom Meeting https://scaqmd.zoom.us/j/94317405856 Meeting ID: 943 1740 5856 Call-in number: 1-669-900-6833



February 2021 Adopted LAER/BACT Guidelines

- > Administrative changes to Table of Contents, Overview, Parts A, C, D, and E
- Part B, Major Polluting Facilities (LAER/BACT) Section I
 - Seven new & one updated listings
- Part C, Policy and Procedures: Non-major Polluting Facilities
 - Update maximum cost effectiveness criteria
- Part D, Non-Major Polluting Facilities (BACT)
 - Four new & three updated listings and clarifications/updates to existing listings

BACT Guidelines Update Process





Boiler, Fire-Tube, Natural Gas Fired <20 MMBTU/HR</p>

- Achieved In Practice Example (PTO: Apr. 2020)
 - Boiler with Low NOx Burner
 - Max Heat Input Rate: 8.4 MMBTU/HR
 - Boilers are used to heat up the process water to keep the bacterial culture used to ferment the ethanol at the optimal temperature.
- Emission Limits:

Emissions *	Current LAER Limit	Source Test	Proposed LAER Limit
NOx (ppmv)	12	5.7	7
CO (ppmv)	50	0.0**	50

* @ 3% O₂ dry

** @ Full load dry (below the detection limit)

- Source testing was performed in 2020
 - Method 100.1



- Rotary Dryer, Aggregate Facility
 - Achieved In Practice Example (PTO: Jan. 2017)
 - Low NOx Burner Gencor Equinox Natural Gas Fired Burner
 - Max Heat Input Rate: 135 MMBTU/HR
 - Rotary dryer is used to dry raw aggregate/recycled asphalt products and shingles
 - Emission Limits:

Emissions *	Current LAER Limit	Source Test	Proposed LAER Limit
NOx (ppmv)	33	29	33

* @ 3% O_2 on a dry basis

- Source test was performed in 2016
 - Method 100.1

Rotary Dryer, Aggregate Facility

- Achieved In Practice Example (PTO: Jan. 2017)
 - Low NOx Burner (ASTEC Natural Gas Fired Burner)
 - Max Heat Input Rate: 125 MMBTU/HR
 - Rotary dryer is used to dry gravel/asphalt/rubber
- Emission Limits:

Emissions *	Current LAER Limit	Source Test	Proposed LAER Limit
NOx (ppmv)	33	24.2	33

* @ 3% O_2 on a dry basis

- Relative Accuracy Test Audit was performed in 2017
 - Method 100.1





- Roller Coater Paper and Film, with RTO for VOC Control
 - Achieved In Practice Example (PTO: Dec. 2016)
 - Manufacturing process involves casting of a vinyl film and application of the adhesive on the film
 - Coatings are applied in PTEs for 100% collection, which are vented to RTO
 - Three flow coaters vented to RTO with permit requirement of 1500F minimum temperature and 95% overall control efficiency
 - Source test was performed in 2016
 - 98.9% control efficiency
 - Methods 25.1/25.3







South Coast AQMD

Part B- LAER/BACT Determination Section I: Proposed New Listing

- I.C. Engine– Stationary, Non-Emergency, Electrical and non-Electrical with SCR, NG Fired
 - Achieved In Practice Example (PTO: Aug. 2019)
 - Cogeneration unit, rated at 1,573 BHP
 - Lean Burn engine with SCR
 - Emission Limits:
 - Comply with Rule 1110.2 for NOX, CO and VOC
 - Ammonia limit: 10 ppm @ 15% O₂
 - Source test was performed in 2019
 - Method 100.1 for NOX and CO
 - Method 207.1 for ammonia slip





- Fumigation Methyl Bromide Fumigation Chamber ≥ 100,000 lb-CH3Br/year
 - Achieved In Practice Example (PTO: Feb. 2014)
 - San Luis Obispo County APCD
 - Using methyl bromide to fumigate vegetables/fruits prior to cooling and shipping
 - 86% overall control efficiency (Carbon Adsorption)
 - Source test was performed in 2013



BACT SRC Meeting, June 2021



- Achieved In Practice Examples:
 - Connecticut Department of Energy & Environmental Protection
 - 805 MW combined cycle power plant (PTO: Jun. 2019)
 - Massachusetts Department of Environmental Protection (MassDEP)
 - 692 MW combined cycle power plant (PTO: Jan. 2014)
- Combined cycle electric generation facility
- Source Test results showing compliance with emission limits
- Emission Limits:
 - NOx limit: 2 ppmvd @ 15% O₂

Emissions *	Current LAER Limit	Proposed LAER Limit
NH ₃ (ppmv)	5	2

* @ 15% O_2 on a dry basis



South Coast AQMD

► I.C. Engine- Stationary, Emergency, ≥ 1,000 BHP

- Bay Area AQMD has established a BACT guideline for large diesel engines used for emergency standby power that requires them to meet the U.S. EPA's Tier 4 emissions standards
- Achieved In Practice Example: MWH Data Center, Quincy, WA (2019)
 - 3.0 MW, 1.5 MW and 1 MW diesel engines
- Source Test (3 engines)
 - Showing emission limits compliance for the 1 MW and 3 MW engines (2020)
 - 1.5 MW engine currently being retested for low load and expect results in June 2021



BACT SRC Meeting, June 2021

Part D- BACT Determination Proposed New Listing

- I.C. Engine-Stationary, Non-Emergency, Electrical and non-Electrical with SCR, NG Fired
 - Achieved In Practice Example (PTO: Aug. 2019)
 - Cogeneration unit, rated at 1,573 BHP
 - Lean Burn engine with SCR
 - Emission Limits:
 - Comply with Rule 1110.2 for NOX, CO and VOC
 - Ammonia limit: 10 ppm @ 15% O₂
 - Source test was performed in 2019
 - Method 100.1 for NOX, CO and VOC
 - Method 207.1 for ammonia slip





Part D- BACT Determination Proposed New Listing I.C. Engine – Stationary, Non-Emergency, Electrical and non-Electrical with SCR, NG Fired Cost-effectiveness Evaluation {work in progress} Baseline: 20 ppm (based on 20 ppm ammonia slip limit on boiler SCR) Proposed ammonia slip BACT limit: 10 ppm Ammonium sulfate as precursor for PM to be used for cost effectiveness Urea NH₃ (slip) NO NH₃ NO₂ NO & NO₂ VOC PM CO SO₃ $(NH_3)_2SO_4$ CO₂ H_2O **Combustion** Catalyst emissions



Part D- BACT Determination Proposed New Listing

Cannabis Extraction/Processing (Butane/Propane Mixture)

- Achieved In Practice Examples:
 - Facility 1
 - Facility 2
- Source testing was performed on Facility 1
- Source testing on Facility 2 to be scheduled
- VOC Recovery Efficiency: ≥ 90% 95% {work in progress}
- Cost-effectiveness Evaluation {work in progress}





Other BACT Updates



Overview, Part A and Part C

- Staff is proposing to add a narrow BACT exemption for non-ozone precursor emission increases associated with air pollution control (APC) equipment installations to comply with NOx BARCT standards
- > Other air districts in California have a similar BACT exemption for sources that are complying with a BARCT requirement

BACT Exemption (PAR 1304)

(f)(1) Upon approval by the Executive Officer or designee, new or modified permit unit(s) to install add-on APC equipment for control of NOx emissions, shall be exempt from the BACT requirement of Rule 1303(a)(1) for any associated increase in PM_{10} and/or SOx emissions caused by the operation of the add-on APC equipment provided ...



- > Once PAR 1304 is adopted by the Board, BACT policy will be updated
- Update Maximum Cost Effectiveness values

Other BACT Updates



Updates for Consistency with Rules and Regulations

- Rules 1134, 1147, 1147.1, 1147.2, and 1304
- Reg XIII and XX
- Clarifications to Part D listings more user friendly
- **>** BACT Technical Assessment for Biogas Flares
 - Continue to monitor new/existing organic and food waste digestion and co-digestion flare projects for ammonia NOx impacts





Thank You.

Al Baez
Bahareh Farahani
909 396 2516
909 396 2353
abaez@aqmd.gov
bfarahani@aqmd.gov

www.aqmd.gov