

San Bernardino County, Fleet Management Department

Hearing Board Case #6070-9

Facility ID No. 161265 [San Sevain]

Regular Variance Conditions

May 18, 2023

1. Petitioner shall limit the operations of the emergency Internal Combustion Engine (ICE), Permit to Operate No. G4555 to emergency usage, and the ICE shall operate no more than 1.0 hour per month total for maintenance and testing time.
2. Petitioner shall maintain a monthly operating log for the emergency ICE and shall send the monthly records to South Coast AQMD by email to AQ Inspector III Kristina Crabtree (kcrabtree@aqmd.gov) on the first Tuesday of each month beginning in April 2023. The operating log shall list all engine operations in the following areas:
 - a. Date and hours of emergency operation, and specify the cause of the emergency;
 - b. Date and hours of maintenance and testing operations; and
 - c. Date and hours of any other non-emergency operation.
3. Petitioner shall calculate, record, and report all excess emissions during the variance period to the Clerk of the Board by January 30, 2024. The emission factors for calculating excess emissions are listed below:

CO: 0.19 lb/hr

NOx: 0.51 lb/hr

PM10: 0.03 lb/hr

RHC: 0.03 lb/hr

SOx: 0.001 lb/hr
4. Pursuant to South Coast AQMD Rule 303(p), all fees for this variance shall be waived.