

Los Angeles County - Internal Services Dept. (Johnson Peak Microwave Site)

Hearing Board Case # 6127-6

Facility ID No. 69307

Regular Variance Conditions

March 29, 2023

1. Petitioner shall limit the operation of the Internal Combustion Engine (“ICE”), as described in Permits to Operate (“PO”) R-F24077, to emergency usage, and the ICE shall operate no more than 1.0 hour per month total for maintenance and testing time.
2. Petitioner shall maintain a monthly operating log for the emergency ICE and shall send the records to the South Coast AQMD by email to AQ Inspector II Jason Leong (jleong@aqmd.gov) on the first Tuesday of each month starting in April 2023 for the prior month. The operating log shall list all engine operations in the following areas:
 - a. Date and hours of emergency operation, and specify the cause of the emergency;
 - b. Date and hours of maintenance and testing operations; and
 - c. Date and hours of any other non-emergency operation.
3. Petitioner shall calculate, record, and report all excess emissions during the variance period, and pay appropriate excess emission fees to the Clerk of the Board by the 30th of each month, starting April 30, 2023, for the prior month. Petitioner may exclude any hours the ICE is operated for Public Safety Power Shutoff (“PSPS”) events as defined by Rule 118.1. provided that Petitioner complies with the notification requirements of Rule 118.1(e).
4. Except as otherwise permitted in variance condition #1, Petitioner shall cease operation of the ICE (PO R-F24077) after the ICE has reached 200 hours of engine operating run-time.