

AQ-SPEC

Air Quality Sensor Performance Evaluation Center

Sensor Description

Manufacturer/Model:

Air Quality Egg/
2018 Model

Pollutants:

PM_{1.0}, PM_{2.5} and PM₁₀ mass concentration

Measurement Range:

0 - 1000 µg/m³

Type: Optical



Additional Information

Field evaluation report:

<http://www.aqmd.gov/aq-spec/evaluations/field>

Lab evaluation report:

<http://www.aqmd.gov/aq-spec/evaluations/laboratory>

AQ-SPEC website:

<http://www.aqmd.gov/aq-spec>

Evaluation Summary

- Overall, the Air Quality Egg 2018 Model sensors showed low to high accuracy, compared to the reference instrument for PM_{1.0} and PM_{2.5}, for a conc. range between 0 to 300 µg/m³. Accuracy increased as PM_{2.5} concentration increased.
- The Air Quality Egg 2018 Model sensors exhibited high precision for all T/RH combinations and all PM concentrations.
- The Air Quality Egg 2018 Model sensors (IDs: 0111, 0121 and 0122) showed low intra-model variability.
- Data recovery was ~100% from all units in both the field and in the laboratory
- For PM_{1.0} and PM_{2.5}, the Air Quality Egg 2018 Model sensors showed strong correlations with GRIMM (PM_{1.0} R² > 0.86) and moderate to strong correlations with the FEM BAM and FEM GRIMM from the field (PM_{2.5} R² > 0.57 and PM_{2.5} R² > 0.84, respectively) and very strong correlations with GRIMM in the laboratory studies (PM_{1.0} R² > 0.99 and PM_{2.5} R² > 0.99).



Field Evaluation Highlights

- Deployment period 04/25/2018 - 06/26/2018: the three Air Quality Egg 2018 Model sensors showed moderate to strong correlations with the PM_{1.0} and PM_{2.5} mass concentration as monitored by the reference instruments BAM and GRIMM. PM₁₀ mass conc. showed very weak correlations with the corresponding GRIMM and BAM data
- The units showed good data recovery and very low intra-model variability.

PM_{1.0}: 0.86 < R² < 0.88

PM_{2.5}: 0.57 < R² < 0.86

PM₁₀: 0.11 < R² < 0.14



Coefficient of Determination (R²)

quantifies how the three sensors followed the PM_{2.5} concentration change by FEM.

An R² approaching the value of 1 reflects a near perfect agreement, whereas a value of 0 indicates a complete lack of correlation.

Laboratory Evaluation Highlights


Accuracy (PM_{2.5})

$$A (\%) = 100 - \frac{|\bar{X} - \bar{R}|}{\bar{R}} * 100$$


Steady state #	Sensor Mean (µg/m ³)	FEM GRIMM (µg/m ³)	Accuracy (%)
1	15.5	9.9	43.6
2	23.5	14.2	34.2
3	49.1	43.4	86.9
4	132.6	132.1	99.6
5	259.6	267.4	97.1

Accuracy was evaluated by a concentration ramping experiment at 20 °C and 40%. The sensor's readings at each ramping steady state are compared to the reference instrument.

A negative % means sensors' overestimation by more than two fold. The higher the positive value (close to 100%), the higher the sensor's accuracy.




Precision (PM_{2.5})



Sensor's ability to generate precise measurements of PM_{2.5} concentration at low, medium, and high pollutant levels were evaluated under 9 combinations of T and RH, including extreme weather conditions like cold and dry (5 °C and 15%) cold and humid (5 °C and 65%), hot and humid (35 °C and 65%), or hot and dry (35 °C and 15%).

Coefficient of Determination



The Air Quality Egg 2018 Model sensors showed very strong correlations with the corresponding FEM PM_{2.5} data ($R^2 > 0.99$) at 20 °C and 40% RH.

For conc. ramping experiments of PM_{1.0}, please see the lab report.

Climate Susceptibility

From the laboratory studies, temperature and relative humidity had minimal effect on the Air Quality Egg 2018 Model sensor performance.

Observed Interferents

N/A

All documents, reports, data, and other information provided in this document are for informational use only. Mention of trade names or commercial products does not constitute endorsement or recommendation. As a Government Agency, the South Coast AQMD and its AQ-SPEC program highly recommend interested entities to make use and purchase decisions based on the requirements of their study design, the technical aspects and features of their specific project applications.