## SENT VIA USPS AND E-MAIL:

October 11, 2013

Oliver.Netburn@lacity.org

Mr. Oliver Netburn, Project Planner City of Los Angeles 200 N. Spring Street, 7<sup>th</sup> Floor Los Angeles, CA 90012

## <u>Draft Mitigated Negative Declaration (Draft MND) for the Proposed Installation, Operation</u> and Maintenance of a Rooftop Wireless Telecom Facility at 7685 Foothill Boulevard (ENV-2013-1902-MND)

The South Coast Air Quality Management District (SCAQMD) staff appreciates the opportunity to comment on the above-mentioned document both as a commenting agency and a responsible agency. The following comments are meant as guidance for the Lead Agency and should be incorporated into the Final Mitigated Negative Declaration.

In the Draft Mitigated Negative Declaration's (Draft MND) project description, the lead agency proposes to install, operate and maintain a rooftop telecommunications facility. In the project description, the lead agency includes the use of a stationary generator that could possibly use diesel fuel. Because of the proximity of the proposed generator to sensitive receptors, i.e., residences located approximately less than 25 feet from the proposed project site and the size of the generator, the generator may require permits from the SCAQMD in accordance with SCAQMD Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Initial Engines. Permit questions should be directed to Engineering and Compliance Staff at (909) 396-2315.

Please provide the SCAQMD with written responses to all comments contained herein prior to the adoption of the Final MND. The SCAQMD staff is available to work with the Lead Agency to address these issues and any other air quality questions that may arise. Please contact Gordon Mize, Air Quality Specialist – CEQA Section, at (909) 396-3302, if you have any questions regarding these comments.

a V. M. mill

Sincerely,

Ian MacMillan

Program Supervisor, Inter-Governmental Review Planning, Rule Development & Area Sources

IM:RC:GM

LAC130925-09 Control Number