



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

SOURCE TEST REPORT

17-339, 17-341 and 17-343

CONDUCTED AT

Weber Metals
16706 Garfield Avenue
Paramount, CA 90723

HEXAVALENT CHROMIUM
EMISSIONS FROM
FURNACES NOS. 337 AND 339, AND PRESS AREA

TESTED: June 1 and July 13, 2017

ISSUED: September 1, 2017

REPORTED BY: Jason Aspell
Senior Air Quality Engineer

REVIEWED BY:

A handwritten signature in blue ink, appearing to read "Michael Garibay". The signature is written over a horizontal line.

Michael Garibay
Supervising Air Quality Engineer

SOURCE TEST ENGINEERING BRANCH

MONITORING & ANALYSIS DIVISION

Cleaning the air that we breathe...

TABLE OF CONTENTS

| <u>SECTION</u> | <u>PAGE</u> |
|--|--------------------|
| SUMMARY | 4 |
| RESULTS | |
| <i>Table 1: Hexavalent Chromium Emissions</i> | 5 |
| <i>Table 2: Furnace 337 Refractory Total Chromium</i> | 5 |
| <i>Table 3: Ambient Air Monitoring Data</i> | 6 |
| <i>Table 4: Mass Emission Rates</i> | 6 |
| <i>Executive Summary</i> | 7 |
| INTRODUCTION | 8 |
| EQUIPMENT & PROCESS DESCRIPTION | 9 |
| <i>Table 5: List of Permitted Furnaces</i> | 9 |
| SAMPLING AND ANALYTICAL PROCEDURES | |
| <i>Hexavalent Chromium Sampling (CARB Method 425)</i> | 10 |
| <i>Integrated Gas Sampling and Analysis</i> | 11 |
| <i>EPA Method 19</i> | 11 |
| DISCUSSION/TEST CRITIQUE | 12 |
| FIGURES | |
| 1) <i>Facility and Ambient Monitor Locations</i> | 14 |
| 2) <i>Location of Process Equipment and Source Testing</i> | 15 |
| 3) <i>CARB Method 425 Train Diagram</i> | 16 |
| 4) <i>SCAQMD Method 10.1</i> | 17 |
| CALCULATIONS | 18 |
| APPENDICES | 25 |
| <i>Appendix A: Compliance Staff Data</i> | 26 |
| <i>Appendix B: Field Data</i> | 29 |
| <i>Appendix C: District Laboratory Data</i> | 42 |
| <i>Appendix D: Discarded Field and Lab Data</i> | 63 |
| <i>Appendix E: Equipment Calibrations</i> | 69 |
| <i>Appendix F: Furnace Permits</i> | 76 |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-3-

Date: 6/1/2017 and 7/13/2017

SUMMARY

- a. Firm Weber Metals, Inc

- b. Test Location 16706 Garfield Avenue,
Paramount, CA 90723

- c. Units Tested Furnaces #337 and # 339, and Press Area

- d. Test Requested by Matt Miyasato PhD, Deputy Executive Officer
SCAQMD, (909) 396-3249

- e. Reason for Test Request..... High ambient air monitor readings of Cr (VI)

- f. Date of Tests June 1, 2017 and July 13, 2017

- g. Source Tests Performed by Jason Aspell, Wayne Stredwick
Bill Welch, Eric Padilla

- h. Test Arrangements Made
Through..... Doug McIntyre (Vice President)
Weber Metals, Inc (562) 602-0260 ext. 259

- i. Source Tests Observed by..... Queen Uchekwe, Weber Metals, Inc.
Malinda Miller, Weber Metals, Inc.
Erik Pearson, Ramboll-Environ

- j. Company I.D. No. 10966

- k. Permit No. Permit No. G40157 (Furnace No. 337)
Permit No. G40158 (Furnace No. 339)

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-4-

Date(s): 6/1/2017 and 7/13/2017

RESULTS

Summary of Test Conditions:

On June 1, 2017, the exhaust of Furnace No. 337 was source tested, in addition to an ambient air sample taken in the area of three presses in operation. High levels of hexavalent chromium were measured from Furnace No. 337. A subsequent source test was conducted on July 13, 2017 on the two exhaust stacks of Furnace No. 339, which showed low hexavalent chromium emissions. During the source tests, both Furnace No. 337 and No. 339 were preheating titanium billets at an operating temperature of 1725-1746°F. The results of the source tests and are presented in Table 1 below. As with previous source testing efforts at other facilities in Paramount, hexavalent chromium emissions have shown to be highly variable from furnace to furnace.

Furnace No. 337 is a rotary type furnace that contains an internal 26 ft. diameter stainless steel table to rotate parts horizontally through the furnace. Although the titanium parts processed were not expected to have significant amounts of chromium, the stainless steel rotating table is a potentially large source of chromium. In addition, during a previous source test visit on May 11, 2017, SCAQMD Compliance staff detected high levels of chromium in the refractory inside Furnace 337 with a handheld X-Ray Fluorescence (XRF) analyzer (Table 2). These components may also contribute to the hexavalent chromium emissions. Due to the nature and configuration of the process, testing was performed as a screening test, non-isokinetically.

Furnace No. 339 is similar in operation to Furnace No. 337 in regards to titanium parts processed and operating temperature, except that Furnace No. 339 does not have the stainless steel rotary table. The furnace refractory is still considered a potential hexavalent chromium source. Information requests regarding the refractory were not answered by the facility.

Seven ambient air monitors are located in close proximity to the facility. Table 3 contains nearby ambient air monitor results for the four ambient sampling days preceding the test dates.

Both furnaces have dedicated natural gas meters and readings were taken during the sampling. EPA Method 19 calculations were used to obtain exhaust flow rates and mass emission rates from the natural gas readings (Table 4). Since Furnace 339 has two exhaust stacks, the exhaust flow rate was assumed equal between the exhaust stacks based on data obtained from SCAQMD Source Test ID PR14194.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-5-

Date(s): 6/1/2017 and 7/13/2017

Results:

Table 1. Hexavalent Chromium Emission Concentrations

| Emissions Source | Date | Concentration (ng/m ³)* |
|------------------------------|---------|--|
| Furnace No. 337 | 6/1/17 | 24,500 |
| Ambient - Furnace/Press Area | 6/1/17 | 10.3 |
| Furnace No. 339- West Stack | 7/13/17 | non-detect |
| East Stack | 7/13/17 | 7.04 |

* Concentrations reported in the same units as the ambient air monitoring data in Table 3

Table 2. Furnace No 337 SCAQMD XRF Total Chromium Measurements* (May 12, 2017)

| Location | Concentration (ppm) |
|--|------------------------|
| Refractory on furnace doorway floor | 818 ± 28 |
| Brick on furnace doorway ceiling | 2910 ± 45 |
| Ceramic fiber insulation wall inside furnace | 5007 ± 60 |
| Burner tunnel refractory | 3468 ± 47 |

* Qualitative readings taken by A.Q. Inspector A. Soltani. For further information refer to in Appendix A

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-6-

Date(s): 6/1/2017 and 7/13/2017

**Table 3. Ambient Air Monitoring Data
for Hexavalent Chromium (ng/m³)***

| Date | Monitor No. | | | | | | |
|---------|-------------|------|------|---------|------|-----------------|-----------------|
| | 19 | 21 | 23 | 24 | 27 | 31 ⁺ | 32 ⁺ |
| 5/22/17 | 1.31 | 0.28 | 1.44 | Invalid | 1.23 | - | - |
| 5/25/17 | 0.90 | 0.68 | 1.09 | 1.76 | 0.78 | - | - |
| 5/28/17 | 0.08 | 0.32 | 0.10 | 0.10 | 2.31 | - | - |
| 5/31/17 | 0.3 | 0.7 | 1.43 | 0.67 | 1.09 | - | - |
| 7/3/17 | 0.14 | 0.14 | 2.90 | 0.43 | 0.23 | 2.07 | 0.21 |
| 7/6/17 | 0.94 | 0.36 | 0.84 | 1.54 | 0.25 | 0.41 | 0.88 |
| 7/9/17 | 1.25 | 1.87 | 0.22 | 1.75 | 0.62 | 3.44 | 3.21 |
| 7/12/17 | 2.87 | 1.26 | 0.86 | 2.90 | 7.66 | 1.41 | 2.99 |

* SCAQMD Multiple Air Toxics Exposure Study (MATES IV) background levels of hexavalent chromium are about 0.06 ng/m³.

+ Monitor was not operational until June 2017.

Table 4. Hexavalent Chromium Mass Emission Rates (U.S. EPA Method 19)

| | Furnace No. 337 | Furnace No. 339 | | |
|---|-------------------------|-------------------------|-------------------------|-------------------------|
| | | West Stack ⁺ | East Stack ⁺ | Total |
| Natural gas usage (corrected)*, cfh | 1,434 | - | - | 1,422 |
| O ₂ ,% | 10.0 | 3.5 | 0.8 | - |
| Exhaust Flow Rate, dscfm | 419 | 121 | 121 | 242 |
| Cr ⁺⁶ Mass Emission Rate (lb/hr) | 3.84 x 10 ⁻⁵ | 3.19 x 10 ⁻⁹ | 0 | 3.19 x 10 ⁻⁹ |

* Readings and calculations are located in Calculations section.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-7-

Date(s): 6/1/2017 and 7/13/2017

EXECUTIVE SUMMARY

Source testing was conducted to screen for emissions at Weber Metals to identify the specific causes of recent elevated ambient hexavalent chromium levels measured near to the facility. Furnace No. 337 and ambient air in the press area were tested on June 1, 2017, and Furnace No. 339 was tested on July 13, 2017, to determine if they were potential sources of the elevated ambient readings.

Notably, the hexavalent chromium emissions from Furnace No. 337 were 10,400 times the highest, recent ambient air monitoring reading prior to the test. The ambient concentrations at ground level in the press area were 4.4 times the highest, recent ambient air monitoring reading. Since the furnace was processing titanium parts, the hexavalent chromium emissions are potentially generated from the internal furnace components (e.g. refractory or stainless steel table). A similar furnace design was issued a Permit to Construct (Appl. No. 572372) in the facility's Title V Facility Permit and further investigation and testing is warranted prior to the issuance of a Permit to Operate.

Furnace No. 339 is similar to Furnace No. 337, and processes titanium at a temperature greater than 1700°F, however Furnace No. 339 does not have an internal rotary table and resulted in very low hexavalent chromium emissions. These test results cannot positively identify the internal furnace components that contribute to the emissions; however, the results do positively identify Furnace No. 337 as a high emitter of hexavalent chromium.

There was a high amount of particulate emissions generated from the press operations during the source testing visits as indicated by visual observation. High opacity visible emissions drifted upwards due to the convection currents and were observed to be consistently exiting the roof vent. The testing of the ambient air did not capture a good representation of these emissions because the majority of them drifted upwards towards the roof vent away from the ground level sampling. Source Test staff also observed these visible emissions at Weber Metals in the past while at neighboring facilities. Higher hexavalent chromium concentrations might be detected at the roof vent.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-8-

Date(s): 6/1/2017 and 7/13/2017

INTRODUCTION

On June 1, 2017, Engineers from the South Coast Air Quality Management District (SCAQMD) Source Test Engineering (STE) branch conducted source testing at Weber Metals, Inc. in Paramount, California. The purpose of the testing was to identify the specific causes of elevated ambient hexavalent chromium levels measured very near to the facility. The locations of these monitors are shown in Figure 1.

Previously, during a May 12, 2017 visit to the facility, SCAQMD Compliance staff detected the presence of chromium in the Furnace 337 refractory and insulation with a handheld XRF analyzer. (Table 2 and Appendix A). In addition, STE staff requested to perform ambient air sampling in the press area for two hours during the visit, but were not given sufficient time by the facility to perform adequate sampling to obtain a good representation of emissions in the press area. Therefore, the sampling results from May 12, 2017 were not valid, and sampling over a longer period was performed on June 1, 2017. The field data sheets from May 12, 2017 may be found in Appendix D.

Based on the information provided by SCAQMD Compliance staff, Furnace 337 was chosen to be source tested, in addition to sampling the ambient air near the presses for an appropriate sampling period of two hours. Furnace 337 was processing titanium parts during sampling. The closest press was processing aluminum, and the two further presses were processing titanium.

Sources whose emissions are screened as greater than that of the nearby ambient air monitors are considered potential contributors to the hexavalent chromium measured by the ambient air monitor, with those exhibiting the greater concentrations more positively identified as contributors.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-9-

Date(s): 6/1/2017 and 7/13/2017

EQUIPMENT AND PROCESS DESCRIPTION

Weber Metals, Inc. forges aluminum and titanium parts with open die (hand forging) and close die (die forging). In aluminum forging operation, stock is preheated to 750 deg. F before being shaped under pressure in the presses. For titanium forging operations, the stock is preheated to 1750 deg. F prior to being shaped in the presses to meet specific product parameters. Grinding is carried out to remove imperfections and to finish the product cycle.

Furnaces and presses are arranged so that heated parts may be removed at their appropriate temperature and shaped in an expedient manner. Testing was performed on one of the titanium furnaces and the ambient air near the furnaces and presses. The furnace tested, Furnace No. 337, currently operates under a Permit to Operate No. G40157. Weber also has Permits to Construct for an Abrasive Blasting Operation, an Aluminum Pre-Heat Furnace, two steel die furnaces and a second larger rotary furnace (Application No. 572372), that is yet to be constructed. A press was also installed recently but is exempt under SCAQMD permit requirements. The titanium furnace is a rotary furnace design rated at 12 MMBtu/hr that has a circular stainless steel table that rotates titanium parts through the furnace during preheating. A list of the permitted furnaces at this facility is provided in Table 5 below as provided by the current SCAQMD permit engineer.

Table 5. List of Permitted Furnaces

| Application No. | Permit No. | Equipment Description | Rating | Used for: |
|-----------------|------------|---|---------------|-------------------|
| 569424 | G40161 | Lindberg chain pre-heat furnace | 3 MMBtu/hr | Aluminum Billets |
| 572370 | | Chain conveyor preheat furnace | 13 MMBtu/hr | Aluminum Billets |
| 572372 | | Rotary pre-heat furnace | 22 MMBtu/hr | Titanium Billets |
| 572373 | | Pedestal die heating furnace #1 | 8 MMBtu/hr | Steel Dies |
| 572374 | | Pedestal die heating furnace #2 | 8 MMBtu/hr | Steel Dies |
| 580275 | | Nutec bickley pre-heat furnace (OVE-340) | 4 MMBtu/hr | Steel Dies |
| 580276 | G40154 | No. 1 box pre-heat furnace | 6.4 MMBtu/hr | Al. & Ti. Billets |
| 580277 | G40156 | No. 2 box pre-heat furnace | 6.4 MMBtu/hr | Al. & Ti. Billets |
| 580278 | G40157 | Rotary hearth pre-heat furnace (OVE-337) * | 12 MMBtu/hr | Titanium Billets |
| 580279 | G40158 | Thorpe technology pre-heat furnace (OVE-339)* | 8.54 MMBtu/hr | Al. & Ti. Billets |
| 580280 | G40155 | No. 2 car bottom pre-heat furnace | 10 MMBtu/hr | Steel Dies |
| 580282 | G40160 | Aov pedestal pre-heat furnace | 4 MMBtu/hr | Steel Dies |
| 580283 | G40162 | A & A pre-heat furnace | 4 MMBtu/hr | Titanium Billets |

*Units source tested

SAMPLING AND ANALYTICAL PROCEDURES

Three sampling trains were utilized during testing. Train #40 was used for the testing of Furnace No. 337, Train #39 was used for the press area, and Train #38 was used as a field blank sample.

Although the furnace had sampling ports, sampling was performed by placing the opening of the quartz sampling probe about one inch inside the port. The furnace was under positive pressure (+0.03) so emissions were able to be collected from the configuration. Because of the small profile of the sampling port compared to the sampling probe, the testing was performed non-isokinetically.

The press area is largely enclosed, with a roof ridge vent above and a large door on the north side of the building that is kept open during operations. The roof ridge vent is designed to allow hot air inside the building to vent to the atmosphere. An aerial photo of the furnace and ridge vent locations is shown in Figure 2.

Hexavalent Chromium Sampling

Testing was conducted based on California Air Resources Board Method 425 applied to the furnace exhaust and the press area, with the procedures of the method specific to stack sampling omitted. Two samples were taken at single non-isokinetic sample points as described above for informational purposes. A third sampling train was used as a blank. Each sampling train consisted of a sampling line, which was used to draw the stack sample from the source. The furnace sample used a quartz probe and nozzle. The sample was then drawn through two impingers each filled with an aqueous solution of 0.1N NaHCO₃ (per Section 21.2), an empty impinger, a 2" filter, and an impinger bubbler filled with tared silica gel. Each sampling train was connected to a vacuum pump, a dry gas meter, and a calibrated orifice. The sampling apparatus was checked for leaks before and after sampling. The impingers were contained in an ice bath to condense water vapor and other condensable matter present in the sample stream (see Figure 3).

The samples were extracted using the sampling trains. The pH of the solution in the first impinger was measured after the test, but prior to recovery, at pH of at least 9 (the method requires a pH of 8.0 or higher). The impinger solutions were recovered within 24 hours and the SCAQMD laboratory analyzed the hexavalent chromium in the samples by CARB Method 425 and SCAQMD SOP 0046. Hexavalent chromium deposited in the filter, sample line and impingers were extracted and analyzed by an Ion Chromatograph equipped with a post-column reactor (IC/PCR) and a visible wavelength detector. Moisture content was determined gravimetrically and volumetrically. At the request of Weber, portions of the liquids extracted

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-11-

Date(s): 6/1/2017 and 7/13/2017

from the samples were provided for duplicate analyses. The duplicate analyses are not included in this test report.

Integrated Gas Sampling and Analysis

An integrated gas sample was collected from the exhaust stack during testing. The gas sampling apparatus consisted of a stainless steel probe, a Teflon line, and a 6-liter summa canister (Figure 4).

The samples were analyzed by the SCAQMD laboratory for carbon dioxide and oxygen. The gases were separated by gas chromatography. The carbon dioxide was determined by a gas chromatograph with a nickel catalyzed methanizer and flame ionization detector (GC/Ni-FID). Oxygen was analyzed by thermal conductivity.

EPA Method 19

Furnace No. 337 was equipped with a dedicated natural gas meter as required by permit conditions. Gas meter readings were recorded during the sampling period to determine the volume of natural gas combusted in the furnace during the test. The formulas in EPA Method 19 were used to derive post-combustion flow rate where diluent measurements are made, the exhaust is analyzed for oxygen, and fuel consumption is measured and recorded. Calculation of the emission flow rate using this procedure requires a test-specific F-factor and Btu value of the fuel being combusted, in this instance natural gas. Utilizing the Higher Heating Values and F_d-factors for natural gas, the exhaust rate was able to be determined. The exhaust rate was used with the measured concentrations to calculate emissions rates.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-12-

Date(s): 6/1/2017 and 7/13/2017

DISCUSSION/TEST CRITIQUE

For purposes of interpreting the test results, the background level of hexavalent chromium during the most recent SCAQMD Multiple Air Toxics Exposure Study (MATES) IV study was about 0.06 ng/m^3 . While the results are substantially higher than the background, it should be noted that it takes a significant volume of air at source concentrations substantially higher than the background to affect the ambient air levels. Ambient air levels measured at the monitors are also a function of distance away from the facility, due to air dilution, deposition, and meteorology. The intent of this test was to identify sources that are at least several times higher than the background levels to identify potential emissions sources and to provide a focus for potential remediation.

The highest ambient concentration adjacent to the facility was 2.31 ng/m^3 on 5/28/17 just a few days prior to the 6/1/17 test, as compared to the measured source concentrations from the facility, which were $24,500 \text{ ng/m}^3$ and 10.2 ng/m^3 for the Furnace No. 337 exhaust stack and the press area, respectively.

Furnace No. 337, as of the time of this report issue date, has the highest emission concentration of all furnaces tested by SCAQMD, and vents its emissions through roof vents that are upwind (prevailing southwest wind direction) from SCAQMD Monitoring Stations #19, 31, and others with elevated readings. The overall conclusion of this report is that elevated source concentrations from the Furnace No. 337 indicate that this furnace is emitting significant hexavalent chromium emissions into the atmosphere. Modeling of the reported hexavalent chromium emissions rate ($3.84 \times 10^{-5} \text{ lb/hr}$) is recommended to more specifically quantify the significance for contribution to the nearby ambient monitoring readings and health risk to the surrounding area.

Despite the use of the single run screening approach, the use of an isokinetic and full triplicate test is not expected to change this conclusion due to the magnitude of emissions source increase over the ambient levels versus any potential variability in using a single run which is minimal. Additionally, the isokinetics were above 100%, which can only cause a low bias in the measured emissions assuring that the reported emissions are at least those that were reported.

The press area sample was diluted by incoming fresh air from a west-facing roll up door. Because of this, the press area sampling was not able to measure the undiluted emissions from the presses. The press results although not nearly as high as the furnace results, may actually be higher when sampled at a location above or closer to the presses.

Regardless of the hexavalent chromium emissions, a large amount of visible particulate matter (PM) emissions was observed from the presses. The PM emissions were caused by the use of water-based graphite containing die lubricants that were sprayed on the heated parts and dies

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-13-

Date(s): 6/1/2017 and 7/13/2017

from the furnaces during the press phase of the forging operation. When sprayed onto the hot dies and parts, the heat from the dies and parts was observed to vaporize and/or partially combust the die lubricant creating visible PM emissions. The PM emissions were then observed to exit the forging building ridge vent. These visible emissions can be seen emitting from the ridge vent to intermittently and to varying degrees from outside the facility. As opposed to the furnace emissions, this report was inconclusive on whether the PM from the die lubricants is a significant contributor to the elevated ambient monitoring for hexavalent chromium.


During the furnace sampling, the sampling line (post impingers and filter) slipped off of the sampling train. For a period of a few seconds, air was pulled through by the pump through the dry gas meter, but not through the impingers and filter. The air volume was minimal and is not expected to impact the results of the test. In addition, since the air did not flow through the sampling train for these few seconds, the results would be biased low by a minimal amount. The silica impinger broke during leak testing of the field blank, so moisture gain could not be analyzed for the field blank. This also is not expected to significantly affect the results of the source test.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-14-

Date(s): 6/1/2017 and 7/13/2017



 SCAQMD Ambient Air Monitors

 Approximate location of SCAQMD Source Testing on June 1, 2017 and July 13, 2017 (further detailed in Figure 2)


Figure 1: Facility and Ambient Monitor Locations

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-15-

Date(s): 6/1/2017 and 7/13/2017



-  Press
-  Furnace No. 337
-  Furnace No. 339 (East and West Exhaust Stacks)
-  SCAQMD Sampling Points

Figure 2: Location of Process Equipment and SCAQMD Source Testing

Test Nos. 17-339, 17-341 and 17-343

-16-

Date(s): 6/1/2017 and 7/13/2017




Figure 3: CARB Method 425 Train Diagram

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-17-

Date(s): 6/1/2017 and 7/13/2017




Figure 4: SCAQMD Method 10.1

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-18-

Date(s): 6/1/2017 and 7/13/2017

CALCULATIONS

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-19-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, California 91765-4182

Test No. 2

Test Date: 6/1/17

SOURCE TEST CALCULATIONS

Sampling Location: **Weber Metals-Ambient Air- Press Area**
Sample Train: **39** Input by: **J. Aspell**

SUMMARY

| | | |
|--|-------------------|--|
| A. Average Traverse Velocity..... | | fps |
| A1. Average Traverse Vertical Velocity..... | | fps |
| B. Gas Meter Temperature (Use 60 deg.F for Temp Comp. Meters)..... | 98.76923 | deg F |
| C. Gas Meter Correction Factor..... | 1.0024 | |
| D. Average Orifice Pressure..... | 3.00 | "H ₂ O |
| E. Nozzle Diameter..... | | inch |
| | | |
| F1. Stack Diameter or Dimension #1..... | inch | M. Pitot Correction Factor..... 0.84 |
| F2. Stack Dim #2 (blank if circular)..... | inch | N. Sampling Time..... 60 min |
| G. Stack Cross Sect. Area..... | ft ² | O. Nozzle X-Sect. Area..... 0.00000 ft |
| H. Average Stack Temp..... | deg F | P. Net Cr ⁺⁶ Collection..... 0.00003 mg |
| I. Barometric Pressure..... | 30.28 "HgA | Q. Net Cr _T Collection..... 0.00016 mg |
| J. Gas Meter Pressure (I+(D/13.6)).... | 30.50 "HgA | R. Water Vapor Condensed..... 35 ml |
| K. Static Pressure..... | "H ₂ O | S. Gas Volume Metered..... 108.640 dcf |
| L. Total Stack Pressure (I+(K/13.6)).... | 30.28 "HgA | |

T. Corrected Gas Volume [(S x J/29.92) x 520/(460+B) x C]..... 103.311 dscf

PERCENT MOISTURE/GAS DENSITY

U. Percent Water Vapor in Gas Sample ((4.64 x R)/((0.0464 x R) + T))..... 1.55 %

V. Average Molecular Weight (Wet):

| Component | Vol. Fract. | x | Moist. Fract. | x | Molecular Wt. | = | Wt./Mole |
|-------------------|-------------|-----------|---------------|---|---------------|---|----------|
| Water | 0.015 | | 1.000 | | 18.0 | , | 0.28 |
| Carbon Dioxide | 0.000 | Dry Basis | 0.985 | | 44.0 | , | 0.02 |
| Carbon Monoxide | 0.000 | Dry Basis | 0.985 | | 28.0 | , | 0.00 |
| Oxygen | 0.209 | Dry Basis | 0.985 | | 32.0 | , | 6.58 |
| Nitrogen & Inerts | 0.791 | Dry Basis | 0.985 | | 28.2 | , | 21.95 |
| | | | | | , | | |
| | | | | | Sum | | 28.83 |

FLOW RATE

| | |
|--|----------|
| W. Gas Density Correction Factor (28.95/V) ^{0.5} | 1.00 |
| X. Velocity Pressure Correction Factor (29.92/L) ^{0.5} | 0.99 |
| Y. Corrected Velocity (A x M x W x X)..... | 0.00 fps |
| YY. Vertical Corrected Velocity (A1 x M x W x X)..... | 0.00 fps |
| Z. Flow Rate (Y x G x 60)..... | 0 cfm |
| ZZ. Vertical Flow Rate (YY x G x 60)..... | 0 cfm |
| AA. Flow Rate (Standard) {Z x (L/29.92) x [520/(460+H)]}..... | 0 scfm |
| AA1. Vertical Flow Rate (Standard) {ZZ x (L/29.92) x [520/(460+H)]}..... | 0 scfm |
| BB. Dry Flow Rate (AA x (U/100))..... | 0 dscfm |
| BB1. Vertical Dry Flow Rate (AA1 x (U/100))..... | 0 dscfm |

SAMPLE CONCENTRATION/EMISSION RATE

| | |
|--|----------------------------|
| CC. Sample Cr+6 Concentration [0.01543 x (P/T)]..... | 4.48E-09 gr/dscf |
| DD. Sample Cr+6 Concentration [54,1 51.996 (Molecular Wt.)]..... | 4.666E-06 ppm |
| EE. Sample Cr+6 Concentration [CCx 64798.9/0.0283168]..... | 1.03E-02 µg/m ³ |
| GG. Sample CrT Concentration [0.01543 x (Q/T)]..... | 2.39E-08 gr/dscf |
| HH. Sample CrT Concentration [54,14 51.996 (Molecular Wt.)]..... | 2.488E-05 ppm |
| II. Sample CrT Concentration [GG x (64798.9/0.0283168)]..... | 5.47E-02 µg/m ³ |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-20-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, California 91765-4182

Test No. 1

Test Date: 6/1/17

SOURCE TEST CALCULATIONS

Sampling Location: **Weber Metals-Furnace 337- Exhaust Stack**
Sample Train: **40** Input by: J. Aspell

SUMMARY

| | | |
|--|------------------------|--|
| A. Average Traverse Velocity..... | | fps |
| A1. Average Traverse Vertical Velocity..... | | fps |
| B. Gas Meter Temperature (Use 60 deg.F for Temp Comp. Meters)..... | 93.16667 | deg F |
| C. Gas Meter Correction Factor..... | 1.0051 | |
| D. Average Orifice Pressure..... | 1.70 | "H ₂ O |
| E. Nozzle Diameter..... | | inch |
| | | |
| F1. Stack Diameter or Dimension #1.. | inch | M. Pitot Correction Factor..... 0.84 |
| F2. Stack Dim #2 (blank if circular).... | inch | N. Sampling Time..... 120 min |
| G. Stack Cross Sect. Area..... | 0.000 ft ² | O. Nozzle X-Sect. Area..... 0.00000 ft |
| H. Average Stack Temp..... | deg F | P. Net Cr ⁺⁶ Collection..... 0.05452 mg |
| I. Barometric Pressure..... | 30.28 "HgA | Q. Net Cr _T Collection..... 0.48029 mg |
| J. Gas Meter Pressure (I+(D/13.6))... | 30.41 "HgA | R. Water Vapor Condensed..... 242 ml |
| K. Static Pressure..... | 0.03 "H ₂ O | S. Gas Volume Metered..... 81.984 dcf |
| L. Total Stack Pressure (I+(K/13.6))... | 30.28 "HgA | |

T. Corrected Gas Volume [(S x J/29.92) x 520/(460+B) x C]..... 78.717 dscf

PERCENT MOISTURE/GAS DENSITY

U. Percent Water Vapor in Gas Sample ((4.64 x R)/((0.0464 x R) + T))..... 12.48 %

V. Average Molecular Weight (Wet):

| Component | Vol. Fract. | x | Moist. Fract. | x | Molecular Wt. | = | Wt./Mole |
|-------------------|-------------|-----------|---------------|---|---------------|---|----------|
| Water | 0.125 | | 1.000 | | 18.0 | , | 2.25 |
| Carbon Dioxide | 0.057 | Dry Basis | 0.875 | | 44.0 | , | 2.19 |
| Carbon Monoxide | 0.000 | Dry Basis | 0.875 | | 28.0 | , | 0.00 |
| Oxygen | 0.100 | Dry Basis | 0.875 | | 32.0 | , | 2.80 |
| Nitrogen & Inerts | 0.843 | Dry Basis | 0.875 | | 28.2 | , | 20.80 |
| | | | | | Sum | | 28.05 |

FLOW RATE

| | |
|--|-----------|
| W. Gas Density Correction Factor (28.95/V) ^{0.5} | 1.02 |
| X. Velocity Pressure Correction Factor (29.92/L) ^{0.5} | 0.99 |
| Y. Corrected Velocity (A x M x W x X)..... | fps |
| YY. Vertical Corrected Velocity (A1 x M x W x X)..... | fps |
| Z. Flow Rate (Y x G x 60)..... | cfm |
| ZZ. Vertical Flow Rate (YY x G x 60)..... | cfm |
| AA. Flow Rate (Standard) {Z x (L/29.92) x [520/(460+H)]}..... | scfm |
| AA1. Vertical Flow Rate (Standard) {ZZ x (L/29.92) x [520/(460+H)]}..... | scfm |
| BB. Dry Flow Rate (AA x (U/100))..... | 419 dscfm |
| BB1. Vertical Dry Flow Rate (AA1 x (U/100))..... | 419 dscfm |

SAMPLE CONCENTRATION/EMISSION RATE

| | |
|--|----------------------------|
| CC. Sample Cr+6 Concentration [0.01543 x (P/T)]..... | 1.07E-05 gr/dscf |
| DD. Sample Cr+6 Concentration [54,1 51.996 (Molecular Wt.)]..... | 1.113E-02 ppm |
| EE. Sample Cr+6 Concentration [CCx 64798.9/0.0283168]..... | 2.45E+01 µg/m ³ |
| FF. Sample Emission Rate (0.00857 x BB1 x CC)..... | 3.84E-05 lb/hr |
| GG. Sample CrT Concentration [0.01543 x (Q/T)]..... | 9.41E-05 gr/dscf |
| HH. Sample CrT Concentration [54,14 51.996 (Molecular Wt.)]..... | 9.803E-02 ppm |
| II. Sample CrT Concentration [GG x (64798.9/0.0283168)]..... | 2.15E+02 µg/m ³ |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
 21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-21-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
 21865 Copley Dr. Diamond Bar, California 91765-4182

Test No. 1

Test Date: 7/13/17

SOURCE TEST CALCULATIONS

Sampling Location: **Weber Metals-Furnace 339- West Exhaust Stack**
 Sample Train: **15** Input by: **J. Aspell**

SUMMARY

| | | |
|--|----------|-------------------|
| A. Average Traverse Velocity..... | #DIV/0! | fps |
| A1. Average Traverse Vertical Velocity..... | #DIV/0! | fps |
| B. Gas Meter Temperature (Use 60 deg.F for Temp Comp. Meters)..... | 106.9375 | deg F |
| C. Gas Meter Correction Factor..... | 1.0024 | |
| D. Average Orifice Pressure..... | 2.86 | "H ₂ O |
| E. Nozzle Diameter..... | | inch |
| F1. Stack Diameter or Dimension #1..... | inch | |
| F2. Stack Dim #2 (blank if circular)..... | inch | |
| G. Stack Cross Sect. Area..... | 0.000 | ft ² |
| H. Average Stack Temp..... | deg F | |
| I. Barometric Pressure..... | 30.20 | "HgA |
| J. Gas Meter Pressure (H/(D/13.6))..... | 30.41 | "HgA |
| K. Static Pressure..... | -0.17 | "H ₂ O |
| L. Total Stack Pressure (H+(K/13.6))..... | 30.19 | "HgA |
| M. Pitot Correction Factor..... | 0.84 | |
| N. Sampling Time..... | 120 | min |
| O. Nozzle X-Sect. Area..... | 0.00000 | ft |
| P. Net Cr ⁺⁶ Collection..... | 0.00002 | mg |
| Q. Net Cr _T Collection..... | 0.0003 | mg |
| R. Water Vapor Condensed..... | 438.6 | ml |
| S. Gas Volume Metered..... | 107.416 | dcf |
| T. Corrected Gas Volume [(S x J/29.92) x 520/(460+B) x C]..... | 100.378 | dscf |

PERCENT MOISTURE/GAS DENSITY

U. Percent Water Vapor in Gas Sample ((4.64 x R)/((0.0464 x R) + T))..... 16.86 %

V. Average Molecular Weight (Wet):

| Component | Vol. Fract. | x | Moist. Fract. | x | Molecular Wt. | = | Wt./Mole |
|-------------------|-------------|-----------|---------------|---|---------------|---|----------|
| Water | 0.169 | | 1.000 | | 18.0 | , | 3.03 |
| Carbon Dioxide | 0.090 | Dry Basis | 0.831 | | 44.0 | , | 3.28 |
| Carbon Monoxide | 0.000 | Dry Basis | 0.831 | | 28.0 | , | 0.00 |
| Oxygen | 0.035 | Dry Basis | 0.831 | | 32.0 | , | 0.93 |
| Nitrogen & Inerts | 0.875 | Dry Basis | 0.831 | | 28.2 | , | 20.52 |
| | | | | | Sum | | 27.77 |

FLOW RATE

| | |
|--|--------------|
| W. Gas Density Correction Factor (28.95/V) ^{0.5} | 1.02 |
| X. Velocity Pressure Correction Factor (29.92/L) ^{0.5} | 1.00 |
| Y. Corrected Velocity (A x M x W x X)..... | #DIV/0! fps |
| YY. Vertical Corrected Velocity (A1 x M x W x X)..... | #DIV/0! fps |
| Z. Flow Rate (Y x G x 60)..... | #DIV/0! cfm |
| ZZ. Vertical Flow Rate (YY x G x 60)..... | #DIV/0! cfm |
| AA. Flow Rate (Standard) (Z x (L/29.92) x [520/(460+H)])..... | #DIV/0! scfm |
| AA1. Vertical Flow Rate (Standard) (ZZ x (L/29.92) x [520/(460+H)])..... | #DIV/0! scfm |
| BB. Dry Flow Rate (AA x (U/100))..... | 121 dscfm |
| BB1. Vertical Dry Flow Rate (AA1 x (U/100))..... | 121 dscfm |

SAMPLE CONCENTRATION/EMISSION RATE

| | | |
|--|-----------|-------------------|
| CC. Sample Cr+6 Concentration [0.01543 x (P/T)]..... | 3.07E-09 | gr/dscf |
| DD. Sample Cr+6 Concentration [54,143 51.996 (Molecular Wt.)]..... | 3.201E-06 | ppm |
| EE. Sample Cr+6 Concentration [CCx 64798.9/0.0283168]..... | 7.04E-03 | µg/m ³ |
| FF. Sample Emission Rate (0.00857 x BB1 x CC)..... | 3.19E-09 | lb/hr |
| GG. Sample CrT Concentration [0.01543 x (Q/T)]..... | 4.61E-08 | gr/dscf |
| HH. Sample CrT Concentration [54,143 51.996 (Molecular Wt.)]..... | 4.802E-05 | ppm |
| II. Sample CrT Concentration [GG x (64798.9/0.0283168)]..... | 1.06E-01 | µg/m ³ |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
 21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-22-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
 21865 Copley Dr. Diamond Bar, California 91765-4182

Test No. **2**

Test Date: **7/13/17**

SOURCE TEST CALCULATIONS

Sampling Location: **Weber Metals-Furnace 339- East Exhaust Stack**
 Sample Train: **5**

Input by: **J. Aspell**

SUMMARY

| | | | |
|--|---------|--|-------|
| A. Average Traverse Velocity..... | #DIV/0! | | fps |
| A1. Average Traverse Vertical Velocity..... | 0.00 | | fps |
| B. Gas Meter Temperature (Use 60 deg.F for Temp Comp. Meters)..... | 104.625 | | deg F |
| C. Gas Meter Correction Factor..... | 1.0051 | | |
| D. Average Orifice Pressure..... | 2.93 | | "Hz0 |
| E. Nozzle Diameter..... | | | inch |
| | | | |
| F1. Stack Diameter or Dimension #1..... | inch | | |
| F2. Stack Dim #2 (blank if circular)..... | inch | | |
| G. Stack Cross Sect. Area..... | 0.000 | | ft2 |
| H. Average Stack Temp..... | #DIV/0! | | deg F |
| I. Barometric Pressure..... | 30.20 | | "HgA |
| J. Gas Meter Pressure (H/(D/13.6))..... | 30.42 | | "HgA |
| K. Static Pressure..... | -0.17 | | "Hz0 |
| L. Total Stack Pressure (H/(K/13.6))..... | 30.19 | | "HgA |
| M. Pitot Correction Factor..... | 0.84 | | |
| N. Sampling Time..... | 120 | | min |
| O. Nozzle X-Sect. Area..... | 0.00000 | | ft |
| P. Net Cr ⁺⁶ Collection..... | 0 | | mg |
| Q. Net Cr _T Collection..... | 0.00032 | | mg |
| R. Water Vapor Condensed..... | 468.6 | | ml |
| S. Gas Volume Metered..... | 112.521 | | dcf |
| | | | |
| T. Corrected Gas Volume [(S x J/29.92) x 520/(460+B) x C..... | 105.880 | | dscf |

PERCENT MOISTURE/GAS DENSITY

U. Percent Water Vapor in Gas Sample ((4.64 x R)/((0.0464 x R) + T))..... 17.04 %

V. Average Molecular Weight (Wet):

| Component | Vol. Fract. | x | Moist. Fract. | x | Molecular Wt. | = | Wt./Mole |
|-------------------|-------------|-----------|---------------|---|---------------|---|----------|
| Water | 0.170 | | 1.000 | | 18.0 | , | 3.07 |
| Carbon Dioxide | 0.103 | Dry Basis | 0.830 | | 44.0 | , | 3.76 |
| Carbon Monoxide | 0.000 | Dry Basis | 0.830 | | 28.0 | , | 0.00 |
| Oxygen | 0.008 | Dry Basis | 0.830 | | 32.0 | , | 0.21 |
| Nitrogen & Inerts | 0.889 | Dry Basis | 0.830 | | 28.2 | , | 20.80 |
| | | | | | Sum | | 27.84 |

FLOW RATE

| | | | |
|--|---------|--|-------|
| W. Gas Density Correction Factor (28.95/V) ^{.5} | 1.02 | | |
| X. Velocity Pressure Correction Factor (29.92/L) ^{.5} | 1.00 | | |
| Y. Corrected Velocity (A x M x W x X)..... | #DIV/0! | | fps |
| YY. Vertical Corrected Velocity (A1 x M x W x X)..... | 0.00 | | fps |
| Z. Flow Rate (Y x G x 60)..... | #DIV/0! | | cfm |
| ZZ. Vertical Flow Rate (YY x G x 60)..... | 0 | | cfm |
| AA. Flow Rate (Standard) {Z x (L/29.92) x [520/(460+H)]}..... | #DIV/0! | | scfm |
| AA1. Vertical Flow Rate (Standard) {ZZ x (L/29.92) x [520/(460+H)]}..... | #DIV/0! | | scfm |
| BB. Dry Flow Rate (AA x (U/100))..... | 121 | | dscfm |
| BB1. Vertical Dry Flow Rate (AA1 x (U/100))..... | 121 | | dscfm |

SAMPLE CONCENTRATION/EMISSION RATE

| | | | |
|---|-----------|--|-------------------|
| CC. Sample Cr+6 Concentration [0.01543 x (P/T)]..... | 0.00E+00 | | gr/dscf |
| DD. Sample Cr+6 Concentration [54,14 x 51.996 (Molecular Wt.)]..... | 0.000E+00 | | ppm |
| EE. Sample Cr+6 Concentration [CC x 64798.9/0.0283168]..... | 0.00E+00 | | µg/m ³ |
| FF. Sample Emission Rate (0.00857 x BB1 x CC)..... | 0.00E+00 | | lb/hr |
| GG. Sample CrT Concentration [0.01543 x (Q/T)]..... | 4.66E-08 | | gr/dscf |
| HH. Sample CrT Concentration [54,14 x 51.996 (Molecular Wt.)]..... | 4.856E-05 | | ppm |
| II. Sample CrT Concentration [GG x (64798.9/0.0283168)]..... | 1.07E-01 | | µg/m ³ |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-23-

Date(s): 6/1/2017 and 7/13/2017

EPA Method 19

Exhaust Flow Rate (dscfm) = Gas Usage (scfm) x HHV / 1,000,000 x F_d x (20.9/(20.9-%O₂))

HHV, nat. gas: 1050 BTU/cu. ft.

F_d-factor, nat. gas: 8710 dscf/MMBtu

Furnace No. 337 - June 1, 2017

| Test Time | Gas Meter Reading, Cu. Ft. (uncorrected) |
|-----------|---|
| +0 | 3185700 |
| +30 | 3186200 |
| +60 | 3186500 |
| +90 | 3187000 |
| +120 | 3187300 |

Cu. Ft. Nat. Gas per Hour (uncorrected): 800 cfh

Pressure-Temperature Correction Factor (12 psig, 60°F): 1.792 (SCAQMD ST ID PR16359)

PR16359 is a source test conducted by Weber and submitted to SCAQMD from which the meter correction data was available.

Corrected Natural Gas Usage: 1433.6 scfh = 23.89 scfm

Stack O₂: 10.0%

Exhaust Flow Rate = 418.99 dscfm

Furnace No. 339 – July 13, 2017

| Test Time | Natural Gas Usage | | |
|-----------|---------------------------|-------------------------------------|-----------------------------------|
| | Process Control (scfh) | Gas Meter, Cu. Ft. (uncorrected) | Gas Meter, Cu. Ft. (corrected) |
| +0 | 1717 | 29,388,800 | 54,509,000 |
| +15 | 1574 | 29,389,000 | 54,509,000 |
| +30 | 1481 | 29,389,300 | 54,509,000 |
| +45 | 1488 | 29,389,400 | 54,510,000 |
| +60 | 1360 | 29,389,600 | 54,510,000 |
| +75 | 1335 | 29,389,800 | 54,510,000 |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-24-

Date(s): 6/1/2017 and 7/13/2017

| Test Time | Natural Gas Usage | | |
|-----------|---------------------------|-------------------------------------|-----------------------------------|
| | Process Control (scfh) | Gas Meter, Cu. Ft. (uncorrected) | Gas Meter, Cu. Ft. (corrected) |
| +90 | 1283 | 29,390,000 | 54,511,000 |
| +105 | 1311 | 29,390,100 | 54,511,000 |
| +120 | 1250 | 29,390,300 | 54,511,000 |
| AVG | 1,422.11 SCFH | | |

Corrected Natural Gas Usage: 1422.11 scfh = 23.70 scfm

Stack O₂: 2.2% (average of both exhaust stacks)

Exhaust Flow Rate (total both stacks) = 242.2 dscfm

Single stack exhaust rate = 121.1 dscfm

(ST ID 14194 shows exhaust flow between stacks are within 6% of each other. Source Test Engineering considers flow rates within 10% as the acceptable margin of error and the stack flow rates will be considered equal)

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-25-

Date(s): 6/1/2017 and 7/13/2017

APPENDICES

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-26-

Date(s): 6/1/2017 and 7/13/2017

APPENDIX A

SCAQMD Compliance Staff Data

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-27-

Date(s): 6/1/2017 and 7/13/2017

Jason Aspell

From: Eric Padilla
Sent: Friday, May 12, 2017 6:46 AM
To: Jason Aspell
Subject: FW: Weber Metals today

From: Areio Soltani
Sent: Thursday, May 11, 2017 5:32 PM
To: Garrett Kakishita <gkakashita@aqmd.gov>
Cc: John Anderson <janderson@aqmd.gov>; Amanda Sanders <asanders@aqmd.gov>; Jeffrey Lloyd <jlloyd@aqmd.gov>; Min Sue <msue@aqmd.gov>; Mike Garibay <MGaribay@aqmd.gov>; Eric Padilla <epadilla@aqmd.gov>; Wayne Stredwick <WStredwick@aqmd.gov>; Bill Welch <bwelch@aqmd.gov>
Subject: Weber Metals today

Garrett, et al.:

I wanted to give a quick summary of Compliance's activities at Weber Metals today 05/11/2017. Mike Garibay and his group were still onsite conducting testing when Min and I departed, so this is not a complete summary of all activity. Present onsite from SCAQMD were: Areio Soltani, Min Sue, Mike Garibay, Eric Padilla, Wayne Stredwick, Bill Welch. From Weber: Doug McIntyre, VP Plant Engineering; Jonathan Ayon, Manager Plant Engineering; Malinda Miller, Plant Engineer I; Jorge Pelayo, Lab Technician. From Ramboll Environ (Weber's consultant): Erik Person, Senior Manager.

We were granted access to 1 press and 1 furnace, both down since Monday for maintenance and repairs. The press was the "Mesta Press", manufactured by Mesta Pahnke and rated at 33k tons, used on both aluminum and titanium parts. A die was loaded in the press. We collected 2 bulk samples from around the press:

Sample #1 = loose debris colored black (pulverized metal scaling) and white (kitty litter); &
Sample #2 = fibrous fabric-looking debris.

We used the XRF on 2 locations, recording total Cr:

Horizontally on die itself = 354 PPM +/- 34 PPM; &
Footing used as a load out area = 596 PPM +/- 34 PPM.

Next we inspected a furnace, a titanium rotary furnace called "OV337" or "OVE337". We observed a box of "Inswool" ceramic fiber outside of the furnace as the furnace was in the process of refractory and insulation maintenance and repair. We scanned 4 surfaces with the XRF and recorded total Cr:

Refractory on furnace doorway floor = 818 PPM +/- 28 PPM;
Brick on furnace doorway ceiling = 2910 PPM +/- 45 PPM;
Ceramic fiber insulation wall inside furnace = 5007 PPM +/- 60 PPM (highest reading inside); &
Burner tunnel refractory = 3468 PPM +/- 47 PPM.

We took 3 samples from inside of the furnace:

Sample #3 = Refractory debris on rotary floor;
Sample #4 = Dark dust and debris from gap in floor; &
Sample #5 = Ceramic fiber insulation debris.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-28-

Date(s): 6/1/2017 and 7/13/2017

We provide a split of each sample to Ms. Miller. Ms. Pelayo also carried an XRF unit and scanned surfaces after I scanned them. We verbally requested SDS information for "Inswool" ceramic fiber insulation, brick and refractory and will also send an email requesting this information.

-- Areio

Areio Soltani - Air Quality Inspector
Toxics and Waste Management Unit
South Coast Air Quality Management District
21865 Copley Dr - Diamond Bar, CA 91765
(909) 396-3318 - Fax: (909) 396-3342

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-29-

Date(s): 6/1/2017 and 7/13/2017

APPENDIX B

Field Data – June 1, 2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-31-

Date(s): 6/1/2017 and 7/13/2017

South Coast Air Quality Management District

Test No. 17-341 Company: Wabco Metals
Sampling Location: oven #337

Date: 6/1/17
Sample Train: #37 400

Traverse Source Test Data

Pre-Test Leak Check:
Filter: _____ cfm @ _____ "Hg vac
Probe: 0.00 cfm @ 17 "Hg vac
Pitot Tube Leak Check: Pass / Fail

Post-Test Leak Check:
Filter: _____ cfm @ _____ "Hg vac
Probe: 0.00 cfm @ 17 "Hg vac
Pitot Tube Leak Check: Pass / Fail

| Time | Sample Point # | Gas Meter Reading (dcf) | Stack | | Calculated | | | Probe Temp. °F | Filter Temp. °F | Imp. Temp. °F | Meter Temp. °F | | Vacuum "Hg |
|--|----------------|-------------------------|-----------------------------------|----------|----------------|---------------------|--------------------------------|----------------|-----------------|---------------|----------------|-----------|------------|
| | | | Velocity Head ("H ₂ O) | Temp. °F | Velocity (fps) | Sampling Rate (cfm) | Orifice ΔP ("H ₂ O) | | | | In | Out | |
| | 11:20 | Start: <u>188.128</u> | | | | | | | | | | | |
| <u>11:26</u> | <u>#10</u> | <u>195.15</u> | | | | | <u>1.7</u> | | | <u>53</u> | <u>81</u> | <u>80</u> | <u>4</u> |
| <u>11:28</u> | <u>#20</u> | <u>202.75</u> | | | | | <u>1.7</u> | | | <u>47</u> | <u>87</u> | <u>81</u> | <u>4</u> |
| <u>11:30</u> | <u>#30</u> | <u>209.55</u> | | | | | <u>1.7</u> | | | <u>53</u> | <u>93</u> | <u>86</u> | <u>4</u> |
| <u>11:32</u> | <u>#40</u> | <u>216.4</u> | | | | | <u>1.7</u> | | | <u>54</u> | <u>93</u> | <u>87</u> | <u>4</u> |
| <u>11:34</u> | <u>#50</u> | <u>223.0</u> | | | | | <u>1.7</u> | | | <u>56</u> | <u>96</u> | <u>89</u> | <u>4</u> |
| <u>11:36</u> | <u>#60</u> | <u>229.6</u> | | | | | <u>1.7</u> | | | <u>58</u> | <u>98</u> | <u>90</u> | <u>4</u> |
| <u>11:38</u> | <u>#70</u> | <u>236.5</u> | | | | | <u>1.7</u> | | | <u>58</u> | <u>99</u> | <u>92</u> | <u>4</u> |
| <u>11:40</u> | <u>#80</u> | <u>243.4</u> | | | | | <u>1.7</u> | | | <u>59</u> | <u>99</u> | <u>93</u> | <u>4</u> |
| <u>11:42</u> | <u>#90</u> | <u>250.0</u> | | | | | <u>1.7</u> | | | <u>59</u> | <u>101</u> | <u>94</u> | <u>4</u> |
| <u>11:44</u> | <u>#100</u> | <u>256.7</u> | | | | | <u>1.7</u> | | | <u>58</u> | <u>102</u> | <u>95</u> | <u>4</u> |
| <u>11:46</u> | <u>#110</u> | <u>263.75</u> | | | | | <u>1.7</u> | | | <u>47</u> | <u>103</u> | <u>96</u> | <u>4</u> |
| <u>11:48</u> | <u>#120</u> | <u>270.112</u> | | | | | <u>1.7</u> | | | | <u>104</u> | <u>97</u> | <u>4</u> |
| <u>11:50</u> | <u>BW</u> | | | | | | | | | | | | |
| * connecting tube disconnected @ 12:06 PM (back end) retest @ 12:07 | | | | | | | | | | | | | |
| FURNACE TEMP: 1725 °F | | | | | | | | | | | | | |


(Net Vol. Uncorr.)

Avg.

K-Factor: 0.5821 Stack Moisture: _____ Canister #: 54205 Start: 11:38 28' "Hg vac
Nozzle Diameter: _____ " Recorded By: B Welch 3"
Barometric Pressure: 30.28 "HgA Pitot Factor: _____
Static Pressure in Stack: 4.03 "H₂O

Calibration Data

| | | |
|---------------------|---------------|------------------------|
| Inclined Manometer | <u>NO 715</u> | (Cal: <u>N/A</u>) |
| Magnehelic No. | _____ | (Cal: _____) |
| Pitot Tube No. | _____ | (Cal: _____) |
| Potentiometer No. | <u>NO 315</u> | (Cal: <u>4/28/14</u>) |
| Thermocouple No. | <u>21202</u> | (Cal: <u>5/11/17</u>) |
| Gas Meter No. | <u>NO 715</u> | (Cal: <u>4/28/17</u>) |
| Meter Corr. Factor: | <u>1.0051</u> | |



Sampling Probe: Stainless Steel / Borosilicate / Quartz

Stack: Horizontal / Vertical Rectangular / Circular

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-33-

Date(s): 6/1/2017 and 7/13/2017

Furnace 337 Gas meter readings Recorded by E. Padilla



Start of Test

11:20 AM



+30 min

11:50 AM



+60 min

12:20 PM

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-34-

Date(s): 6/1/2017 and 7/13/2017



+90 min
12:50 PM



+120 min
1:20 PM

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-35-

Date(s): 6/1/2017 and 7/13/2017

Field Data – July 13, 2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-36-

Date(s): 6/1/2017 and 7/13/2017

South Coast Air Quality Management District

Test No. 17-343 Company: Weber Metals Date: 7/13/17
Sampling Location: Area 339 West Stack Sample Train: 15

Traverse Source Test Data

Pre-Test Leak Check: Filter: _____ cfm @ _____ *Hg vac
Probe: Ø cfm @ 15 *Hg vac
Pitot Tube Leak Check: Pass / Fail

Post-Test Leak Check: Filter: _____ cfm @ _____ *Hg vac
Probe: Ø cfm @ 15 *Hg vac
Pitot Tube Leak Check: Pass / Fail

| Time | Sample Point # | Gas Meter Reading (dcl) | Stack | | Calculated | | | Probe Temp. °F | Filter Temp. °F | Imp. Temp. °F | Meter Temp. °F | | Vacuum *Hg |
|----------|----------------|-------------------------|------------------------------------|----------|----------------|---------------------|-------------------------------|----------------|-----------------|---------------|----------------|-----|------------|
| | | | Velocity H ₂ O (ft/min) | Temp. °F | Velocity (fps) | Sampling Rate (cfm) | Orifice ΔP (H ₂ O) | | | | In | Out | |
| 11:05 AM | | Start: 511.796 | | | | | | | | | | | |
| | +15 | 525.47 | 3.0 | | | | | | | 42 | 91 | 89 | 9 |
| | +30 | 533.73 | 3.0 | | | | | | | 42 | 102 | 92 | 10 |
| | +45 | 552.67 | 3.0 | | | | | | | 45 | 111 | 98 | 10 |
| | +60 | 516.43 | 3.0 | | | | | | | 43 | 113 | 102 | 11 |
| | +75 | 530.06 | 3.0 | | | | | | | 48 | 116 | 105 | 11 |
| | +90 | 593.27 | 2.7 | | | | | | | 52 | 119 | 108 | 12 |
| | +105 | 606.36 | 2.6 | | | | | | | 59 | 120 | 113 | 12 |
| | +120 | 619.212 | 2.6 | | | | | | | 45 | 120 | 112 | 12 |
| | +130 | | | | | | | | | | | | |

(Net Vol. Uncorr.) _____ Avg. _____


K-Factor: 0.5682 Stack Moisture: _____ Canister #: 54080 Start: 30 *Hg vac

Nozzle Diameter: _____
Barometric Pressure: 30.20 *HgA
Static Pressure in Stack: +1- _____ *H₂O

Recorded By: SP
Pitot Factor: _____

Calibration Data

| | |
|-----------------------------------|------------------------|
| Inclined Manometer _____ | (Cal: N/A) |
| Magnehelic No. _____ | (Cal: _____) |
| Pitot Tube No. _____ | (Cal: _____) |
| Potentiometer No. <u>N0314</u> | (Cal: <u>7/24/17</u>) |
| Thermocouple No. <u>71207</u> | (Cal: <u>5/15/17</u>) |
| Gas Meter No. <u>N0714</u> | (Cal: <u>7/24/17</u>) |
| Meter Corr. Factor: <u>1.0024</u> | |



Sampling Probe: Stainless Steel / Borosilicate Quartz Stack: Horizontal / Vertical Rectangular / Circular

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-38-

Date(s): 6/1/2017 and 7/13/2017

South Coast Air Quality Management District

Test No. 17-343 Company: WEBER METAL Date: 7/13/17
 Sampling Location: PIE 339 - EAST STACK (FURNACE) Sample Train: 5

Traverse Source Test Data

Pre-Test Leak Check: Filter: _____ cfm @ _____ "Hg vac
 Probe: 0.004 cfm @ 15 "Hg vac
 Pitot Tube Leak Check: Pass / Fail

Post-Test Leak Check: Filter: _____ cfm @ _____ "Hg vac
 Probe: 0.015 cfm @ 12 "Hg vac
 Pitot Tube Leak Check: Pass / Fail

| Time | Sample Point # | Gas Meter Reading (dcl) | Stack | | Calculated | | | Probe Temp. °F | Filter Temp. °F | Imp. Temp. °F | Meter Temp. °F | | Vacuum "Hg |
|-------------|----------------|-------------------------|---------------------------------|-------------|-----------------|---------------------|--------------------------------|----------------|-----------------|---------------|----------------|------------|------------|
| | | | Velocity Head "H ₂ O | Temp. °F | Velocity (ft/s) | Sampling Rate (cfm) | Orifice ΔP ("H ₂ O) | | | | In | Out | |
| | | Start: <u>270.24</u> | | | | | | | | | | | |
| <u>1105</u> | <u>+15</u> | <u>284.65</u> | <u>-17</u> | <u>1746</u> | | | <u>3.0</u> | | | <u>45</u> | <u>91</u> | <u>90</u> | <u>7</u> |
| | <u>+530</u> | <u>298.84</u> | <u>-17</u> | <u>1745</u> | | | <u>3.0</u> | | | <u>40</u> | <u>98</u> | <u>99</u> | <u>8</u> |
| | <u>+45</u> | <u>312.89</u> | <u>-17</u> | <u>1745</u> | | | <u>3.0</u> | | | <u>48</u> | <u>109</u> | <u>99</u> | <u>8</u> |
| | <u>+60</u> | <u>327.06</u> | <u>-17</u> | <u>1745</u> | | | <u>3.0</u> | | | <u>39</u> | <u>107</u> | <u>100</u> | <u>8</u> |
| | <u>+75</u> | <u>341.28</u> | <u>-18</u> | <u>1745</u> | | | <u>2.0</u> | | | <u>43</u> | <u>111</u> | <u>103</u> | <u>8</u> |
| | <u>+90</u> | <u>355.44</u> | <u>-19</u> | <u>1745</u> | | | <u>2.9</u> | | | <u>39</u> | <u>104</u> | <u>106</u> | <u>9</u> |
| | <u>+105</u> | <u>369.43</u> | <u>-19</u> | <u>1745</u> | | | <u>2.8</u> | | | <u>41</u> | <u>116</u> | <u>108</u> | <u>9</u> |
| <u>1305</u> | <u>+120</u> | <u>383.205</u> | <u>-19</u> | <u>1745</u> | | | <u>2.7</u> | | | <u>45</u> | <u>119</u> | <u>112</u> | <u>9</u> |

(Net Vol. Uncorr.) _____ Avg. _____

K-Factor: .5821 Stack Moisture: _____ Canister #: 54179 #1 Start: 30 "Hg vac
 Nozzle Diameter: _____ Recorded By: JA
 Barometric Pressure: 30.20 "HgA Pitot Factor: _____
 Static Pressure in Stack: 31 - 0.02 "H₂O

Calibration Data

| | | |
|---------------------|---------------|------------------------|
| Inclined Manometer | <u>N0715</u> | (Cal: <u>N/A</u>) |
| Magnehelic No. | _____ | (Cal: _____) |
| Pitot Tube No. | _____ | (Cal: _____) |
| Potentiometer No. | <u>N0315</u> | (Cal: <u>5/2/17</u>) |
| Thermocouple No. | <u>70702</u> | (Cal: <u>3/11/17</u>) |
| Gas Meter No. | <u>N0715</u> | (Cal: <u>4/26/17</u>) |
| Meter Corr. Factor: | <u>1.0051</u> | |

Stack: Horizontal / Vertical / Rectangular / Circular

Revision 01/09

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-41-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
TCA TEST DATA SHEET

Date: 7/13/17 NAT GAS METERS
Test No.: 17343

Page No.: _____
Recorded by: JA

Company/Sampling Location: _____
Basic and Control Equipment: _____

| | | | | | |
|--------------------------------|--------------|--------------------------|---|--------------|--------------------------|
| SAMPLE A | | | SAMPLE B | | |
| Tank # _____ | Trap # _____ | Control # _____ | Tank # _____ | Trap # _____ | Control # _____ |
| Pre-Test Leak Check: | | Gauge _____ Δ P _____ | Pre-Test Leak Check: | | Gauge _____ Δ P _____ |
| Post-Test Leak Check: | | Gauge _____ Δ P _____ | Post-Test Leak Check: | | Gauge _____ Δ P _____ |
| Barometric Pressure _____ "HgA | | | Static Pressure _____ "HgA (a _____ "H2O) | | |

PROCESS CONTROL
SCFH
1717 HOS
1574
1481
1488
1360
1375
1283
1311
1250

UN CORRECTED

| TIME | VACUUM ("Hg) | FLOW (cc/min) | COMMENTS |
|------|--------------|---------------|--------------------------------------|
| 0 | | | <u>MCF-CCF</u> <u>54509 29388</u> |
| +15 | | | <u>293890</u> |
| +70 | | | <u>293893</u> |
| +45 | | | <u>293894</u> |
| +60 | | | <u>293896</u> |
| +75 | | | <u>293898</u> |
| +90 | | | <u>293900</u> |
| +105 | | | <u>293901</u> |
| +120 | | | <u>293903</u> |

293888
CORRECTED

| TIME | VACUUM ("Hg) | FLOW (cc/min) | COMMENTS |
|------|--------------|---------------|----------------------------|
| 0 | | | <u>MCF</u> <u>54509</u> |
| | | | <u>54509</u> |
| | | | <u>54509</u> |
| | | | <u>54510</u> |
| +60 | | | <u>54510</u> |
| +75 | | | <u>54510</u> |
| +90 | | | <u>54511</u> |
| +105 | | | <u>54511</u> |
| | | | <u>54511</u> |

HONEYWELL MINIMAX
TCA SAMPLING INTERVAL TABLE (Δ P)

| | 70 | 200 | 300 | 400 | 500 | 600 | 700 | 800 | 1000 | 1200 |
|----|------|------|------|------|------|------|------|------|------|------|
| 15 | 2.65 | 2.90 | | | | | | | | |
| 20 | 2.20 | 2.45 | 2.70 | | | | | | | |
| 25 | 1.90 | 2.15 | 2.30 | 2.70 | | | | | | |
| 30 | 1.65 | 1.85 | 2.00 | 2.40 | 2.85 | | | | | |
| 35 | 1.40 | 1.60 | 1.80 | 2.10 | 2.50 | 2.85 | | | | |
| 40 | 1.20 | 1.40 | 1.60 | 1.90 | 2.25 | 2.50 | 2.95 | | | |
| 45 | 1.05 | 1.25 | 1.40 | 1.70 | 2.00 | 2.25 | 2.60 | 3.00 | | |
| 50 | 0.95 | 1.15 | 1.25 | 1.50 | 1.85 | 2.05 | 2.40 | 2.70 | | |
| 55 | 0.85 | 1.05 | 1.15 | 1.35 | 1.65 | 1.85 | 2.15 | 2.45 | 2.80 | |
| 60 | 0.80 | 0.95 | 1.05 | 1.25 | 1.55 | 1.70 | 2.00 | 2.30 | 2.55 | |
| 65 | 0.70 | 0.85 | 0.95 | 1.15 | 1.40 | 1.60 | 1.90 | 2.15 | 2.40 | |
| 70 | 0.65 | 0.80 | 0.90 | 1.05 | 1.30 | 1.50 | 1.75 | 2.00 | 2.25 | |
| 75 | 0.60 | 0.75 | 0.80 | 1.00 | 1.25 | 1.40 | 1.65 | 1.90 | 2.15 | |
| 80 | 0.55 | 0.65 | 0.75 | 0.90 | 1.15 | 1.30 | 1.55 | 1.80 | 2.05 | |
| 85 | 0.50 | 0.60 | 0.70 | 0.85 | 1.10 | 1.25 | 1.50 | 1.75 | 1.95 | |
| 90 | 0.50 | 0.55 | 0.65 | 0.80 | 1.05 | 1.25 | 1.50 | 1.65 | 1.90 | |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-42-

Date(s): 6/1/2017 and 7/13/2017

APPENDIX C

District Laboratory Data

June 1, 2017 – Source Test

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-43-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr., Diamond Bar, CA 91765-4182

Page 1 of 2

MONITORING & ANALYSIS
REPORT OF LABORATORY ANALYSIS

| | | |
|--|----------------|--------------|
| TO Mike Garibay Supervising A.Q. Engineer Source Test & Engineering | LABORATORY NO | 1714534 |
| | SOURCE TEST NO | 17-341 |
| SAMPLE(S) DESCRIBED AS 3 Hexavalent Chromium Trains | DATE RECEIVED | 06/01/17 |
| | RULE NO | NA |
| SAMPLING LOCATION Facility ID 10966 Weber Metals, Inc. 16706 Garfield Ave. Paramount, CA 90723 | REQUESTED BY | Jason Aspell |
| | DATE ANALYZED | 6/2/2017 |
| | DATE REPORTED | 6/8/2017 |

ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS

Moisture and Hexavalent Chromium by CARB 425 (Sodium Bicarbonate(NaHCO₃) solution)

| | Train 40 | Train 39 | Train 38 |
|-----------------------|----------|----------|----------|
| Moisture gain, g | 242.0 | 35.0 | - |
| Silica gel% expended | 90 | 75 | 0 |
| Filter gain, g | 0.0001 | 0.0003 | -0.0013 |
| Impinger 1 pH | 9 | 10 | 9 |
| Impinger 2 pH | 8 | 10 | 9 |
| Cr ⁺⁶ , ug | 54.52 | 0.03 | 0.00 |
| Total Cr, ug | 480.29 | 0.16 | 0.10 |

Recovery Notes:

Train 38: The neck of Impinger 4 broke in the field, therefore post-sampling weight and moisture gain values are not obtainable.

NOTE: Additional significant figures provided for calculation purposes.

Reviewed By: Joan Mertit
Joan Mertit, Principal A.Q. Chemist
Laboratory Services

Date Reviewed: 06/08/17

Approved By: Aaron Katzenstein
Aaron Katzenstein, Ph.D.
Senior Manager
Laboratory Services
(909) 396-2219

Date Approved: 6/8/17

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-44-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr., Diamond Bar, CA 91765-4182
Page 2 of 2

MONITORING & ANALYSIS
REPORT OF LABORATORY ANALYSIS

LABORATORY NO 1714534

REQUESTED BY Jason Aspell

ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS
Moisture and Hexavalent Chromium by CARB 425 (Sodium Bicarbonate(NaHCO₃) solution)

QUALITY CONTROL

BALANCE CHECK (MOISTURE GAIN)

| Lab No. | Result (g) | Limit (g) | Check Status |
|--------------|------------|-----------|--------------|
| B17F012-CCV1 | 99.9998 | ±0.0005 | Pass |
| B17F012-CCV2 | 500.0 | ±0.2 | Pass |

CCV RECOVERIES (CR6)

| Lab No. | Results (ppt) | Limit (%) | % Recovery |
|--------------|---------------|-----------|------------|
| S17F009-CCV1 | 100 | 90-110 | 100 |
| S17F009-CCV2 | 93 | 90-110 | 93 |
| S17F009-CCV3 | 99 | 90-110 | 99 |
| S17F009-CCV4 | 97 | 90-110 | 97 |

| CCV RECOVERIES (TOTAL CR) | Limit (%) | % Recovery |
|---------------------------|-----------|------------|
| S17F010-CCV1 | 90-110 | 97 |
| S17F010-CCV2 | 90-110 | 103 |
| S17F010-CCV3 | 90-110 | 100 |
| S17F010-CCV4 | 90-110 | 102 |
| S17F010-CCV5 | 90-110 | 98 |

REF B17F012
S17F009
S17F010

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-45-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr., Diamond Bar, CA 91765-4182
Page 2 of 2

MONITORING & ANALYSIS
REPORT OF LABORATORY ANALYSIS

LABORATORY NO 1714534

REQUESTED BY Jason Aspell

ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS
Moisture and Hexavalent Chromium by CARB 425 (Sodium Bicarbonate(NaHCO₃) solution)

QUALITY CONTROL

BALANCE CHECK (MOISTURE GAIN)

| Lab No. | Result (g) | Limit (g) | Check Status |
|--------------|------------|-----------|--------------|
| B17F012-CCV1 | 99.9998 | ±0.0005 | Pass |
| B17F012-CCV2 | 500.0 | ±0.2 | Pass |

CCV RECOVERIES (CR6)

| Lab No. | Results (ppt) | Limit (%) | % Recovery |
|--------------|---------------|-----------|------------|
| S17F009-CCV1 | 100 | 90-110 | 100 |
| S17F009-CCV2 | 93 | 90-110 | 93 |
| S17F009-CCV3 | 99 | 90-110 | 99 |
| S17F009-CCV4 | 97 | 90-110 | 97 |

| CCV RECOVERIES (TOTAL CR) | Limit (%) | % Recovery |
|---------------------------|-----------|------------|
| S17F010-CCV1 | 90-110 | 97 |
| S17F010-CCV2 | 90-110 | 103 |
| S17F010-CCV3 | 90-110 | 100 |
| S17F010-CCV4 | 90-110 | 102 |
| S17F010-CCV5 | 90-110 | 98 |

REF B17F012
S17F009
S17F010

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-46-

Date(s): 6/1/2017 and 7/13/2017



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS
REPORT OF LABORATORY ANALYSIS

(Page 1 of 3)

To: Mike Garibay
Supervising A.Q. Engineer
Source Test & Engineering

Laboratory No. 1714534-13
Requested By Jason Aspell
Rule No. NA
ST No. 17-341
Report Created 06/14/2017

Sampling Location

Facility ID 10966
Weber Metals, Inc.
16706 Garfield Ave.
Paramount, CA 90723

ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS, AND RESULTS

Percent hydrogen (H₂), nitrogen (N₂), oxygen (O₂), and methane (CH₄) by SCAQMD Method
10.1 (GC-TCD)

See attached results and sample information.

Reviewed By: 
Joan Nieritit
Principal A.Q. Chemist
Laboratory Services

Date Reviewed: 06/14/17

Approved By: 
Aaron Katzenstein, Ph.D.
Senior Manager
Laboratory Services
(909) 396-2219

Date Approved: 6/15/17

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-47-

Date(s): 6/1/2017 and 7/13/2017



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS
REPORT OF LABORATORY ANALYSIS

(Page 2 of 3)

Laboratory No. 1714534-13

Sample Description SUMMA Canister Canister 54205, Furnace Sample

Sample Date 06/01/2017

Received Date 06/01/2017

Analyzed Date 06/06/2017

Percent hydrogen (H₂), nitrogen (N₂), oxygen (O₂), and methane (CH₄) by SCAQMD Method 10.1
(GC-TCD)

| Analyte, Unit | Result | MDL | MRL |
|---------------------|--------|-----|-----|
| H ₂ , % | <0.2 | 0.2 | NA |
| O ₂ , % | 10 | 0.2 | NA |
| N ₂ , % | 80 | 0.2 | NA |
| CH ₄ , % | <0.2 | 0.2 | NA |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-48-

Date(s): 6/1/2017 and 7/13/2017



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS
REPORT OF LABORATORY ANALYSIS

(Page 3 of 3)

Laboratory No. 1714534-13

Percent hydrogen (H2), nitrogen (N2), oxygen (O2), and methane (CH4) by SCAQMD Method 10.1
(GC-TCD)

QUALITY CONTROL SUMMARY

CCV1 (CC122586)

Analyte, Unit

H2, %

O2, %

N2, %

CH4, %

| Measured | Theoretical | Absolute Difference | QC Limit ±0.5% |
|----------|-------------|---------------------|----------------|
| 1.00 | 0.94 | 0.06 | PASS |
| 1.05 | 1.03 | 0.02 | PASS |
| 1.07 | 0.96 | 0.11 | PASS |
| 1.04 | 1.01 | 0.03 | PASS |

CCV2 (CC73109)

Analyte, Unit

H2, %

O2, %

N2, %

CH4, %

| Measured | Theoretical | Absolute Difference | QC Limit ±0.5% |
|----------|-------------|---------------------|----------------|
| 0.00 | 0.00 | NA | PASS |
| 24.65 | 24.63 | 0.02 | PASS |
| 4.97 | 4.93 | 0.04 | PASS |
| 0.00 | 0.00 | NA | PASS |

CCV3 (FF130)

Analyte, Unit

H2, %

O2, %

N2, %

CH4, %

| Measured | Theoretical | Absolute Difference | QC Limit ±0.5% |
|----------|-------------|---------------------|----------------|
| 0.00 | 0.00 | NA | PASS |
| 0.98 | 1.00 | 0.02 | PASS |
| 93.66 | 93.9 | 0.24 | PASS |
| 0.00 | 0.00 | NA | PASS |

CCV4 (CC122586)

Analyte, Unit

H2, %

O2, %

N2, %

CH4, %

| Measured | Theoretical | Absolute Difference | QC Limit ±0.5% |
|----------|-------------|---------------------|----------------|
| 1.00 | 0.94 | 0.06 | PASS |
| 1.07 | 1.03 | 0.04 | PASS |
| 1.09 | 0.96 | 0.13 | PASS |
| 1.02 | 1.01 | 0.01 | PASS |

CCV5 (CC73109)

Analyte, Unit

H2, %

O2, %

N2, %

CH4, %

| Measured | Theoretical | Absolute Difference | QC Limit ±0.5% |
|----------|-------------|---------------------|----------------|
| 0.00 | 0.00 | NA | PASS |
| 24.65 | 24.63 | 0.02 | PASS |
| 5.01 | 4.93 | 0.08 | PASS |
| 0.00 | 0.00 | NA | PASS |

CCV6 (FF130)

Analyte, Unit

H2, %

O2, %

N2, %

CH4, %

| Measured | Theoretical | Absolute Difference | QC Limit ±0.5% |
|----------|-------------|---------------------|----------------|
| 0.00 | 0.00 | NA | PASS |
| 1.00 | 1.00 | 0.00 | PASS |
| 94.01 | 93.9 | 0.11 | PASS |
| 0.00 | 0.00 | NA | PASS |

REFERENCE NO. B17F037

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-49-

Date(s): 6/1/2017 and 7/13/2017



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS
REPORT OF LABORATORY ANALYSIS

(Page 1 of 3)

To: Mike Garibay
Supervising A.Q. Engineer
Source Test & Engineering

Laboratory No. 1714534-13
Requested By Jason Aspell
Rule No. NA
ST No. 17-341
Report Created 06/14/2017


Sampling Location

Facility ID 10966
Weber Metals, Inc.
16706 Garfield Ave.
Paramount, CA 90723

ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS, AND RESULTS

Total Gaseous Non-Methane Non-Ethane Organic Carbon by SCAQMD Method 25.1 (GC-TCA)

See attached results and sample information.

Reviewed By: 
Joan Niertit
Principal A.Q. Chemist
Laboratory Services

Date Reviewed: 06/14/17

Approved By: 
Aaron Katzenstein, Ph.D.
Senior Manager
Laboratory Services
(909) 396-2219

Date Approved: 6/16/17

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-50-

Date(s): 6/1/2017 and 7/13/2017



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS
REPORT OF LABORATORY ANALYSIS

(Page 2 of 3)

Laboratory No. 1714534-13

Sample Description SUMMA Canister Canister 54205, Furnace Sample

Sample Date 06/01/2017

Received Date 06/01/2017

Analyzed Date 06/06/2017

Total Gaseous Non-Methane Non-Ethane Organic Carbon by SCAQMD Method 25.1 (GC-TCA)

| Analyte, Unit | Result | MDL | MRL |
|-------------------------|--------|-----|-----|
| CH ₄ , ppmvC | <1 | 0.5 | 1 |
| CO ₂ , ppmvC | 57155 | 0.5 | 1 |
| Ethane, ppmvC | <1 | 0.5 | 1 |
| NMNEOC, ppmvC | <1 | 0.5 | 1 |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-51-

Date(s): 6/1/2017 and 7/13/2017



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, CA 91765-4182

**MONITORING AND ANALYSIS
REPORT OF LABORATORY ANALYSIS**

(Page 3 of 3)

Laboratory No. 1714534-13

Total Gaseous Non-Methane Non-Ethane Organic Carbon by SCAQMD Method 25.1 (GC-TCA)

QUALITY CONTROL SUMMARY

CCV1 (CC106783)

Analyte, Unit

CO, ppmvC

CH4, ppmvC

CO2, ppmvC

Ethane, ppmvC

NMNEOC, ppmvC

| Measured | Theoretical | Percent Error | Absolute Difference | QC Limit ±5% or ±1 |
|----------|-------------|---------------|---------------------|-----------------------|
| 2.15 | 1.92 | 11.75 | 0.23 | PASS |
| 1.99 | 2.02 | 1.68 | 0.03 | PASS |
| 2.37 | 1.57 | 51.05 | 0.80 | PASS |
| 2.00 | 2.03 | 1.48 | 0.03 | PASS |
| 2.18 | 2.03 | 7.50 | 0.15 | PASS |

CCV2 (CC135067)

Analyte, Unit

CO, ppmvC

CH4, ppmvC

CO2, ppmvC

Ethane, ppmvC

NMNEOC, ppmvC

| Measured | Theoretical | Percent Error | Absolute Difference | QC Limit ±5% or ±1 |
|----------|-------------|---------------|---------------------|-----------------------|
| 10130 | 10100 | 0.25 | 25.46 | PASS |
| 9997 | 9950 | 0.47 | 46.97 | PASS |
| 10180 | 10100 | 0.76 | 76.38 | PASS |
| 10020 | 9940 | 0.80 | 79.47 | PASS |
| 10150 | 10000 | 1.54 | 154.08 | PASS |

CCV3 (CC106783)

Analyte, Unit

CO, ppmvC

CH4, ppmvC

CO2, ppmvC

Ethane, ppmvC

NMNEOC, ppmvC

| Measured | Theoretical | Percent Error | Absolute Difference | QC Limit ±5% or ±1 |
|----------|-------------|---------------|---------------------|-----------------------|
| 2.23 | 1.92 | 15.90 | 0.31 | PASS |
| 2.18 | 2.02 | 7.71 | 0.16 | PASS |
| 2.09 | 1.57 | 33.21 | 0.52 | PASS |
| 2.18 | 2.03 | 7.39 | 0.15 | PASS |
| 2.06 | 2.03 | 1.58 | 0.03 | PASS |

CCV4 (CC135067)

Analyte, Unit

CO, ppmvC

CH4, ppmvC

CO2, ppmvC

Ethane, ppmvC

NMNEOC, ppmvC

| Measured | Theoretical | Percent Error | Absolute Difference | QC Limit ±5% or ±1 |
|----------|-------------|---------------|---------------------|-----------------------|
| 10080 | 10100 | 0.18 | 18.19 | PASS |
| 9970 | 9950 | 0.20 | 19.78 | PASS |
| 10140 | 10100 | 0.39 | 39.21 | PASS |
| 9999 | 9940 | 0.59 | 58.58 | PASS |
| 10120 | 10000 | 1.22 | 122.24 | PASS |

REFERENCE NO. B17F036

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-52-

Date(s): 6/1/2017 and 7/13/2017

July 13, 2017 – Source Test

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-53-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr., Diamond Bar, CA 91765-4182
Page 1 of 2

MONITORING & ANALYSIS
REPORT OF LABORATORY ANALYSIS

| | | |
|---|-----------------------------|--------------|
| TO Mike Garibay Supervising A.Q. Engineer Source Test Engineering | LABORATORY NO _____ | 1718636 |
| | SOURCE TEST NO _____ | 17-343 |
| SAMPLE(S) DESCRIBED AS 3 Hexavalent Chromium Trains | DATE RECEIVED _____ | 07/13/2017 |
| | RULE NO _____ | NA |
| SAMPLING LOCATION Facility ID 10966 Weber Metals, Inc. 16706 Garfield Ave. Paramount, CA 90723 | REQUESTED BY _____ | Jason Aspell |
| | DATE ANALYZED _____ | 7/14/2017 |
| | DATE REPORTED _____ | 7/19/2017 |

ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS

Moisture and Hexavalent Chromium by CARB 425 (Sodium Bicarbonate (NaHCO₃) solution)

| | Train 5 | Train 15 | Train 44 |
|-----------------------|---------|----------|----------|
| Moisture gain, g | 468.6 | 438.6 | 0.2 |
| Silica gel% expended | 95 | 95 | 2 |
| Filter gain, g | 0.007 | 0.0025 | -0.0003 |
| Impinger 1 pH | 7-8 | 7-8 | 9 |
| Impinger 2 pH | 7-8 | 7-8 | 9 |
| Cr ⁶⁺ , ug | 0.00 | 0.02 | 0.00 |
| Total Cr, ug | 0.32 | 0.30 | 0.14 |

Recovery Notes:

Train 5: The impingers contained a significant amount of particulate matter, and the filter was brown and discolored.


Train 15: The impingers contained a significant amount of particulate matter, and the filter was brown and discolored. The filter was buckled and pulled away from teflon filter holder.

Train 44: Field Blank, no probe, no tubing

NOTE: Additional significant figures provided for calculation purposes.

Reviewed By: 
Na Mon Trinh
Senior A.Q. Chemist
Laboratory Services

Date Reviewed: 7/19/17

Approved By: 
Aaron Katzenstein, Ph.D. *AK*
Senior Manager
Laboratory Services
(909) 396-2219

Date Approved: 07/20/17

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-54-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr., Diamond Bar, CA 91765-4182
Page 2 of 2

MONITORING & ANALYSIS
REPORT OF LABORATORY ANALYSIS

LABORATORY NO 1718636

REQUESTED BY Jason Aspell

ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS
Moisture and Hexavalent Chromium by CARB 425 (Sodium Bicarbonate (NaHCO₃) solution)

QUALITY CONTROL

BALANCE CHECK (MOISTURE GAIN)

| Lab No. | Result (g) | Limit (g) | Check Status |
|--------------|------------|-----------|--------------|
| B17G069-CCV1 | 99.9999 | ±0.0005 | Pass |
| B17G069-CCV2 | 500.0 | ±0.2 | Pass |

CCV RECOVERIES (CR6)

| Lab No. | Results (ppt) | Limit (%) | % Recovery |
|--------------|---------------|-----------|------------|
| S17G033-CCV1 | 98 | 90-110 | 98 |
| S17G033-CCV2 | 101 | 90-110 | 101 |
| S17G033-CCV3 | 107 | 90-110 | 107 |
| S17G033-CCV4 | 97 | 90-110 | 97 |

CCV RECOVERIES (TOTAL CR)

| Lab No. | Results (ppb) | Limit (%) | % Recovery |
|--------------|---------------|-----------|------------|
| S17G028-CCV1 | 4.71 | 90-110 | 94 |
| S17G028-CCV2 | 4.51 | 90-110 | 90 |
| S17G028-CCV3 | 4.65 | 90-110 | 93 |
| S17G028-CCV4 | 4.60 | 90-110 | 92 |
| S17G028-CCV5 | 5.05 | 90-110 | 101 |
| S17G028-CCV6 | 5.44 | 90-110 | 109 |

REF B17G069
S17G033
S17G028

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-55-

Date(s): 6/1/2017 and 7/13/2017

SOURCE TEST REQUEST FOR EQUIPMENT/ANALYSIS

Company Weber Metals, Inc. Source Test No. 17-343
 Address 16706 Garfield Ave, Paramount, CA 90723 Request Date 6/28/17
 Basic Equipment Rotary Furnace Control Device N/A
 Analysis/Equipment Requested By Jason Aspell Date Equipment Needed 7/11/17
 For Compliance, Rule(s) _____
 Other (specify) AB 2588 Facility ID No. 10966

Dry Ice Needed Laboratory No. 1718636
(100 POUNDS)

SAMPLE EQUIPMENT ANALYSIS REQUEST

| Equipment Requested/ID # | Analysis Requested | Set ID |
|--|---|--------|
| Two CARB Method 425 trains (NaHCO ₃ , modified with back-end filter positioned before silica impinger) | Total Chrome, Cr+6, moisture | |
| | <u>Trains Nos. 15, 5, 44</u> | |
| Two Quartz Sampling Probes | <u>Canisters Nos. 54080, 54128, 54139</u> | |
| | <u>Reference: STP 41, Pages 144, 145</u> | |
| Tubing (two sections) | | |
| 3 6 L Summa Canister | Fixed Gases | |
| <u>3 trains, 3 cans, 2 quartz probes, tubing</u> | | I |
| <u>Equipment Return</u> | | II |
| <u>Train 5: East Furnace, tubing, probe</u> | | |
| <u>Train 15: West Furnace, tubing, probe</u> | | |
| <u>Train 44: ambient field blank, no tubing</u> | | |
| <u>Can 54128: not used</u> | | |
| <u>Can 54080: West Furnace</u> | | |
| <u>Can 54139: East Furnace</u> | | |
| <u>Trip Blank</u> | | |
| <u>Cr(VI) & Total Cr Analysis</u> | | III |
| <u>Train 5: Cont 1 (-02), Cont 2 (-03), Cont 3 (-04)</u> | | |
| <u>Train 15: Cont 1 (-06), Cont 2 (-07), Cont 3 (-08)</u> | | |
| <u>Train 44: Cont 2 (-10), Cont 3 (-11)</u> | | |
| <u>Trip Blank: (-12)</u> | | |

SAMPLE EQUIPMENT CHAIN OF CUSTODY

| Sample Equipment Set ID | From | To | For (S/T, Analysis, Cleanup, Not Used) | Date Received | Time |
|-------------------------|--------------------|--------------------|--|-----------------|--------------|
| I | <u>C. Schellen</u> | <u>J. Aspell</u> | <u>S/T</u> | <u>07/12/17</u> | <u>14:00</u> |
| II | <u>C. Schellen</u> | <u>C. Schellen</u> | <u>Analysis</u> | <u>07/13/17</u> | <u>16:30</u> |
| III | <u>C. Schellen</u> | <u>Samuel</u> | <u>Analysis</u> | <u>07/14/17</u> | <u>14:21</u> |
| | | | | | |
| | | | | | |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-56-

Date(s): 6/1/2017 and 7/13/2017



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS
REPORT OF LABORATORY ANALYSIS

(Page 1 of 6)

To: Mike Garibay
Supervising A.Q. Engineer
Source Test Engineering

Laboratory No. 1718636-13 to -14

Requested By Jason Aspell

Sampling Location

Facility ID 10966
Weber Metals, Inc.
16706 Garfield Ave.
Paramount, CA 90723

Rule No. NA

ST No. 17-343

Report Created 08/02/2017

ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS, AND RESULTS

Percent hydrogen (H₂), nitrogen (N₂), oxygen (O₂), and methane (CH₄) by SCAQMD Method
10.1 (GC-TCD)

Total Gaseous Non-Methane Non-Ethane Organic Carbon by SCAQMD Method 25.1 (GC-TCA)

See attached results and sample information.

Reviewed By: Christi Schroeder
Christi Schroeder
Senior A.Q. Chemist
Laboratory Services

Date Reviewed: 08/02/17

Approved By: Aaron Katzenstein
Aaron Katzenstein, Ph.D.
Senior Manager
Laboratory Services
(909) 396-2219

Date Approved: 8/8/17

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-57-

Date(s): 6/1/2017 and 7/13/2017



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS
REPORT OF LABORATORY ANALYSIS

(Page 2 of 6)

Laboratory No. 1718636-13
Sample Description Grab, SUMMA Canister Canister 54080, West Furnace
Sample Date 07/13/2017 Received Date 07/13/2017 Analyzed Date 07/18/2017

Percent hydrogen (H₂), nitrogen (N₂), oxygen (O₂), and methane (CH₄) by SCAQMD Method 10.1 (GC-TCD)

| Analyte, Unit | Result | MDL | MRL |
|---------------------|--------|-----|-----|
| H ₂ , % | 1.9 | 0.2 | NA |
| O ₂ , % | 3.5 | 0.2 | NA |
| N ₂ , % | 80.0 | 0.2 | NA |
| CH ₄ , % | 0.2 | 0.2 | NA |

Laboratory No. 1718636-13
Sample Description Grab, SUMMA Canister Canister 54080, West Furnace
Sample Date 07/13/2017 Received Date 07/13/2017 Analyzed Date 07/20/2017

Total Gaseous Non-Methane Non-Ethane Organic Carbon by SCAQMD Method 25.1 (GC-TCA)

| Analyte, Unit | Result | MDL | MRL |
|-------------------------|--------|-----|-----|
| CH ₄ , ppmvC | 1920 | 0.5 | 1 |
| CO ₂ , ppmvC | 89700 | 0.5 | 1 |
| Ethane, ppmvC | <1 | 0.5 | 1 |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-58-

Date(s): 6/1/2017 and 7/13/2017



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS
REPORT OF LABORATORY ANALYSIS

(Page 3 of 6)

Laboratory No. 1718636-14
Sample Description Grab, SUMMA Canister Canister 54139, East Furnace
Sample Date 07/13/2017 Received Date 07/13/2017 Analyzed Date 07/18/2017

Percent hydrogen (H₂), nitrogen (N₂), oxygen (O₂), and methane (CH₄) by SCAQMD Method 10.1
(GC-TCD)

| Analyte, Unit | Result | MDL | MRL |
|---------------------|--------|-----|-----|
| H ₂ , % | 2.4 | 0.2 | NA |
| O ₂ , % | 0.8 | 0.2 | NA |
| N ₂ , % | 80.8 | 0.2 | NA |
| CH ₄ , % | 0.8 | 0.2 | NA |

Laboratory No. 1718636-14
Sample Description Grab, SUMMA Canister Canister 54139, East Furnace
Sample Date 07/13/2017 Received Date 07/13/2017 Analyzed Date 07/20/2017

Total Gaseous Non-Methane Non-Ethane Organic Carbon by SCAQMD Method 25.1 (GC-TCA)

| Analyte, Unit | Result | MDL | MRL |
|-------------------------|--------|-----|-----|
| CH ₄ , ppmvC | 8530 | 0.5 | 1 |
| CO ₂ , ppmvC | 103000 | 0.5 | 1 |
| Ethane, ppmvC | <1 | 0.5 | 1 |
| NMNEOC, ppmvC | 537 | 0.5 | 1 |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-59-

Date(s): 6/1/2017 and 7/13/2017



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS
REPORT OF LABORATORY ANALYSIS

(Page 4 of 6)

Laboratory No. 1718636-13 to -14

Percent hydrogen (H₂), nitrogen (N₂), oxygen (O₂), and methane (CH₄) by SCAQMD Method 10.1
(GC-TCD)

QUALITY CONTROL SUMMARY

CCV1 (CC122586)

Analyte, Unit

H₂, %

O₂, %

N₂, %

CH₄, %

| Measured | Theoretical | Absolute Difference | QC Limit ±0.5% |
|----------|-------------|---------------------|----------------|
| 1.00 | 0.94 | 0.06 | PASS |
| 1.11 | 1.03 | 0.08 | PASS |
| 1.24 | 0.96 | 0.28 | PASS |
| 1.00 | 1.01 | 0.01 | PASS |

CCV2 (CC73109)

Analyte, Unit

H₂, %

O₂, %

N₂, %

CH₄, %

| Measured | Theoretical | Absolute Difference | QC Limit ±0.5% |
|----------|-------------|---------------------|----------------|
| NA | NA | NA | NA |
| 24.55 | 24.63 | 0.08 | PASS |
| 4.97 | 4.93 | 0.04 | PASS |
| NA | NA | NA | NA |

CCV3 (FF130)

Analyte, Unit

H₂, %

O₂, %

N₂, %

CH₄, %

| Measured | Theoretical | Absolute Difference | QC Limit ±0.5% |
|----------|-------------|---------------------|----------------|
| NA | NA | NA | NA |
| 1.11 | 1.00 | 0.11 | PASS |
| 93.86 | 93.9 | 0.04 | PASS |
| NA | NA | NA | NA |

CCV4 (CC122586)

Analyte, Unit

H₂, %

O₂, %

N₂, %

CH₄, %

| Measured | Theoretical | Absolute Difference | QC Limit ±0.5% |
|----------|-------------|---------------------|----------------|
| 1.00 | 0.94 | 0.06 | PASS |
| 1.03 | 1.03 | 0.00 | PASS |
| 1.13 | 0.96 | 0.17 | PASS |
| 0.98 | 1.01 | 0.03 | PASS |

CCV5 (CC73109)

Analyte, Unit

H₂, %

O₂, %

N₂, %

CH₄, %

| Measured | Theoretical | Absolute Difference | QC Limit ±0.5% |
|----------|-------------|---------------------|----------------|
| NA | NA | NA | NA |
| 24.63 | 24.63 | 0.00 | PASS |
| 5.02 | 4.93 | 0.09 | PASS |
| NA | NA | NA | NA |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-60-

Date(s): 6/1/2017 and 7/13/2017



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS
REPORT OF LABORATORY ANALYSIS

(Page 5 of 6)

Laboratory No. 1718636-13 to -14

Percent hydrogen (H₂), nitrogen (N₂), oxygen (O₂), and methane (CH₄) by SCAQMD Method 10.1
(GC-TCD)

QUALITY CONTROL SUMMARY

CCV6 (FF130)
Analyte, Unit
H₂, %
O₂, %
N₂, %
CH₄, %

| Measured | Theoretical | Absolute Difference | QC Limit ±0.5% |
|----------|-------------|---------------------|----------------|
| NA | NA | NA | NA |
| 1.11 | 1.00 | 0.11 | PASS |
| 93.65 | 93.9 | 0.25 | PASS |
| NA | NA | NA | NA |

REFERENCE NO. B17G094

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-61-

Date(s): 6/1/2017 and 7/13/2017



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr. Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS
REPORT OF LABORATORY ANALYSIS

(Page 6 of 6)

Laboratory No. **1718636-13 to -14**

Total Gaseous Non-Methane Non-Ethane Organic Carbon by SCAQMD Method 25.1 (GC-TCA)

QUALITY CONTROL SUMMARY

CCV1 (CC106783)

Analyte, Unit
CO, ppmvC
CH4, ppmvC
CO2, ppmvC
Ethane, ppmvC
NMNEOC, ppmvC

| Measured | Theoretical | Percent Error | Absolute Difference | QC Limit ±5% or ±1 |
|----------|-------------|---------------|---------------------|-----------------------|
| 1.92 | 1.92 | 0.21 | 0.00 | PASS |
| 1.99 | 2.02 | 1.68 | 0.03 | PASS |
| 2.00 | 1.57 | 27.47 | 0.43 | PASS |
| 1.91 | 2.03 | 5.91 | 0.12 | PASS |
| 1.93 | 2.03 | 4.83 | 0.10 | PASS |

CCV2 (CC12628)

Analyte, Unit
CO, ppmvC
CH4, ppmvC
CO2, ppmvC
Ethane, ppmvC
NMNEOC, ppmvC

| Measured | Theoretical | Percent Error | Absolute Difference | QC Limit ±5% or ±1 |
|----------|-------------|---------------|---------------------|-----------------------|
| 1055 | 1036 | 1.88 | 19.44 | PASS |
| 1052 | 1068 | 1.53 | 16.30 | PASS |
| 1043 | 1022 | 2.01 | 20.56 | PASS |
| 1046 | 1044 | 0.15 | 1.60 | PASS |
| 1034 | 1024 | 1.00 | 10.21 | PASS |

CCV3 (CC106783)

Analyte, Unit
CO, ppmvC
CH4, ppmvC
CO2, ppmvC
Ethane, ppmvC
NMNEOC, ppmvC

| Measured | Theoretical | Percent Error | Absolute Difference | QC Limit ±5% or ±1 |
|----------|-------------|---------------|---------------------|-----------------------|
| 2.03 | 1.92 | 5.51 | 0.11 | PASS |
| 1.97 | 2.02 | 2.67 | 0.05 | PASS |
| 2.00 | 1.57 | 27.47 | 0.43 | PASS |
| 1.93 | 2.03 | 4.93 | 0.10 | PASS |
| 2.04 | 2.03 | 0.59 | 0.01 | PASS |

CCV4 (CC135067)

Analyte, Unit
CO, ppmvC
CH4, ppmvC
CO2, ppmvC
Ethane, ppmvC
NMNEOC, ppmvC

| Measured | Theoretical | Percent Error | Absolute Difference | QC Limit ±5% or ±1 |
|----------|-------------|---------------|---------------------|-----------------------|
| 10090 | 10100 | 0.10 | 9.87 | PASS |
| 9947 | 9950 | 0.03 | 3.23 | PASS |
| 10140 | 10100 | 0.44 | 44.66 | PASS |
| 9982 | 9940 | 0.43 | 42.26 | PASS |
| 10120 | 10000 | 1.16 | 116.04 | PASS |

REFERENCE NO. B17G115

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-62-

Date(s): 6/1/2017 and 7/13/2017

A

SOURCE TEST REQUEST FOR EQUIPMENT/ANALYSIS

| | |
|--|--------------------------------------|
| Company <u>Weber Metals, Inc.</u> | Source Test No. <u>17-343</u> |
| Address <u>16706 Garfield Ave, Paramount, CA 90723</u> | Request Date <u>6/28/17</u> |
| Basic Equipment <u>Rotary Furnace</u> | Control Device <u>N/A</u> |
| Analysis/Equipment Requested By <u>Jason Aspell</u> | Date Equipment Needed <u>7/11/17</u> |
| For Compliance, Rule(s) _____ | |
| Other (specify) <u>AB 2588</u> | Facility ID No. <u>10966</u> |

Dry Ice Needed (100 POUNDS)

Laboratory No. 1718636

SAMPLE EQUIPMENT ANALYSIS REQUEST

| Equipment Requested/ID # | Analysis Requested | Set ID |
|--|---|--------|
| 3 Two CARB Method 425 trains (NaHCO ₃), modified with back-end filter positioned before silica impinger) | Total Chrome, Cr+6, moisture <u>Trains Nos. 15, 5, 44</u> | |
| Two Quartz Sampling Probes | <u>Canisters Nos. 54080, 54128, 54139</u> <u>Reference: STP 41, Pages 144, 145</u> | |
| Tubing (two sections) | | |
| 3 6 L Summa Canister | Fixed Gases | |
| <u>3 trains, 3 cans, 2 quartz probes, tubing</u> | | I |
| <u>Equipment Return</u> | | II |
| <u>Train 5: East Furnace, tubing, probe</u> | | |
| <u>Train 15: West Furnace, tubing, probe</u> | | |
| <u>Train 44: Ambient, field blank, no tubing</u> | | |
| <u>Can 54128: not used</u> | | |
| <u>Can 54080: West Furnace</u> | | |
| <u>Can 54139: East Furnace</u> | | |
| <u>Trip Blank</u> | | |
| <u>Cr(VI) Total Cr Analysis</u> | | III |
| <u>Train 5: Cont 1 (-02), Cont 2 (-03), Cont 3 (-04)</u> | | |
| <u>Train 15: Cont 1 (-06), Cont 2 (-07), Cont 3 (-08)</u> | | |
| <u>Train 44: Cont 2 (-10), Cont 3 (-11)</u> | | |
| <u>Trip Blank: (-12)</u> | | |

SAMPLE EQUIPMENT CHAIN OF CUSTODY

| Sample Equipment Set ID | From | To | For (S/T, Analysis, Cleanup, Not Used) | Date Received | Time |
|-------------------------|-------------|-------------|--|---------------|-------|
| I | C. Schaefer | [Signature] | S/T | 07/12/17 | 14:00 |
| II | [Signature] | C. Schaefer | Analysis | 07/13/17 | 16:30 |
| III | C. Schaefer | [Signature] | Analysis | 07/14/17 | 14:21 |
| | | | | | |
| | | | | | |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-63-

Date(s): 6/1/2017 and 7/13/2017

APPENDIX D

Field Data and Lab Data– May 11, 2017
Discarded

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-65-

Date(s): 6/1/2017 and 7/13/2017

South Coast Air Quality Management District

Test No: 17-339 Company: Weber Metals Date: 5/11/17
 Sampling Location: Ambient - Process Area Sample Train: 30

Traverse Source Test Data

Pre-Test Leak Check: Filter: _____ cfm @ _____ "Hg vac
 Probe: 0.008 cfm @ 15 "Hg vac
 Pitot Tube Leak Check: Pass / Fail

Post-Test Leak Check: Filter: _____ cfm @ _____ "Hg vac
 Probe: 0.016 cfm @ 15 "Hg vac
 Pitot Tube Leak Check: Pass / Fail


| Time | Sample Point # | Gas Meter Reading (dcf) Start: <u>527.527</u> | Stack | | Calculated | | | Probe Temp. °F | Filter Temp. °F | Imp. Temp. °F | Meter Temp. °F | | Vacuum "Hg |
|-------------|----------------|--|-----------------------------------|----------|----------------|---------------------|--------------------------------|----------------|-----------------|---------------|----------------|-----------|------------|
| | | | Velocity Head ("H ₂ O) | Temp. °F | Velocity (fps) | Sampling Rate (cfm) | Orifice ΔP ("H ₂ O) | | | | In | Out | |
| <u>5:12</u> | | " | | | | <u>2.80</u> | | | <u>41</u> | <u>104</u> | <u>98</u> | <u>15</u> | |
| <u>+15</u> | | <u>340.82</u> | | | | <u>2.8</u> | | | <u>40</u> | <u>106</u> | <u>98</u> | <u>15</u> | |
| <u>+30</u> | <u>21.4</u> | <u>346.426</u> | | | | <u>2.8</u> | | | <u>42</u> | <u>105</u> | <u>98</u> | <u>15</u> | |
| <u>5:45</u> | | | | | | | | | | | | | |
| <u>+60</u> | | | | | | | | | | | | | |

(Net Vol. Uncorr.) _____ Avg. _____
 K-Factor: 0.5682 Stack Moisture: _____ Canister #: _____ Start: _____ "Hg vac

Nozzle Diameter: N/A " Recorded By: _____
 Barometric Pressure: 30.1 " HgA Pitot Factor: _____
 Static Pressure in Stack: +/- " H₂O

Calibration Data

| | |
|-----------------------------------|------------------------|
| Inclined Manometer | (Cal: <u>N/A</u>) |
| Magnehelic No. | (Cal: _____) |
| Pitot Tube No. | (Cal: _____) |
| Potentiometer No. <u>N0314</u> | (Cal: <u>3/24/17</u>) |
| Thermocouple No. | (Cal: _____) |
| Gas Meter No. <u>N0714</u> | (Cal: <u>3/24/17</u>) |
| Meter Corr. Factor: <u>1.0024</u> | |



Stack: Horizontal / Vertical Rectangular / Circular

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-66-

Date(s): 6/1/2017 and 7/13/2017

SOURCE TEST REQUEST FOR EQUIPMENT/ANALYSIS

| | | | |
|---------------------------------|--|-----------------------|---------|
| Company | Weber Metals | Source Test No. | 17-339 |
| Address | 16706 Garfield Avenue, Paramount, CA 90723 | Request Date | 5/4/17 |
| Basic Equipment | Furnace, Die Lubricant Area | Control Device | N/A |
| Analysis/Equipment Requested By | Eric Padilla | Date Equipment Needed | 5/11/17 |
| For Compliance, Rule(s) | | | |
| Other (specify) | Rule Development | Facility ID No. | 10966 |

Dry Ice Needed (100 POUNDS)

Laboratory No. 1712514

SAMPLE EQUIPMENT ANALYSIS REQUEST

| Equipment Requested/ID # | Analysis Requested | Set ID |
|---|--|--------|
| Three CARB 425 trains (NaHCO ₃ with back-end filter) | <i>Trains Nos 17, 22, 30</i> | |
| Two quartz probes | <i>Reference: Blue Book 41, pages 134, 135</i> | |
| Tubing (two 8' sections plus one longer) | <i>Analysis Requested: Total Chromium, hexavalent chromium, and % moisture</i> | |
| | <i>Sample Date: May 11, 2017</i> | |
| | <i>Note: We will also attempt to get a sample of the die lubricant for analysis.</i> | |
| <i>No probes returned</i> | <i>Train 17: sample, tubing, no probe</i> | |
| | <i>Train 30: sample, tubing, no probe</i> | |
| | <i>Train 22: Blank, tubing, no probe</i> | |
| <i>Recovery Samples</i> | | |
| <i>Train 17: -01</i> | <i>Cont 2: -04 Cont 3: -05 Cont 1: -11</i> | |
| <i>Train 22: -02</i> | <i>Cont 2: -06 Cont 3: -07 Cont 1: -12</i> | |
| <i>Train 30: -03</i> | <i>Cont 2: -08 Cont 3: -09 Cont 1: -13</i> | |

SAMPLE EQUIPMENT CHAIN OF CUSTODY

| Sample Equipment | From | To | For (S/T, Analysis, Cleanup, Not Used) | Date Received | Time |
|------------------------|----------------------|----------------------|--|---------------|-------|
| Trains, probes, tubing | <i>C. Schmalz</i> | <i>Philip S. ...</i> | S/T | 05/11/17 | 07:20 |
| Trains & tubing | <i>Philip S. ...</i> | <i>C. Schmalz</i> | Recovery | 05/12/17 | 08:37 |
| Recovery Samples | <i>C. Schmalz</i> | <i>Philip S. ...</i> | Analysts | 05/12/17 | 17:10 |
| | | | | | |
| | | | | | |

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-67-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr., Diamond Bar, CA 91765-4182
Page 1 of 2

**MONITORING & ANALYSIS
REPORT OF LABORATORY ANALYSIS**

| | | |
|---|-----------------------------|--------------|
| TO Mike Garibay Supervising A.Q. Engineer Source Test & Engineering | LABORATORY NO _____ | 1712514 |
| | SOURCE TEST NO _____ | 17-339 |
| SAMPLE(S) DESCRIBED AS 3 Hexavalent Chromium Trains | DATE RECEIVED _____ | 05/12/17 |
| | RULE NO _____ | NA |
| SAMPLING LOCATION Facility ID 10966 Weber Metals 16706 Garfield Ave. Paramount, CA 90723 | REQUESTED BY _____ | Eric Padilla |
| | DATE ANALYZED _____ | 5/12/2017 |
| | DATE REPORTED _____ | 5/17/2017 |

ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS

Moisture and Hexavalent Chromium by CARB 425 (Sodium Bicarbonate(NaHCO₃) solution)

| | Train 17 | Train 22 | Train 30 |
|---------------------------|----------|----------|----------|
| Moisture gain, g | 17.0 | 0.0 | 13.8 |
| Silica gel% expended | 75 | 15 | 1 |
| Filter gain, g | -0.0016 | -0.0009 | 0.0035 |
| Impinger 1 pH | 9 | 9 | 9 |
| Impinger 2 pH | 9 | 9 | 9 |
| Cr ⁺⁶ total ug | 0.51 | 0.03 | 0.01 |

Recovery Notes:

Train 17: Teflon tape severely occluded ball side of the tubing adapter.

Train 22: Field Blank. Particulates stuck to the inside of impinger walls for all 3 impingers.

Train 30: The contents of Impinger 3 had a very musty smell.

NOTE: Additional significant figures provided for calculation purposes.

Reviewed By: 
Joan Nierit, Principal A.Q. Chemist
Laboratory Services

Date Reviewed: 05/18/17

Approved By: 
Aaron Katzenstein, Ph.D.
Senior Manager
Laboratory Services
(909) 396-2219

Date Approved: 5/19/17

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-68-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Dr., Diamond Bar, CA 91765-4182
Page 2 of 2

MONITORING & ANALYSIS
REPORT OF LABORATORY ANALYSIS

LABORATORY NO 1712514

REQUESTED BY Eric Padilla

ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS
Moisture and Hexavalent Chromium by CARB 425 (Sodium Bicarbonate(NaHCO₃) solution)

QUALITY CONTROL

BALANCE CHECK

| Lab No. | Result (g) | Limit (g) | Check Status |
|--------------|------------|-----------|--------------|
| B17E093-CCV1 | 100.0002 | ±0.0005 | Pass |
| B17E093-CCV2 | 500.0 | ±0.2 | Pass |

CCV RECOVERIES

| Lab No. | Results (ppt) | Limit (%) | % Recovery |
|--------------|---------------|-----------|------------|
| S17E037-CCV1 | 101 | 90-110 | 101 |
| S17E037-CCV2 | 101 | 90-110 | 101 |
| S17E037-CCV3 | 103 | 90-110 | 103 |
| S17E037-CCV4 | 102 | 90-110 | 102 |
| S17E037-CCV5 | 100 | 90-110 | 100 |

REF B17E093
S17E037

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-69-

Date(s): 6/1/2017 and 7/13/2017

APPENDIX E

Equipment Calibrations

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-70-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
DRY GAS METER CALIBRATION WORKSHEET

Page 3

DATE : March 24, 2017
PERFORMED BY: W. Stredwick

DRY GAS METER COEFFICIENT CALCULATIONS

STANDARD DRY GAS METER ID#: 7812470
With Coefficient of 1.0000

DRY GAS METER N0714

| TRIAL | CFM | U/C FlowRate | TEMP | H2O Corrected FlowRate | U/C TEMP FlowRate | H2O Corrected FlowRate | COEF | AVE: | OVERALL |
|-------|-----|-----------------|------|---------------------------|----------------------|---------------------------|--------|--------|---------|
| 1 | 1/4 | 0.3168 | 74 | 1.2 0.3089 | 0.3188 | 74 0.8 0.3105 | 0.9950 | 0.9960 | 1.0024 |
| 2 | 1/4 | 0.3158 | 74 | 1.2 0.3079 | 0.3158 | 74 0.8 0.3076 | 1.0010 | | |
| 3 | 1/4 | 0.3158 | 74 | 1.2 0.3079 | 0.3186 | 74 0.8 0.3103 | 0.9922 | | |
| 1 | 1/2 | 0.5311 | 74 | 2.8 0.5198 | 0.5316 | 74 1.88 0.5192 | 1.0012 | 1.0145 | |
| 2 | 1/2 | 0.5283 | 74 | 2.8 0.5172 | 0.5267 | 74 1.88 0.5144 | 1.0053 | | |
| 3 | 1/2 | 0.5472 | 74 | 2.8 0.5356 | 0.5289 | 74 1.88 0.5165 | 1.0369 | | |
| 1 | 3/4 | 0.7782 | 74 | 5.2 0.7662 | 0.7843 | 74 3.6 0.7692 | 0.9960 | 0.9986 | |
| 2 | 3/4 | 0.7846 | 74 | 5.2 0.7725 | 0.7879 | 74 3.6 0.7727 | 0.9997 | | |
| 3 | 3/4 | 0.7861 | 74 | 5.2 0.7740 | 0.7890 | 74 3.6 0.7739 | 1.0002 | | |
| 1 | 1 | 1.0097 | 74 | 9 1.0033 | 1.0157 | 74 6.05 1.0021 | 1.0012 | 1.0006 | |
| 2 | 1 | 1.0096 | 74 | 9 1.0032 | 1.0177 | 74 6.05 1.0041 | 0.9991 | | |
| 3 | 1 | 1.0130 | 74 | 9 1.0066 | 1.0189 | 74 6.05 1.0052 | 1.0013 | | |

CORRECTION FACTOR: 1.0024

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-71-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
DRY GAS METER CALIBRATION WORKSHEET

DATE: 5/23/2017

PERFORMED BY:
W. Stredwick

DRY GAS METER COEFFICIENT CALCULATIONS

DRY GAS METER ID : N0715

| TRIAL | CFM | U/C FlowRate | TEMP | H2O | Corrected FlowRate | U/C FlowRate | TEMP | H2O | Corrected FlowRate | COEF | AVE: | OVERALL |
|-------|-----|-----------------|------|-----|-----------------------|-----------------|------|-------|-----------------------|--------|--------|---------|
| 1 | 1/4 | 0.2976 | 74 | 1.1 | 0.2904 | 0.2969 | 74 | 0.7 | 0.2894 | 1.0032 | 0.8697 | 0.9910 |
| 2 | 1/4 | 0.1764 | 74 | 1.1 | 0.1721 | 0.2948 | 74 | 0.7 | 0.2874 | 0.5988 | | |
| 3 | 1/4 | 0.2959 | 74 | 1.1 | 0.2887 | 0.2941 | 74 | 0.7 | 0.2867 | 1.0072 | | |
| 1 | 1/2 | 0.5498 | 74 | 2.2 | 0.5380 | 0.5351 | 74 | 1.975 | 0.5233 | 1.0280 | 1.0278 | |
| 2 | 1/2 | 0.5500 | 74 | 2.2 | 0.5381 | 0.5350 | 74 | 1.975 | 0.5232 | 1.0286 | | |
| 3 | 1/2 | 0.5496 | 74 | 2.2 | 0.5377 | 0.5355 | 74 | 1.975 | 0.5237 | 1.0268 | | |
| 1 | 3/4 | 0.7928 | 74 | 5.6 | 0.7822 | 0.7697 | 74 | 3.85 | 0.7561 | 1.0345 | 1.0347 | |
| 2 | 3/4 | 0.7907 | 74 | 5.6 | 0.7800 | 0.7678 | 74 | 3.85 | 0.7543 | 1.0342 | | |
| 3 | 3/4 | 0.7907 | 74 | 5.6 | 0.7801 | 0.7668 | 74 | 3.85 | 0.7533 | 1.0355 | | |
| 1 | 1 | 1.0267 | 74 | 9.6 | 1.0227 | 1.0046 | 74 | 6.55 | 0.9934 | 1.0295 | 1.0317 | |
| 2 | 1 | 1.0289 | 74 | 9.6 | 1.0249 | 1.0033 | 74 | 6.55 | 0.9921 | 1.0331 | | |
| 3 | 1 | 1.0302 | 74 | 9.6 | 1.0262 | 1.0052 | 74 | 6.55 | 0.9939 | 1.0324 | | |

DRY GAS METER ID : N0715

CORRECTION FACTOR: 0.9910

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-74-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
DATA SHEET FOR THERMOCOUPLE/POTENTIOMETER CALIBRATION

Field Meter STQC# : N0314 + N0315
 Ref. Thermometer # : ASTM 08343
 Temperature Source(s) : JOKA FURNACE

Date: 3-24-17
 Calibration By: LS
 Calibration Period:
 Semiannual X
 Bimonthly _____
 Other _____

| Temp.* | A | N0314 Lead Wire STQC# | | | | N0315 Lead Wire STQC# | | | | COMMENTS |
|--------|-----|--------------------------|------|------------------|------|--------------------------|------|------------------|------|----------|
| | | B | | (B-A)100 A ** | | B | | (B-A)100 A ** | | |
| | | Ch#1 | Ch#2 | Ch#1 | Ch#2 | Ch#1 | Ch#2 | Ch#1 | Ch#2 | |
| 10102 | 32 | 32 | 32 | | | 32 | 32 | | | |
| 20108 | 33 | 33 | 33 | | | 33 | 33 | | | |
| 50111 | 33 | 33 | 33 | | | 33 | 33 | | | |
| 20202 | 33 | 33 | 33 | | | 33 | 33 | | | |
| 60112 | 33 | 33 | 33 | | | 33 | 32 | | | |
| 10102 | 211 | 211 | 212 | | | 212 | 212 | | | |
| 20108 | 211 | 211 | 211 | | | 211 | 211 | | | |
| 50111 | 211 | 211 | 211 | | | 211 | 211 | | | |
| 20202 | 212 | 215 | 214 | | | 212 | 212 | | | |
| 60112 | 212 | 211 | 211 | | | 212 | 211 | | | |
| 10102 | 612 | 611 | 612 | | | 611 | 611 | | | |
| 20108 | 611 | 610 | 611 | | | 612 | 611 | | | |
| 50111 | 612 | 611 | 611 | | | 612 | 612 | | | |
| 20202 | 611 | 611 | 611 | | | 612 | 612 | | | |
| 60112 | 612 | 612 | 611 | | | 612 | 611 | | | |

* All temperatures are in degrees F.
 **Percent (%) difference should not exceed +/- 1.5%.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-75-

Date(s): 6/1/2017 and 7/13/2017

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
DATA SHEET FOR THERMOCOUPLE/POTENTIOMETER CALIBRATION

Field Meter STQC# : N0314 + N0315
 Ref. Thermometer # : ASTM 08343
 Temperature Source(s) : JOKA FURNACE

Date: 3-24-17
 Calibration By: WS
 Calibration Period:
 Semiannual X
 Bimonthly _____
 Other _____

N0314

N0315

| Temp.* | Lead Wire STQC# | | | | Lead Wire STQC# | | | | COMMENTS | |
|--------|-----------------|------|------|------------------|-----------------|------|------|------------------|----------|------|
| | A | B | | (B-A)100 A ** | | B | | (B-A)100 A ** | | |
| | Ref. Temp. | Ch#1 | Ch#2 | Ch#1 | Ch#2 | Ch#1 | Ch#2 | Ch#1 | | Ch#2 |
| 10102 | 32 | 32 | 32 | | | 32 | 32 | | | |
| 20108 | 33 | 33 | 33 | | | 33 | 33 | | | |
| 50111 | 33 | 33 | 33 | | | 33 | 33 | | | |
| 20202 | 33 | 33 | 33 | | | 33 | 33 | | | |
| 60112 | 33 | 33 | 33 | | | 33 | 32 | | | |
| 10102 | 211 | 211 | 212 | | | 212 | 212 | | | |
| 20108 | 211 | 211 | 211 | | | 211 | 211 | | | |
| 50111 | 211 | 211 | 211 | | | 211 | 211 | | | |
| 20202 | 212 | 215 | 214 | | | 212 | 212 | | | |
| 60112 | 212 | 211 | 211 | | | 212 | 211 | | | |
| 10102 | 612 | 611 | 612 | | | 611 | 611 | | | |
| 20108 | 611 | 610 | 611 | | | 612 | 611 | | | |
| 50111 | 612 | 611 | 611 | | | 612 | 612 | | | |
| 20202 | 611 | 611 | 611 | | | 612 | 612 | | | |
| 60112 | 612 | 612 | 611 | | | 612 | 611 | | | |

* All temperatures are in degrees F.

**Percent (%) difference should not exceed +/- 1.5%.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-76-

Date(s): 6/1/2017 and 7/13/2017

APPENDIX F
Copy of Furnace Permits

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-77-

Date(s): 6/1/2017 and 7/13/2017

Furnace No. 337

Section D Page 34
Facility ID#: 10966
Revision #: 7
Date: June 30, 2017

**FACILITY PERMIT
WEBER METALS INC.**

PERMIT TO OPERATE

**Permit No. G40157
A/N 580278**

Equipment Description:

Pre-Heat Furnace, Rotary Hearth Type, Titanium Billets, Custom Made, 26'-0" Dia. x 7'-0" H., with Eight Bloom Engineering Model 1480-035 Natural Gas-Fired Burners, 12 MMBTU/hr Total.

Conditions:

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
[Rule 204]
2. This equipment shall be properly maintained and kept in good operating condition at all times.
[Rule 204]
3. The NO_x concentration, on a dry basis corrected to 3% oxygen, shall not exceed 40 parts per million by volume (ppmv).
[Rule 1303(a)(1)-BACT, Rule 1303(b)(2)-Offsets]
4. A non-resettable totalizing gas meter shall be installed and maintained in the fuel supply line to the furnace.
[Rule 1303(b)(2)-Offsets; Rule 1401; Rule 3004(a)(4)-Periodic Monitoring]
5. The amount of natural gas fuel consumed by this furnace and those furnaces associated with Permits to Operate 580276, 580277 and 580279 shall not exceed 7,678,000 standard cubic feet in any one calendar month.
[Rule 1303(b)(2)-Offsets; Rule 1401]
6. Metal contaminated with rubber, plastics, paper, rags, oil, grease, or similar smoke-producing material shall not be charged to this furnace.
[Rule 401, Rule 1303(a)(1)-BACT]
7. Records shall be maintained to demonstrate compliance with conditions 3 and 5. The records shall be kept on file for at least the last five years and be made available to SCAQMD personnel upon request.
[Rule 1303(b)(2)-Offsets; Rule 1401; Rule 3004(a)(4)-Periodic Monitoring]

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-78-

Date(s): 6/1/2017 and 7/13/2017

Section D Page 35
Facility ID #: 10966
Revision #: 7
Date: June 30, 2017

**FACILITY PERMIT
WEBER METALS INC.**

Emissions And Requirements:

8. This equipment is subject to the applicable requirements of the following rules and regulations:
CO: 2000 PPMV, Rule 407
PM: 0.1 GR/SCF, Rule 409
PM: Rule 404, See Appendix B for emission limits

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-79-

Date(s): 6/1/2017 and 7/13/2017

Furnace No. 339

**FACILITY PERMIT
WEBER METALS INC.**

PERMIT TO OPERATE

**Permit No. G40158
A/N 580279**

Equipment Description:

Pre-Heat Furnace No. 3, Box Type, Aluminum And Titanium Billets, Thorpe Technologies, Inc., Custom, 34'-0" W. x 23'-0" L. x 18'-0" H., with Two Bloom Engineering Model 1480-030 Burners And Four Bloom Engineering Model 1480-035 Burners, Natural Gas-Fired, 8.54 MMBTU/hr Total.

Conditions:

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
[Rule 204]
2. This equipment shall be properly maintained and kept in good operating condition at all times.
[Rule 204]
3. The NOx concentration, on a dry basis corrected to 3% oxygen, shall not exceed 40 parts per million by volume (ppmv).
[Rule 1303(a)(1)-BACT, Rule 1303(b)(2)-Offsets]
4. A non-resettable totalizing gas meter shall be installed and maintained in the fuel supply line to the furnace.
[Rule 1303(b)(2)-Offsets; Rule 1401; Rule 3004(a)(4)-Periodic Monitoring]
5. The amount of natural gas fuel consumed by this furnace and those furnaces associated with permits to operate 580276, 580277 and 580278 shall not exceed 7,678,000 standard cubic feet in any one calendar month.
[Rule 1303(b)(2)-Offsets; Rule 1401]
6. Metal contaminated with rubber, plastics, paper, rags, oil, grease, or similar smoke-producing material shall not be charged to this furnace.
[Rule 401, Rule 1303(a)(1)-BACT]
7. Records shall be maintained to demonstrate compliance with conditions 3 and 5. The records shall be kept on file for at least the last five years and be made available to SCAQMD personnel upon request.
[Rule 1303(b)(2)-Offsets; Rule 1401; Rule 3004(a)(4)-Periodic Monitoring]

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 17-339, 17-341 and 17-343

-80-

Date(s): 6/1/2017 and 7/13/2017

Section D Page 37
Facility LD #: 10966
Revision #: 7
Date: August 12, 2017

**FACILITY PERMIT
WEBER METALS INC.**

Emissions And Requirements:

8. This equipment is subject to the applicable requirements of the following rules and regulations:
CO: 2000 PPMV, Rule 407
PM: 0.1 GR/SCF, Rule 409
PM: Rule 404, See Appendix B for emission limits