

FORM 3B: Periodic Monitoring Recordkeeping Form For Portable Analyzers

SCAQMD RULES 1146 & 1146.1 Emissions of Oxides of Nitrogen from Industrial, Institutional and Commercial Boilers, Steam Generators, and Process Heaters

DATE:		TIME (start/s	stop):	1	NAME:					
FACILITY NAME:					ANALYZER (Make/	ANALYZER (Make/Model):				
Facility ID Number:					Analyzer S/N:	Analyzer S/N:				
Boiler Name:					Date of Last Stability	Date of Last Stability Check ¹ :				
Permit to Operate:					Date of Last Lineari	Date of Last Linearity Check ² :				
Application No.:						Stability check must be conducted within 12 months of test date Linearity check must be conducted within 12 months of test date				
"As Found" Test Resu		Date:		Calibration Result	Calibration Results					
Time Start:			Ambient Tem (°F):	perature	Date of Pre-Test Ca	Date of Pre-Test Calibration:				
Time End:					Date of Post-Test Calibration:					
Constituent	CO (ppm)	NO (ppm)	NO ₂ (ppm)	O ₂ (%)	Constituent	CO (ppm)	NO (ppm)	NO ₂ (ppm)	O ₂ (%)	
Measured, C _{MEAS*}	(PP)	(PP)	(ррш)	(70)	Pre-Test Zero	(pp)	(pp)	(рріп)	(70)	
Cal Adjusted, C _{CORR}					Post-Test Zero					
Example					Mean Zero, C _{CZ}					
Calculation: C_{ADJ}	C_{CZ} $\times \left(\frac{C}{C_{CM}}\right)$	CAL -C-		Span Gas, C _{CAL}						
		Ç-CM	-(2)		Pre-Test Span					
			Boiler Operati	ng Conditions:	Post-Test Span					
Constituent	CO (ppm)	NO _x (ppm)			Mean Span, C _{CM}					
C _{ADJ} @ 3% O ₂ , N	(ррш)	(ррпі)	1		Drift, %					
Compliance Limit			1		Drift Calculation is li	sted in Section 3.6	6, Periodic Mon	itoroing Protoco		
Difference							,	J		
"As Left" Test Results (If applicable) Date:						Describe any boiler or control system maintenance or tuning conducted after the "As Found" Test to bring the boiler into compliance (attach additional documentation as				
Time Start:			Ambient Tem (°F):	perature	necessary):	g the boner into oc	mphanoo (allac	on additional doc	amontation do	
Time End:										
Constituent	CO (ppm)	NO (ppm)	NO ₂ (ppm)	O ₂ (%)						
Measured, C _{MEAS*}										
Cal Adjusted, C _{ADJ}			Boiler Operati	ng Conditions:	_					
Occastituant	СО	NO _x	Boiler Operati	rig Coriditions.						
Constituent	(ppm)	(ppm)								
C _{ADJ} @ 3% O ₂ , N										
Compliance Limit			_							
Difference										
* Attach printouts from t	the portable	analyzer or t	he manual reco	ord of constituent co	oncentrations during the tes	<u>t.</u>				
					cordance with this protocol, ource at the time of this tes		statements and	information con	tained in this	
Test Conducted By					Signature	Signature				
Titlo				Data						