



Rule 1109.1 – NO_x Emission Reduction for Refinery Equipment

Working Group Meeting #10
February 18, 2020

Call-in Information

Call-in Number: 1-866-705-2554

Meeting Number: 219723

Agenda

2



Summary of Working Group Meeting #9

Progress of Rule Development

Updates from Last Working Group Meeting

BARCT Assessments for Gas Turbines, FCCU, and SRU/TGI

Next Steps

Progress of Rule Development

3

Summary of Working Group #9 (12/12/19)

- John Zink Hamworthy Presentation on SOLEX™ Burner Technology
- Discussed potential SOx RECLAIM sunset
- Baseline emission calculations
- U.S. EPA SCR cost spreadsheet revision
- Proposed BARCT limits for Heater and Boiler categories

Since Last Working Group Meeting


- Adjusted cost-effectiveness calculations to reflect stakeholder comments
- Discussions with consultants
- Stakeholder meetings and site visits
- Discussions with control technology suppliers
- ClearSign Core™ Demonstration Project Update

- Some stakeholders expressed concern of co-pollutant impacts due to ammonia from SCRs
- Primary concern is sulfur in the fuel gas
 - Some facilities already remove sulfur from fuel gas
- Staff needs to gather data to understand full scope of the issue for impacted facilities
- Sending out a survey to gather the following information:
 - Current sulfur concentration in the fuel gas system(s)
 - Number and type of existing treatment system(s)
 - Volume of gas treated
 - Anticipated upgrades and/or additional units required
 - Any potential NOx emissions increase associated with upgrades or expansions
 - Cost of gas clean up to meet Rule 431.1 sulfur limit


SOx/PM Survey

ClearSign Core™ Demonstration Project Update

- ClearSign Core™ burner technology was retrofitted in a multi-burner process heater
- Initial tests showed NOx emissions less than 4 ppm with natural gas
- Initial results showed burner-to-burner interaction limited the maximum firing capacity of the heater
- Decision was made to reinstall the original burners and temporarily suspend field test
- Further offsite product refinement and demonstration ongoing to address issue
- Seeking to resume field demonstration later this year



Areas of Discussion on Cost-Effectiveness Calculation



Cost-Effectiveness Calculation - Burner Cost

7

- Combination of SCR and Ultra-Low NOx Burners (ULNB) can achieve 2 ppm
- Units that require >95% NOx reduction will require burner control
- Staff proposed the following burner cost:
 - <40 MMBtu/hr - \$2.2MM/unit
 - ≥40 MMBtu/hr - \$2.8MM/unit

Background¹

Stakeholders Comment

- Scale burner cost based on heater size – similar to SCR power curve relationship


- Staff agrees

Staff Response


¹. Staff proposal from Working Group Meeting #9.

Cost-Effectiveness Calculation – Burner Cost (*con't*)

- Facilities provided cost for 13 burner installations
 - Cost ranged from \$1.6MM to \$9.8 MM
 - Power curve generated based on \$ per MMBtu/hr
- Based on the power curve, burner cost is:
 - $y = \$23,137 (150/x)^{0.892}$




Burner Total Installed Cost Based on Unit Size



*Curve generated from 13 estimated burner costs provided by facilities (some points represent multiple units)

Cost-Effectiveness Calculation – LCF versus DCF

10



Cost-Effectiveness Calculation – NO_x Concentration

11

- Staff proposed back-calculating NO_x emissions based on Annual Emission Reported (AER) value (annual mass)

Background

Stakeholders Comment


- Back-calculated emissions did not agree with survey due to the use of “actual” versus “dry standard” cubic feet/minute (acfm versus scfm)

- Use NO_x concentration as reported in survey (CEMS annual average) and mass emissions as reported in AER
 - Example calculation on next slide


Staff Response

Cost-Effectiveness Calculation – NOx Concentration (*con't*)

- Survey NOx Concentration (CEMS annual average) = **23.3 ppm**
 - Percent reduction to achieve 2 ppm = **91.4%**
 - ✓ Technically feasible with SCR only
 - Annual emissions (AER) = **5.31 tpy**
 - Emission reductions
$$5.31 \text{ tpy} \times 91.4\% = 4.85 \text{ tpy}$$



Cost-Effectiveness Calculation – Facility versus Spreadsheet Cost Estimates for SCR



Cost-Effectiveness Calculation – Facility versus Spreadsheet Cost Estimates

- Some units are have much higher costs due to challenging retrofits
- Cost curve cannot account for outliers
 - Retrofit factor in EPA SCR spreadsheet designed to address outliers

Comparison of facility supplied Total Install Costs (TIC) and Operations and Maintenance Costs (O&M) versus costs generated from modified U.S. EPA SCR spreadsheet

Size (MMBtu/hr)	Facility TIC	EPA TIC	Facility O&M	EPA O&M
67	\$7 MM	\$8 MM	\$140 M	\$99 M
91	\$8 MM	\$9 MM	\$140 M	\$120 M
135	\$11.8 MM	\$11 MM	\$140 M	\$140 M
173	\$22.2 MM	\$13 MM	\$170 M	\$220 M
340	\$17 MM	\$18 MM	\$160 M	\$370 M
527	\$32 MM	\$22 MM	\$160 M	\$370 M

Staff Adjustments to Cost-Effectiveness Calculation

15

Developed cost curve to estimate burner replacement costs

```
graph TD; A[Developed cost curve to estimate burner replacement costs] --> B[Used actual facility cost estimates when available]; B --> C[Used NOx concentration from survey to calculate percent reduction and applied to mass emissions from AER]; C --> D[Recalculated based on DCF];
```

Used actual facility cost estimates when available


Used NO_x concentration from survey to calculate percent reduction and applied to mass emissions from AER

Recalculated based on DCF

Revised Cost-Effectiveness Analysis for Heaters and Boilers

16


- Staff revised the cost-effectiveness calculations for each heater/boiler category presented in Working Group Meeting #9



- Following slides details the changes to the cost-effectiveness and staff recommended NOx concentrations limits
- Staff still evaluating outliers and units with existing SCR

Revised Cost-Effectiveness Analysis for Heaters and Boilers (cont.)

Revised cost and emissions resulted in some cost increases and some cost decreases



* NOx concentration from survey lower than back-calculated value

1. Lower emission reductions increased cost-effectiveness values
2. For some units, the recalculated SCR removal efficiency could achieve proposed NOx limit without the need/cost of burner replacement

Heaters <40 MMBtu/hr using Refinery Gas

Revised cost-effectiveness analysis (cont.)

Presented at WGM #9

Cost-Effectiveness Analysis for 9 ppm (Heaters <40 MMBtu/hr Using Refinery Gas)

Cost-Effectiveness at 9 ppm

Heater Category	Burners Replaced Before Useful Life	Burners Replaced After Useful Life
<20 MMBtu/hr	\$98,017	No cost increase, possibly savings
20 to 40 MMBtu/hr	\$48,746	

- Evaluation of 9 ppm using refinery gas
 - Based on emerging technologies: ClearSign or SOLEX
 - Implementation schedule will need to account for technology development
- Evaluated two heater sizes:
 - < 20 MMBtu/hr
 - 20 to 40 MMBtu/hr
- For each of the heater sizes, evaluated two scenarios:
 - Burner replacement before useful life
 - Burner replacement after useful life, if replacement before useful life is not cost-effective
- Assumptions
 - ClearSign is <\$1 MM
 - Used cost based on traditional low-NOx burner ~\$2.2 MM (conservative assumption)
 - Assumed 25 years useful life

Revised Cost-Effectiveness at 9 ppm

Heater Category	Burners Replaced <i>Before</i> Useful Life	Burners Replaced <i>After</i> Useful Life
<20 MMBtu/hr	\$212,421 (14 units)	Potential additional cost beyond what the facility will already incur
20 to 40 MMBtu/hr	\$77,664* (36 units)	

* No longer cost-effective, changed recommendation

Revised Staff Recommendation:

- 9 ppm at end of burner useful life for all heaters <40MMBtu/hr
 - ✓ Assess maturity of emerging technology, an implementation schedule will be established

Heaters >40 ppm, <40 MMBtu/hr using Refinery Gas

Revised cost-effectiveness analysis (cont.)

Presented at WGM #9

Cost-Effectiveness Analysis for 30 ppm (Heaters >40 PPM, <40 MMBtu/hr Using Refinery Gas)

Cost-Effectiveness at 30 ppm

Heater Category	NOx Limit 30 ppm
<20 MMBtu/hr	\$525,603
20 to 40 MMBtu/hr	\$20,558

- Most heaters are achieving NOx concentration <40 ppm
- Three heaters with NOx concentrations > 40 ppm
 - 2 heaters are < 20 MMBtu/hr
 - 1 heater is 20 to 40 MMBtu/hr
- Commercially proven low-NOx burners can achieve < 30 ppm
 - Burner manufacturers will guarantee 30 ppm using refinery gas
- Evaluated cost-effectiveness of interim NOx concentration limit of 30 ppm for heaters currently > 40 ppm for two heater sizes:
 - < 20 MMBtu/hr
 - 20 to 40 MMBtu/hr
- Assumptions
 - Average cost for burners is \$2.2 MM
 - Assumed 25 years useful life

41

Revised Cost-Effectiveness at 30 ppm

Heater Category	30 ppm
<20 MMBtu/hr	\$276,058 (2 units)
20 to 40 MMBtu/hr	\$50,109 (1 unit)

Maintain Staff Recommendation:

- 30 ppm for heaters 20 to 40 MMBtu/hr
- 9 ppm at end of useful life
 - ✓ Assess maturity of emerging technology, an implementation schedule will be established

Heaters >40 MMBtu/hr using Refinery Gas

Revised cost-effectiveness analysis (cont.)

Presented at WGM #9

Cost-Effectiveness Analysis for 2 ppm (Heaters ≥40 MMBtu/hr Using Refinery Gas)

Cost-Effectiveness at 2 ppm

Heater Category	2 ppm
≥40 to 110 MMBtu/hr	\$48,892
>110 MMBtu/hr	\$40,682

- Burner costs included for units requiring >95% reduction from SCR
 - \$2.8MM/unit for installation of ULNB
 - ULNB can achieve < 30 ppm
 - 14 units will require burner upgrades
- Cost-effectiveness calculated using U.S. EPA cost spreadsheet
 - Average cost-effectiveness of all heaters >40 MMBtu/hr < \$50,000/ton NOx reduced
 - Units with existing SCR (37) not included in cost-effectiveness calculation
 - Assume new catalyst(s), ammonia injection grid upgrades, and tuning can improve removal efficiency
 - Will not require complete SCR retrofit installation
 - Cost will be less than a complete retrofit installation
 - Staff still evaluating costs and potential reductions for units with existing SCRs

48

Revised Cost-Effectiveness at 2 ppm

Heater Category	2 ppm
≥40 to 110 MMBtu/hr	\$56,366 (44 units)
>110 MMBtu/hr	\$39,857 (33 units)

Maintain Staff Recommendation:

- 2 ppm for heaters >40 MMBtu/hr
- Outliers and units with existing SCR currently being evaluated

Boilers <40 MMBtu/hr using Natural Gas

- Working Group Meeting #9, staff evaluated 2 ppm, 5 ppm and 9 ppm NOx limits for boilers <40 MMBtu/hr
 - All boilers <40 MMBtu/hr fueled by natural gas
 - 2 ppm not cost-effective
 - 9 ppm achieved in practice
 - Considered 5 ppm using Solex™
 - John Zink indicated the Solex burner is not applicable to boilers but commercially available burner technology currently can achieve 5 ppm on natural gas

Boilers <40 MMBtu/hr using Natural Gas

Revised cost-effectiveness analysis (cont.)

Presented at WGM #9

Cost-Effectiveness Analysis for 2, 5, and 9 ppm (Boilers <40 MMBtu/hr, Natural Gas)

Cost-Effectiveness at 2, 5, and 9 ppm

Boiler Category	2 ppm	5 ppm*	9 ppm
<20 MMBtu/hr	\$167,149	No additional Cost	\$55,563
20 to 40 MMBtu/hr	\$42MM	No additional Cost	\$0 Achieved

* After burner useful life

- Combination of SCR (95% reduction) and ULNB (< 30 ppm) can achieve 2 ppm
 - SCR cost-estimates based on U.S. EPA cost spreadsheet with adjustments (previous slides)
- Evaluation of 5 ppm based on burner replacement after burner reaches useful life
- Evaluation of 9 ppm using natural gas based on use of LNB
- Evaluated two heater sizes:
 - < 20 MMBtu/hr
 - 20 to 40 MMBtu/hr
- Assumptions
 - Used cost based on traditional LNB burner ~\$2 MM
 - Assumed 25 years useful life

57

Revised Cost-Effectiveness at 2 and 5 ppm

Boiler Category	2 ppm	5 ppm	5 ppm <i>after</i> useful life
<20 MMBtu/hr	\$93,604 (2 units)	\$67,983	Potential additional cost beyond what the facility will already incur
20 to 40 MMBtu/hr	\$512,110 (2 units)	\$413,055	

Maintain Staff Recommendation:

- 5 ppm at end of burner useful life, keep current permit limit

Boilers ≥40 MMBtu/hr Using Refinery Gas

Revised cost-effectiveness analysis (cont.)

Presented at WGM #9

Cost-Effectiveness Analysis for 2 ppm (Boilers ≥40 MMBtu/hr Using Refinery Gas)

- Burner costs included for units requiring >95% reduction from SCR
 - \$2.8MM/unit
 - NOx reduced to 30 ppm
 - 8 boilers will require burner upgrades
- Cost-effectiveness calculated using U.S. EPA cost spreadsheet
 - Average cost-effectiveness for all boilers ≥ 40 MMBtu/hr < \$50,000/ton NOx reduced
 - Units with existing SCR (7) not included in cost-effectiveness analysis
 - Assume new catalyst(s), ammonia injection grid upgrades, and tuning can improve removal efficiency
 - Will not require complete SCR retrofit installation
 - Cost will be less than a complete retrofit installation
 - Staff still evaluating cost and potential reductions for units with existing SCR

65

Cost-Effectiveness at 2 ppm

Heater Category	2 ppm
≥40 to 110 MMBtu/hr	\$36,578
>110 MMBtu/hr	\$31,461

Revised Cost-Effectiveness at 2 ppm

Boiler Category	2 ppm
≥40 to 110 MMBtu/hr	\$50,042 (2 units, 1 standby not included)
>110 MMBtu/hr	\$19,286 (11 units)

Maintain Staff Recommendation:

- 2 ppm for boilers ≥40 MMBtu/hr

Summary of Proposed BARCT Limits for Boilers and Heaters

24

Proposed BARCT NOx Limit for Heaters

25

Size (MMBtu/hr)	Proposed BARCT NOx Limit*	Revised Cost-Effectiveness
<20	40 ppm ¹ /9 ppm ²	\$0/Potential additional cost
20 to 40	30 ppm/9 ppm ²	\$50,109/Potential additional cost
≥40 to 110	2 ppm	\$56,366
>110	2 ppm	\$39,857

1. Two units > 40 ppm – not cost- effective to retrofit (no action required)
2. Future effective limit of 9 ppm at end of burner useful life (technology forcing based on emerging technologies)

Proposed BARCT NOx Limit for Boilers

26

Size (MMBtu/hr)	Proposed BARCT NOx Limit	Revised Cost-Effectiveness
<20	5 ppm ¹	Potential additional cost
20 to 40	5 ppm ¹	Potential additional cost
≥40 to 110	2 ppm	\$50,042
>110	2 ppm	\$19,286


¹ Staff proposing a future effective limit at end of burner useful life due to high cost-effectiveness. Commercially available burner technology can achieve 5 ppm.



Gas Turbines Assessment

Gas Turbines Categories

28



Technical Feasibility for Gas Turbines

- Combination of dry-low NO_x (DLN) combustor and SCR can achieve 2 ppm with proper engineering and design
- DLN combustors can achieve:
 - 9 – 25 ppm fired with natural gas
 - 10 – 27.5 ppm fired with refinery gas (~10% higher NO_x emissions)
- SCR can achieve ~95% NO_x reduction
- 2015 BARCT Assessment and Norton report concurred a 2 ppm NO_x limit is technically feasible

Gas Turbines Fired with Natural Gas


30

Technical Feasibility for Gas Turbines (Natural Gas)

- Recent BARCT Assessments for combined cycle gas turbines fired with natural gas established 2 ppm
 - Rule 1134 – Emissions of Oxides of Nitrogen from Stationary Gas Turbines
 - Rule 1135 – Emissions of Oxides of Nitrogen from Electricity Generating Facilities
- Both gas turbines fired with natural gas have existing SCRs and CO catalysts
 - Average NOx removal efficiency of existing SCRs is 94%
 - Both units currently achieving < 2 ppm NOx

Gas Turbines Assessment (Natural Gas)

32



Cost-Effectiveness for 2ppm (Gas Turbines with Natural Gas)

Cost-Effectiveness at 2 ppm

2 ppm with SCR

\$0/Achieved-in-practice

- All existing natural gas units achieving 2 ppm

Staff BARCT Recommendation:

- 2 ppm for Gas Turbines using Natural gas
 - ✓ Achieved-in-practice

Gas Turbines Fired with Refinery Gas


34

Technical Feasibility for Gas Turbines (Refinery Gas)

- All gas turbines have existing SCRs and CO catalysts with the following characteristics:
 - SCR NO_x removal efficiency: 70 - 89%
 - Catalysts age range: 1–12 years
 - Catalyst beds range: 1 - 2
- NO_x removal efficiency can be improved by:
 - SCR upgrades (e.g., ammonia injection grid, catalyst, additional catalyst beds)
 - Possibility of combustor upgrade (10 – 27.5 ppm)
- Combination of DLN combustor and maximized SCR removal efficiency can achieve 2 ppm NO_x
- 2 ppm achieved-in-practice with refinery gas (DLN combustor and SCR) based on stack test

Gas Turbine Assessment (Refinery Gas)

36



Initial BARCT NO_x Limits for Cost-Effectiveness for Gas Turbines (Refinery Gas)

37

2 ppm

Upgrade existing
SCR to achieve 95%
reduction

OR

Upgrade existing
SCR and DLN
combustor

Potential NO_x BARCT
Emission Limit

Total NO_x emission is 1.41 tpd

Cost-Effectiveness for 2 ppm (Gas Turbines with Refinery Gas)

Cost-Effectiveness at 2 ppm

2 ppm with SCR

\$35,573


- SCR upgrades are most cost-effective option to achieve 2 ppm
- Cost-effectiveness analysis based on new SCR installation (worse-case cost assumption)
 - Used U.S. EPA cost model with a 20% increase for labor costs (SB54)
 - Did not use modified cost curve (reflects costs for heaters/boilers)

Staff Recommendation:

2 ppm for Gas Turbines using Refinery Gas

Gas Turbine Assessment (Refinery Gas)

39



Cost-Effectiveness for Gas Turbines

40

Natural Gas
at 2 ppm

Cost-Effectiveness:
\$0, Achieved

Staff Recommendation:
2 ppm

Refinery Gas
at 2 ppm

Cost-Effectiveness:
\$35,573

Staff Recommendation:
2 ppm

Staff BARCT Recommendation:

- 2 ppm for Gas Turbines

Gas Turbine Summary

Proposing 2 ppm NOx limit for all gas turbines

- Natural Gas and Refinery Gas
- Achieved-in-practice, technically feasible, and cost-effective

Considerations


- Averaging Time
- Ammonia limit
 - ✓ Some units currently have 20 ppm ammonia permit limit



FCCU Assessment

FCCU Categories

43




Technical Feasibility of 2 ppm for FCCU

- Three technologies identified for NOx control in FCCU applications
 - DeNOx additive
 - ~45% reduction dependent on configuration
 - LoTOx
 - 95% reduction
 - One FCCU installation at Marathon, Texas City
 - SCR
 - 95% reduction
- 2 ppm is technically feasible with SCR
 - One existing FCCU
 - One planned FCCU retrofit (SCR) engineered for 2 ppm


FCCU Assessment

45



Initial BARCT NO_x Limits for Cost-Effectiveness for FCCU

46



Total NO_x emission for is 0.67 tpd

Cost-Effectiveness for FCCU

Cost-Effectiveness at 2 ppm

2 ppm with SCR

\$36,509

- Evaluated cost-effectiveness for all units not achieving 2 ppm
- Cost estimates:
 - Facilities provided two capital cost estimates (\$57 MM and \$19.5 MM)
 - Staff used those data points to estimate costs for other units
 - Scaled cost based on flow rate
 - Annual O&M Cost assumed 0.5% of Total Capital Investment Cost
 - Consistent with boilers/heaters estimates
- Cost based on new SCR installation
 - Units with existing SCR could optimize SCR to achieve reductions

Staff Recommendation:

2 ppm for FCCU

Cost-Effectiveness for FCCU

48

FCCU
at 2 ppm

Cost-Effectiveness:
\$36,509

Recommendation:
2 ppm

Staff Recommendation:

- 2 ppm for FCCU

Proposing 2 ppm NOx limit

- One unit achieved-in-practice
- One planned installation unit designed to meet 2 ppm
- Technically feasible and cost-effective

Considerations


- Averaging time
- Ammonia limit
 - ✓ All units currently have 10 ppm ammonia permit limit pursuant to Rule 1105.1



Sulfur Recovery Units /Tail Gas Incinerators (SRU/TGI)

SRU/TGI Universe

51



- Sulfur recovery units (SRU) convert hydrogen sulfide into elemental sulfur
- SRU converts ~95 percent of the hydrogen sulfide into sulfur and the tail gas incinerators (TGI) converts the remaining hydrogen sulfide into SO_2
- Tail gas is vented to a thermal/catalytic oxidizer/incinerator
- SRU/TGI are classified as major sources of NO_x


- Currently no units have been retrofitted with post combustions controls
- Challenging retrofits
 - High stacks adds to installation costs
 - Flue temperatures above maximum SCR temperatures
 - Waste heat boiler or excess air needed to cool gas
- Hydrogen sulfide rich gas contains NO_x precursors
 - Not all NO_x from burner

Technical Feasibility for SRU/TGI

- Combination of SCR (95% reduction) and ULNB (< 30 ppm) can achieve 2 ppm with proper engineering and design
 - Waste heat boiler or tempered air needed to reduce flue gas temperature
- LoTOx™ is another control option with ULNB that can achieve >95% NOx reduction
 - Operating temperature even lower than SCR
 - Waste heat boiler or tempered air
 - Used in combination with wet scrubber to control NOx, SOx, and PM
 - No ammonia use, but ozone is required
 - Waste effluent treatment system required
- 2015 BARCT Assessment and Norton report concurred that a 2 ppm NOx limits was technically feasible

Initial BARCT NOx Limit for SRU/TGI

55



* Texas Department of Environmental Quality Title 30, Part 1 Chapter 117, Subchapter B, Division 3, Rule 117.310 for Industrial Incinerators

Initial BARCT NOx Limits for Cost-Effectiveness Analysis for SRU/TGI

56

- Evaluated three NOx concentration limits
 - 2 ppm using SCR/ULNBs or LoTOx™
 - 5 ppm using SCR or LoTOx™
 - 30 ppm using ULNB only

2 ppm

SCR and ULNB
or LoTOx™ and
ULNB

5 ppm

SCR or
LoTOx™

30 ppm

ULNB
(< 30 ppm)

Potential NOx BARCT Emission Limits

Total NOx emission for SRU/TGTU is 0.43 tpd

Cost-Effectiveness Analysis for 2 and 5 ppm using SCR

Cost-Effectiveness at 2 and 5 ppm	
2 ppm (SCR and ULNB)	5 ppm (SCR)
\$90,000	\$89,000

- Staff received one cost estimate for a SCR retrofit (~ \$60 MM for two units with common SCR)
- Cost estimates for remaining units:
 - SCR cost ~\$45 per standard cubic feet/minute flow rate
 - Waste heat boiler ~ \$100,000
 - Installation ~ 4.5 times capital cost (Based on 2015 BARCT Norton recommendation)
 - Operating and Maintenance ~ \$150,000/year
- ULNB installation and cost
 - 8 units exceed 95% reduction to achieve 2 ppm and would need to replace burners
 - Burner cost curve used to estimate cost
 - No units need to replace burners to achieve 5 ppm
- Technically feasible to retrofit to 2 or 5 ppm with SCR but not cost-effective

Staff Recommendation

2 and 5 ppm is not cost-effective for SRU/TGI using SCR

Cost-Effectiveness Analysis for 2 and 5 ppm using LoTOx™

Cost-Effectiveness at 2 and 5 ppm	
2 ppm (LoTOx™ and ULNB)	5 ppm (LoTOx™)
\$96,000	\$95,000

- Staff relied on 2015 BARCT assessment to estimate costs (3 data points)
 - Scaled costs up using 4% interest rate
 - Created cost curve for total install and O&M costs
- ULNB installation and cost
 - 8 units exceed 95% reduction to achieve 2 ppm and would need to replace burners
 - Burner cost curve used to estimate cost
 - No units need to replace burners to achieve 5 ppm
- Technically feasible to retrofit to 2 ppm or 5 ppm with LoTOx™ but not cost-effective

Staff Recommendation
2 and 5 ppm is not cost-effective for SRU/TGI using LoTOx™

Cost-Effectiveness Analysis for 30 ppm

Cost-Effectiveness at 30 ppm
ULNB
\$51,700

- Cost estimates for burner retrofit:
 - Staff used the burner cost curve to estimate burner costs (average cost ~ \$3.1 MM)
 - Operating and Maintenance ~ \$2,000/year
 - 9 units currently operating above 30 ppm would need to be retrofit
- Based on current cost estimates, 30 ppm is cost-effective

Staff Recommendation

30 ppm is cost-effective for SRU/TGI using ULNB

Staff Recommendation for SRU/TGI

60



- Staff Recommendation
- 30 ppm

*Cost per ton of NOx reduced

Proposed BARCT NOx Limit for SRU/TGI

61

	RECLAIM 2015 BARCT	Existing Units	Other Regulatory	Technology Assessment	Proposed BARCT NOx Limit	
All Units	2 ppm	4 - 74 ppm	27 ppm*	2 ppm	30 ppm	16 units (9 retrofits)

* Texas Department of Environmental Quality Title 30, Part 1 Chapter 117, Subchapter B, Division 3, Rule 117.310 for Industrial Incinerators

Staff proposing 30 ppm NOx limit


- Based on burner technology
- Technically feasible and cost effective

Considerations

- Challenging to retrofit
 - High stacks
 - High flue gas temperature
 - Limited space
 - Moderate emissions

Next Steps

63



Rule 1109.1 Staff Contacts

64

Heather Farr
Program Supervisor
hfarr@aqmd.gov
909.396.3672

Jong Hoon Lee, Ph.D.
AQ Specialist
jhlee@aqmd.gov
909.396.3903

Sarady Ka
AQ Specialist
ska@aqmd.gov
909.396.2331

Michael Krause
Planning & Rules Manager
mkrause@aqmd.gov
909.396.2706



RECLAIM Staff Contacts

65

Kevin Orellana
Program Supervisor
korellana@aqmd.gov
909.396.3792

Gary Quinn, P.E.
Program Supervisor
gquinn@aqmd.gov
909.396.3121

Michael Morris
Planning & Rules Manager
mmorris@aqmd.gov
909.396.3282

