



South Coast  
AQMD

# Proposed Amended Rule 1134 Working Group #4

August 10, 2018

# Agenda

- Summary of Working Group Meeting #3
- Discuss preliminary rule language
- Concepts for Monitoring, Reporting, and Recordkeeping

## Previous Working Group Meeting

- Presented BARCT analysis
  - ▷ Technology assessment
  - ▷ Established BARCT emission limits for most categories
  - ▷ Cost-effectiveness
- Provided initial rule concepts

# Preliminary Rule Language

## Overview


- Rule language based on initial rule concepts with input from stakeholders
- Opportunities remain to revise rule language as rule development process progresses
  - Requesting further input from stakeholders where issues remain
- Presentation will highlight key provisions of preliminary rule language

## Applicability – Subdivision (b)

- Apply to turbines regardless of installation date
- Retain size threshold of  $\geq 0.3$  MW output
- Does not apply to turbines subject to:
  - ▷ Electricity Generating Facilities regulated under Proposed Amended Rule 1135
  - ▷ Refineries regulated under Proposed Rule 1109.1
- BARCT assessment did not consider turbines subject PAR 1135 and PR 1109.1

## NUMBER OF TURBINES

■ RECLAIM ■ Non-RECLAIM



## Exemptions – Paragraphs (h)(1) and (h)(2)

- Retaining exemptions for:
  - ▷ Laboratory turbines
  - ▷ Fire fighting turbines
  - ▷ Flood control turbines
  - ▷ Emergency turbines
- These turbines are used very infrequently and have minimal emissions

## Exemptions – Paragraphs (h)(1) and (h)(2) (*continued*)

- Deleting exemptions for:
  - ▷ Chemical processing turbines
    - ▷ Will be subject to applicable Rule 1134 fuel type emission limit or Rule 1109.1 if located at refinery
  - ▷ Turbines located in Southeast Desert Air Basin
    - ▷ No longer within SCAQMD boundaries
  - ▷ Turbines located on San Clemente Island
    - ▷ No turbines remain on San Clemente Island

## Key Definitions – Subdivision (c)

- Annual Capacity Factor – Ratio between measured heat input during a calendar year and the potential heat input had it been operating continuously at the permitted rating
  - ▷ Term used for low-use provisions
- Existing Gas Turbine Unit – Turbines operating prior to August 4, 1989 that did not enter RECLAIM program
  - ▷ Existing units will remain subject to existing requirements in rule in the interim

## Key Definitions – Subdivision (c) (continued)

- Landfill Gas – Gas derived from the decomposition of buried organic material (SCAQMD Rule 1150.1)
- Natural Gas – Pipeline quality gas (SCAQMD Rule 2000)
- Produced Gas – Gas associated with the production, gathering, separation, or processing of crude oil (SCAQMD Rule 1148.1)
- Sewage Digester Gas - Gas derived from anaerobic decomposition of organic sewage (unchanged)

## Existing Requirements – Paragraphs (d)(1) and (d)(2)

- Current emission limits retained during interim for existing turbines until emission concentration limits in paragraph (d)(3) are met or become effective
- Current emission limits do not apply to:
  - ▷ Turbines exiting RECLAIM
  - ▷ Turbines in operation after August 1989
  - ▷ Applying current limits would add costs and slow progress to meet BARCT limits
- Retains notice of applicability of Regulation XIII if CO emissions increase when NOx controls installed
  - ▷ Informational statement that Regulation XIII applies if there are emission increases on other pollutants
  - ▷ No CO emission limits in PAR 1134

## Emission Limitations – Paragraph (d)(3)

- Limits reflect BARCT assessment discussed in previous working group meetings
  - ▷ Limits provided by category and fuel type
  - ▷ Includes limit for ammonia
- Effective Date: January 1, 2024
- Proposed emission limits in Table I
- Seeking additional input on proposed emission limits

# Proposed Emission Limits – Table I

Table I: Emissions Limits for Stationary Gas Turbines

Fuel Type	NOx (ppmv @ 15% O <sub>2</sub> )	Ammonia (NH <sub>3</sub> ) (ppmv @ 15% O <sub>2</sub> )
Landfill Gas	12.5	5.0
Liquid – Outer Continental Shelf	25.0	5.0
Natural Gas – Combined Cycle	2.0	5.0
Natural Gas – Pipeline Gas Turbine	5.0	5.0
Natural Gas – Simple Cycle	2.5	5.0
Produced Gas	5.0	5.0
Produced Gas – Outer Continental Shelf	9.0	5.0
Sewage Digester	18.8	5.0
Other	12.5	5.0

## Cost-Effectiveness for Landfill Gas Turbines

Fuel Type	NOx (ppmv @ 15% O2)	Ammonia (NH3) (ppmv @ 15% O2)
Landfill Gas	12.5	5.0

- Based on recent source testing, 12 of 16 landfill gas turbines can meet 12.5 ppm NOx limit
  - ▷ Short periods where low loads or SOx mass emission limits impact NOx emission concentrations
  - ▷ Including provisions in rule to address low loads (10% of maximum rated load) and SOx mass emissions
- Remaining four units installed in 2010 already using SCR control technology
  - ▷ Recent test results indicate that meeting 25 ppm permit limit is challenging
  - ▷ Experiencing high costs due to frequent catalyst replacement
- More recent version of turbine model reportedly has NOx emissions of 15 ppm with no SCR
  - ▷ Stranded assets may be somewhat offset by elimination of SCR control costs
  - ▷ Estimated to become cost effective (< \$50,000 per ton reduced) by 2030

## Liquid – Outer Continental Shelf

Fuel Type	NOx (ppmv @ 15% O2)	Ammonia (NH3) (ppmv @ 15% O2)
Liquid – Outer Continental Shelf	25.0	5.0

- Liquid only used when there is insufficient produced gas
- Applicable only for turbines where natural gas pipelines are not available
- Must utilize dry low NOx or water injection technology in combination with SCR
  - ▷ Examining cost-effectiveness of SCR installation on Outer Continental Shelf sources

# Natural Gas Turbines

Fuel Type	NOx (ppmv @ 15% O2)	Ammonia (NH3) (ppmv @ 15% O2)
Natural Gas – Combined Cycle	2.0	5.0
Natural Gas – Pipeline Gas Turbine	5.0	5.0
Natural Gas – Simple Cycle	2.5	5.0

- Excluding low-use turbines and turbines permitted near proposed limits, proposed limits for combined cycle and simple cycle turbine are cost-effective
  - ▷ Average cost-effectiveness for combined cycle turbines: \$15,200
  - ▷ Average cost-effectiveness for simple cycle turbines: \$16,800

# Pipeline Gas Turbines

- Four < 1 MW turbines used for natural gas pipelines
  - ▷ Challenged by variation in fuel flow
  - ▷ Currently emitting < 10 tons combined annually
- BACT and SJVAPCD limits are currently:
  - ▷ NOx - 8 ppmv @ 15% O2 steady / 12 ppmv @ 15% O2 transition
  - ▷ Ammonia - 20 ppmv @ 15% O2
  - ▷ Based on analysis nearly 25 years ago
- More recent (2014) installation at Kettleman has NOx limit of 8 ppmv @ 15% O2 and ammonia limit of 10 ppmv @ 15% O2
- Analyzing incremental cost-effectiveness between retrofit and replacement
  - ▷ Retrofit costs less but replacement realizes more emission reductions

## Produced Gas

Fuel Type	NOx (ppmv @ 15% O2)	Ammonia (NH3) (ppmv @ 15% O2)
Produced Gas	5.0	5.0

- Produced gas has frequent load changes and low-load challenges
- Applicable only for turbines where natural gas is not used
- Must utilize dry low NOx or water injection technology in combination with SCR

## Produced Gas – Outer Continental Shelf Source

Fuel Type	NOx (ppmv @ 15% O2)	Ammonia (NH3) (ppmv @ 15% O2)
Produced Gas – Outer Continental Shelf Source	9.0	5.0

- Produced gas has frequent load changes and low-load challenges
- Applicable only for turbines where natural gas pipelines are not available
- Must utilize dry low NOx or water injection technology in combination with SCR
  - ▷ Examining cost-effectiveness of SCR installation on Outer Continental Shelf sources

# Sewage Digester Gas Turbines

Fuel Type	NOx (ppmv @ 15% O2)	Ammonia (NH3) (ppmv @ 15% O2)
Sewage Digester	18.8	5.0

- Sewage digester gas turbines challenged by high siloxane levels
- Three turbines currently meet 18.8 ppm NOx using SCR
- Other three turbines may meet same limit through water injection
- Analyzing impacts on power generation and averaging time



## Other Gas

Fuel Type	NOx (ppmv @ 15% O2)	Ammonia (NH3) (ppmv @ 15% O2)
Other	12.5	5.0

- No “other” gas currently utilized
- Biogas may be utilized in future
  - Similar challenges as landfill gas turbines
- Must utilize dry low NOx technology

## Start-Up, Shutdown, and Tuning Requirements – Paragraph (d)(4)

- Emission limits in Table I not applicable during Start-Up, Shutdown, and Tuning
- SCAQMD permits establish provisions for start-up, shutdown, and tunings
  - ▷ Specifies duration, mass emissions, frequency for start-up and shutdown
  - ▷ Permit may contain additional conditions for tunings



## Averaging Time – Paragraph (d)(5)

- Units installed or retrofitted after rule amendment shall average emission limits over a 60 minute rolling average
  - ▷ 60 minute rolling average requires software modification
  - ▷ Permits will contain similar requirement
- Units installed prior to rule that comply with proposed limits shall retain current averaging time requirements specified in the permit
  - ▷ Existing averaging times vary widely

## Prohibition of Liquid Fuel – Paragraph (d)(6)

- Prohibits use of liquid fuel except for gas turbines located on Outer Continental Shelf
  - ▷ Liquid fuel needed when produced gas is insufficient; no access to pipeline natural gas
- Fuel must be 10% or greater liquid content by volume to qualify for higher limit



Photo by Beta Offshore [www.betaoffshore.com](http://www.betaoffshore.com)

## Low-Use Turbines – Clauses (h)(3)(A) & (h)(3)(B)

- Many electric power generating units are operated sporadically to support renewables
  - ▷ Low-use units are not cost-effective to install additional control equipment
- NOx concentration not applicable for turbines that:
  - ▷ Operate less than 25% of annual capacity factor in one year;
  - ▷ Operate less than 10% averaged over three years;
  - ▷ Retain NOx and NH3 limits, averaging times, and start-up, shutdown, and tuning requirements in current permit; and
  - ▷ Have a permit condition limiting annual capacity factor

## Low-Use Turbines – Clauses (h)(3)(A) & (h)(3)(B) *(Continued)*

- Turbines must demonstrate low-use over three year period from 2017-2019
- Apply for permit modification to include annual capacity limit by July 2020

## Exceedance of Low-Use Exemption – Clause (d)(3)(C)

Ensures that low-use threshold is maintained and provides instructions if exceedance

- Demonstrate each July that turbine remains below annual capacity factor threshold
- If exceedance:
  - ▷ Submit permit application within 9 months from reported date
  - ▷ Submit CEMS Plan within six months
  - ▷ Operate in compliance with limits in Table I by three years from date of reported exceedance

## Landfill Gas Turbines – Paragraphs (h)(4) and (h)(5)

Landfill Gas turbines can meet proposed limit except during low-load operations and when trying to limit SOx emissions

- NOx limits not applicable when operating below ten percent of the rating of a landfill gas turbine
  - ▷ Limited to 250 hours per year
- NOx limits not applicable when limiting SOx mass emissions
  - ▷ SOx mass emissions must be within 10% of daily permitted SOx mass emission limit
  - ▷ Limited to 100 hours per year

# Monitoring, Recordkeeping, and Reporting (MRR)

## Overview of Monitoring, Reporting, and Recordkeeping (MRR) – Subdivision (e)

Establish interim MRR for landing rules

- Retain MRR for non-RECLAIM facilities
  - ▷ CEMS for turbines > 2.9 MW
  - ▷ Source testing for turbines  $\leq$  2.9 MW
- RECLAIM facilities will retain Rule 2012 monitoring and recordkeeping
  - ▷ Includes CEMS requirement for turbines > 2.9 MW
  - ▷ Excludes emergency standby turbines

Considering companion rule to Rule 2012 to transition from current requirements into consistent and comprehensive MRRs for all PAR 1134 facilities

## MRR for Non-RECLAIM Gas Turbines – Paragraph (e)(1)

- Require CEMS for NO<sub>x</sub> to meet the requirements of SCAQMD Rule 218 – Continuous Emission Monitoring
  - ▷ Many Rule 1134 applicable turbines already meeting Rule 218
  - ▷ Current provisions are inadequate and antiquated
- Retain measurement of flow rates of liquids or gases and elapsed time of operation

## Source Testing – Paragraph (e)(2)

- Require source testing for turbines rated  $\leq 2.9$  MW
  - ▷ Adding SCAQMD Test Method 207.1 for ammonia – Paragraph (f)(1)
- Retain annual source test for NO<sub>x</sub> and ammonia for turbines emitting 25 tons or more of NO<sub>x</sub> per calendar year
- Source testing every three years otherwise
  - ▷ Previously was every 8,400 hours
  - ▷ New requirement provides consistency and predictability

## MRR for RECLAIM Gas Turbines – Paragraph (e)(3)

- Comply with SCAQMD Rule 2012 – Requirements for Monitoring, Reporting, and Recordkeeping for Oxides of Nitrogen Emissions
  - ▷ Applicable only to turbines currently subject to RECLAIM
- Exclude requirements in Rule 2012 for reporting
  - ▷ Retains monitoring and recordkeeping requirements but minimizes reporting requirements

## Recordkeeping - Paragraph (g)(3)

- Require data acquisition system to record compliance with emission concentration limits in rule
  - ▷ Monthly emission summary removed
  - ▷ Provides needed information to determine compliance without requiring extensive reporting

# Schedule

## Current Tentative Schedule

- Next Working Group Meeting      September 2018
- Public Workshop      Summer 2018
- Stationary Source Committee      Fall 2018
- Set Hearing      Fall 2018
- Public Hearing      Winter 2019

# Contacts

## **PAR 1134 Development**

Michael Morris, [mmorris@aqmd.gov](mailto:mmorris@aqmd.gov), (909) 396-3282

Uyen-Uyen Vo, [uvo@aqmd.gov](mailto:uvo@aqmd.gov), (909) 396-2238

## **RECLAIM Questions**

Gary Quinn, P.E., [gquinn@aqmd.gov](mailto:gquinn@aqmd.gov), (909) 396-3121

Kevin Orellana, [korellana@aqmd.gov](mailto:korellana@aqmd.gov), (909) 396-3492

Tracy Goss, P.E., [tgoss@aqmd.gov](mailto:tgoss@aqmd.gov), (909) 396-3106

## **General Questions**

Susan Nakamura, [snakamura@aqmd.gov](mailto:snakamura@aqmd.gov), (909) 396-3105