



TOTAL AIR ANALYSIS, INC.

**EMISSIONS SOURCE
TEST REPORT**

**LIEBHERR 250 KW ENGINE
FRAUENFELD (SWITZERLAND)
Waste Water Treatment Plant**

Prepared For:


Alpine Energy Systems
2945 Townsgate Road, Suite 200
Westlake Village, California 91361
Attn: Bill Morton

Test Dates: July 8, 2014
Report Date: August 11, 2014
Report Identification No: MF-141223

Prepared By:

Total Air Analysis, Inc.
1210 East 223rd Street, Suite 314
Carson, CA 90745

Performed by:



Russ P. Logan, President

TABLE OF CONTENTS

	<u>Page</u>
1.0 Summary of Results	1
2.0 Introduction	2
3.0 Process Description	2
3.1 <i>Equipment Description</i>	2
4.0 Test Description.....	2
4.1 <i>Test Requirements and Locations</i>	2
4.2 <i>Operating Parameters</i>	2
5.0 Sampling and Analytical Procedures	3
5.1 <i>EPA CTM-030 - Portable Gaseous Emissions Sampling</i>	3
5.2 <i>EPA Method 18 - Total Hydrocarbons Determination</i>	3
6.0 Test Results and Discussion	3
7.0 Quality Assurance/Quality Control	3

LIST OF APPENDICES

	<u>Page</u>
Appendix A - EPA Method CTM-030 – Emission Calculations and DAS Data.....	4
Appendix B - EPA Method 18.....	16
Appendix C - Operating Data.....	20
Appendix D - Quality Assurance/Quality Control.....	23

1.0 SUMMARY OF RESULTS

Facility: Frauenfeld, Switzerland WWTP
Source: Liebherr 250 KW GenSet
Date: 7/8/2014

Parameter/Condition Run No.	Units	Bio-Gas 1	Bio-Gas 2	Bio-Gas 3	Limits SCAQMD	Pass/Fail
NOx	ppmv	3.28	1.98	1.09	Rule 1110.2	
NOx @ 15% O ₂	ppmv	0.93	0.56	0.31	11	Pass
CO	ppmv	78.75	53.68	27.48		
CO @ 15% O ₂	ppmv	22.36	15.25	7.80	250	Pass
Total Hydrocarbons						
Methane	ppm	-	432	-		
TOC, non-methane	ppm	-	2.00	-		
TOC @ 15% O ₂	ppm	-	0.57	-	30	Pass
O ₂	%	0.00	0.00	0.00	-	-
CO ₂	%	11.70	11.70	11.70	-	-

2.0 Introduction

Total Air Analysis, Inc. was contracted to perform an emissions source test program on one (1) GenSet internal combustion engine (ICE) operated at the Frauenfeld Waste Water Treatment Plant in Switzerland. The purpose of the source test was to determine the emissions of Nitrogen Oxides (NOx), Carbon Monoxide (CO), Carbon Dioxide (CO₂), and oxygen (O₂) in accordance with SCAQMD emission limits.

3.0 Process Description

Avesco AG operates a Liebherr 250 KW Internal Combustion Engine (ICE) firing on digester gas at the Frauenfeld Waste Water Treatment Plant in Switzerland. Triplicate twenty (20) minute sample runs were performed for NOx, CO, CO₂ and O₂. A single sample was taken for total hydrocarbons using EPA Method 18.

3.1 Equipment Description

The ICE is a Liebherr Rich burn digester gas fired eight (8) cylinder four-stroke engine driving a 250 kW electrical generator. The exhaust is outfitted with Avesco AG's proprietary exhaust gas recirculation system and a non-selective catalytic converter.

4.0 Test Description

4.1 Testing Requirements and Locations

The source testing was conducted at the exhaust of the ICE after the catalytic converter. Table 1 summarizes the test methods used, sampling duration, and number of tests.

Table 1
Testing Location and Requirements

<i>Parameter</i>	<i>Test Methods</i>	<i>Test Locations</i>	<i>Test Duration per Run</i>	<i>Number of Tests</i>
NOx, CO, O ₂ , CO ₂	EPA CTM-030	Exhaust	20 Minutes	Triplicate
Total Hydrocarbons	EPA Method 18	Exhaust	20 Minutes	Single

4.2 Operating Parameters

Operating parameters were documented during the source test using existing monitoring instruments. See Appendix C for a picture of the control panel taken during the test.

5.0 Sampling and Analytical Procedures

5.1 CTM-030 – Portable Gaseous Emissions Sampling

An ECOM J2KN portable instrument was used to determine post-cat exhaust emissions. NOx, CO, CO₂ and O₂ were measured to determine emission levels during triplicate twenty (20) minute tests. This instrument was calibrated before and after this test. Results are found in Appendix A.

5.2 EPA Method 18 - Total Hydrocarbons Determination

The apparatus consists of a stainless steel probe connected by Teflon line to an airtight canister. Sample gas was drawn into the 1-liter canister. The sample was 20 minutes in duration.

Upon completion the sample was sealed and transported to SGS-RUK Laboratory in Germany. Sample was then injected into the GC for Methane and TOC analysis.

6.0 Test Results and Discussion

The emissions tests were conducted at the exhaust of the ICE GenSet. Triplicate 20-minute tests were conducted for NOx, CO, CO₂ and O₂. Total Hydrocarbons were sampled using EPA Method 18 and analyzed by GC.

Results of the emissions tests are summarized in Section 1.0 (Summary of Results).

7.0 Quality Assurance and Quality Control

Total Air Analysis, Inc. applies stringent quality control and quality assurance procedures to ensure the validity of measurements for all projects. Our QA/QC procedures are documented in detailed quality assurance project plans similar to those used by the EPA, CARB, SCAQMD, and SDAPCD.

- ❖ Total Air Analysis QA/QC procedures follow guidelines in *Quality Assurance Handbook for Air Pollution Measurement Systems*, Volumes I through III. These procedures outline pretest preparation and calibrations of sampling equipment, post-test sample handling, and post-test calibrations.

Appendix A

EPA Method CTM-030

Emission Calibrations and DAS Data



FORM 3A: Periodic Monitoring Recordkeeping Form For Portable Analyzers
SCAQMD RULE 1110.2 Emissions from Gaseous and Liquid-Fueled Engines

DATE:	7/8/2014	TIME (start/stop):	10:42 / 11:01	NAME:	Total Air Analysis, Inc.
FACILITY NAME:	ARA Frauenfeld, Switzerland			ANALYZER (Make/Model):	ECOM J2KN
Facility	Wastewater Treatment Plant			Analyzer S/N:	2701 OCNX
Engine Name:	Avesco 250 KW GenSet			Date of Last Stability Check ¹ :	8/2/2013
Permit to Operate:				Date of Last Linearity Check ² :	8/2/2013
Application No.:				1. Stability check must be conducted within 12 months of test date 2. Linearity check must be conducted within 12 months of test date	

<u>"As Found" Test Results</u>					Date:	7/8/2014
Time Start:	10:42:10 AM		Ambient Temperature (°F):			
Time End:	11:01:25 AM		Engine Hour	Meter	Reading:	
Constituent	CO (ppm)	NO (ppm)	NO ₂ (ppm)	O ₂ (%)		
Measured, C _{MEAS} *	76.95	2.53	0.78	0.00		
Cal Adjusted, C _{CORR}	78.7	2.5	0.8	0.00		

Example
Calculation: $C_{ADJ} = (C_{MEAS} - C_{CZ}) \times \left(\frac{C_{CAL}}{C_{CM} - C_{CZ}} \right)$

Constituent	CO (ppm)	NO _x (ppm)	Engine Operating Conditions:	
			Normal Operating Conditions	KW - 256
C _{ADJ} @ 15% O ₂ , N	22.4	0.9		
Compliance Limit	250.0	11.0		
Difference	227.6	10.1		

Constituent	CO (ppm)	NO (ppm)	NO ₂ (ppm)	O ₂ (%)
Pre-Test Zero	0	0	0	0
Post-Test Zero	0	0	0	0
Mean Zero, C _{CZ}	0	0	0	0
Span Gas, C _{CAL}	89.80	22.42	74.5	20.95
Pre-Test Span	87.5	22.8	75.0	21.00
Post-Test Span	88.0	22.5	74.8	21.00
Mean Span, C _{CM}	87.8	22.6	74.9	21.00
Drift, %	0.57	-1.10	-0.33	0.00

Drift Calculation is listed in Section 3.6, Periodic Monitoring Protocol

<u>"As Left" Test Results (If applicable)</u>					Date:
Time Start:	Ambient Temperature (°F):				
Time End:	Engine Hour Meter Reading:				
Constituent	CO (ppm)	NO (ppm)	NO ₂ (ppm)	O ₂ (%)	
Measured, C _{MEAS} *					
Cal Adjusted, C _{ADJ}					Engine Operating Conditions:
Constituent	CO (ppm)	NO _x (ppm)			
C _{ADJ} @ 15% O ₂ , N					
Compliance Limit					
Difference					

Describe any engine or control system maintenance or tuning conducted after the "As Found" Test to bring the engine into compliance (attach additional documentation as necessary):

*Attach printouts from the portable analyzer or the manual record of constituent concentrations during the test.

CERTIFICATION: Based on the calibrations and measurements performed in accordance with this protocol, I certify that the statements and information contained in this report are true, accurate, complete and representative of the emissions from this source.

Russ P. Logan

Test Conducted By

President

Title

Signature

7/8/2014

Date



FORM 3A: Periodic Monitoring Recordkeeping Form For Portable Analyzers
SCAQMD RULE 1110.2 Emissions from Gaseous and Liquid-Fueled Engines

DATE:	7/8/2014	TIME (start/stop):	11:04 / 11:24	NAME:	Total Air Analysis, Inc.
FACILITY NAME:	ARA Frauenfeld, Switzerland			ANALYZER (Make/Model):	ECOM J2KN
Facility ID Number:	Wastewater Treatment Plant			Analyzer S/N:	2701 OCNX
Engine Name:	Avesco 250 KW GenSet			Date of Last Stability Check ¹ :	8/2/2013
Permit to Operate:				Date of Last Linearity Check ² :	8/2/2013
Application No.:				1. Stability check must be conducted within 12 months of test date 2. Linearity check must be conducted within 12 months of test date	

"As Found" Test Results					Date:	7/8/2014
Time Start:	11:04:55 AM		Ambient Temperature (°F):			
Time End:	11:24:25 AM		Engine Hour	Meter	Reading:	
Constituent	CO (ppm)	NO (ppm)	NO ₂ (ppm)	O ₂ (%)		
Measured, C _{MEAS} *	52.46	2.00	0.00	0.00		
Cal Adjusted, C _{ADJ}	53.7	2.0	0.0	0.00		

Example
Calculation: $C_{ADJ} = (C_{MEAS} - C_{CZ}) \times \left(\frac{C_{CAL}}{C_{CM} - C_{CZ}} \right)$

Constituent	CO (ppm)	NO _x (ppm)	Engine Operating Conditions:	
			Normal Operating Conditions 255 KW	
C _{ADJ} @ 15% O ₂ , N	15.2	0.6		
Compliance Limit	250.0	11.0		
Difference	234.8	10.4		

Constituent	CO (ppm)	NO (ppm)	NO ₂ (ppm)	O ₂ (%)
Pre-Test Zero	0	0	0	0
Post-Test Zero	0	0	0	0
Mean Zero, C _{CZ}	0	0	0	0
Span Gas, C _{CAL}	89.80	22.42	74.5	20.95
Pre-Test Span	87.5	22.8	75.0	21.00
Post-Test Span	88.0	22.5	74.8	21.00
Mean Span, C _{CM}	87.8	22.6	74.9	21.00
Drift, %	0.57	-1.10	-0.33	0.00

Drift Calculation is listed in Section 3.6, Periodic Monitoring Protocol

"As Left" Test Results (If applicable)					Date:
Time Start:	Ambient Temperature (°F):				
Time End:	Engine Hour Meter			Reading:	
Constituent	CO (ppm)	NO (ppm)	NO ₂ (ppm)	O ₂ (%)	
Measured, C _{MEAS} *					
Cal Adjusted, C _{ADJ}					Engine Operating Conditions:
Constituent	CO (ppm)	NO _x (ppm)			
C _{ADJ} @ 15% O ₂ , N					
Compliance Limit					
Difference					

Describe any engine or control system maintenance or tuning conducted after the "As Found" Test to bring the engine into compliance (attach additional documentation as necessary):

* Attach printouts from the portable analyzer or the manual record of constituent concentrations during the test.

CERTIFICATION: Based on the calibrations and measurements performed in accordance with this protocol, I certify that the statements and information contained in this report are true, accurate, complete and representative of the emissions from this source.

Russ P. Logan

Test Conducted By

President

Title

Signature

7/8/2014

Date



FORM 3A: Periodic Monitoring Recordkeeping Form For Portable Analyzers
SCAQMD RULE 1110.2 Emissions from Gaseous and Liquid-Fueled Engines

DATE: 7/8/2014 TIME (start/stop): 11:27 / 11:47

NAME: Total Air Analysis, Inc.

FACILITY NAME: ARA Frauenfeld, Switzerland

ANALYZER (Make/Model): ECOM J2KN

Facility ID Number: Wastewater Treatment Plant

Analyzer S/N: 2701 OCNX

Engine Name: Avesco 250 KW GenSet

Date of Last Stability Check ¹: 8/2/2013

Permit to Operate:

Date of Last Linearity Check ²: 8/2/2013

Application No.:

1. Stability check must be conducted within 12 months of test date
2. Linearity check must be conducted within 12 months of test date

"As Found" Test Results

Date: 7/8/2014

Time Start: 11:27:25 AM Ambient Temperature (°F):

Time End: 11:47:40 AM Engine Hour Meter
Reading:

Constituent	CO (ppm)	NO (ppm)	NO _x (ppm)	O ₂ (%)
Measured, C _{MEAS} *	26.85	1.00	0.10	0.00
Cal Adjusted, C _{ADJ}	27.5	1.0	0.1	0.00

Example
Calculation: $C_{ADJ} = (C_{MEAS} - C_{cz}) \times \left(\frac{C_{CAL}}{C_{CM} - C_{cz}} \right)$

Constituent	CO (ppm)	NO _x (ppm)
C _{ADJ} @ 15% O ₂ , N	7.8	0.3
Compliance Limit	250.0	11.0
Difference	242.2	10.7

Engine Operating Conditions:

Normal Operating Conditions

KW - 256

Calibration Results

Date of Pre-Test Calibration: 7/3/2014

Date of Post-Test Calibration: 7/11/2014

Constituent	CO (ppm)	NO (ppm)	NO _x (ppm)	O ₂ (%)
Pre-Test Zero	0	0	0	0
Post-Test Zero	0	0	0	0
Mean Zero, C _{cz}	0	0	0	0
Span Gas, C _{CAL}	89.80	22.42	74.5	20.95
Pre-Test Span	87.5	22.8	75.0	21.00
Post-Test Span	88.0	22.5	74.8	21.00
Mean Span, C _{CM}	87.8	22.6	74.9	21.00
Drift, %	0.57	-1.10	-0.33	0.00

Drift Calculation is listed in Section 3.6, Periodic Monitoring Protocol

"As Left" Test Results (If applicable)

Date:

Time Start: Ambient Temperature (°F):

Time End: Engine Hour Meter
Reading:

Constituent	CO (ppm)	NO (ppm)	NO _x (ppm)	O ₂ (%)
Measured, C _{MEAS} *				
Cal Adjusted, C _{ADJ}				
Constituent	CO (ppm)	NO _x (ppm)	Engine Operating Conditions:	
C _{ADJ} @ 15% O ₂ , N				
Compliance Limit				
Difference				

Describe any engine or control system maintenance or tuning conducted after the "As Found" Test to bring the engine into compliance (attach additional documentation as necessary):

* Attach printouts from the portable analyzer or the manual record of constituent concentrations during the test.

CERTIFICATION: Based on the calibrations and measurements performed in accordance with this protocol, I certify that the statements and information contained in this report are true, accurate, complete and representative of the emissions from this source.

Russ P. Logan

Test Conducted By

President

Title


Signature
7/8/2014
Date

Total Air Analysis, Inc
Data Acquisition System

Facility: ARA Frauenfeld, Switzerland

Date: 7/8/2014

Source: ICE GenSet, 250 KW Max

Run No.:

1

Date	Time	O2	CO	NO	NO2
7/8/2014	10:42:10	0	169	3	1
7/8/2014	10:42:25	0	203	3	0
7/8/2014	10:42:40	0	202	3	0
7/8/2014	10:42:55	0	173	3	1
7/8/2014	10:43:10	0	138	3	2
7/8/2014	10:43:25	0	113	3	1
7/8/2014	10:43:40	0	94	3	1
7/8/2014	10:43:55	0	69	4	4
7/8/2014	10:44:10	0	83	4	2
7/8/2014	10:44:25	0	78	4	2
7/8/2014	10:44:40	0	86	4	2
7/8/2014	10:44:55	0	108	3	2
7/8/2014	10:45:10	0	137	3	2
7/8/2014	10:45:25	0	108	3	2
7/8/2014	10:45:40	0	70	3	1
7/8/2014	10:45:55	0	61	5	1
7/8/2014	10:46:10	0	39	6	1
7/8/2014	10:46:25	0	47	6	1
7/8/2014	10:46:40	0	122	4	1
7/8/2014	10:46:55	0	148	3	1
7/8/2014	10:47:10	0	153	3	1
7/8/2014	10:47:25	0	172	2	1
7/8/2014	10:47:40	0	194	2	1
7/8/2014	10:47:55	0	187	2	1
7/8/2014	10:48:10	0	138	2	1
7/8/2014	10:48:25	0	101	2	1
7/8/2014	10:48:40	0	66	2	1
7/8/2014	10:48:55	0	32	3	1
7/8/2014	10:49:10	0	21	3	1
7/8/2014	10:49:25	0	52	3	1
7/8/2014	10:49:40	0	92	2	1
7/8/2014	10:49:55	0	109	2	1
7/8/2014	10:50:10	0	81	2	1
7/8/2014	10:50:25	0	61	2	1
7/8/2014	10:50:40	0	85	2	1
7/8/2014	10:50:55	0	102	2	1
7/8/2014	10:51:10	0	100	2	1
7/8/2014	10:51:25	0	81	2	1
7/8/2014	10:51:40	0	70	2	1
7/8/2014	10:51:55	0	64	2	1
7/8/2014	10:52:10	0	64	2	1
7/8/2014	10:52:25	0	73	2	1
7/8/2014	10:52:40	0	70	2	1
7/8/2014	10:52:55	0	58	2	1
7/8/2014	10:53:10	0	45	2	1
7/8/2014	10:53:25	0	37	2	1
7/8/2014	10:53:40	0	38	2	1
7/8/2014	10:53:55	0	29	2	1
7/8/2014	10:54:10	0	20	2	1

7/8/2014	10:54:25	0	16	2	1
7/8/2014	10:54:40	0	47	2	1
7/8/2014	10:54:55	0	52	2	1
7/8/2014	10:55:10	0	44	2	0
7/8/2014	10:55:25	0	48	2	0
7/8/2014	10:55:40	0	47	2	0
7/8/2014	10:55:55	0	42	2	0
7/8/2014	10:56:10	0	40	2	0
7/8/2014	10:56:25	0	35	2	0
7/8/2014	10:56:40	0	21	2	0
7/8/2014	10:56:55	0	11	3	0
7/8/2014	10:57:10	0	9	3	0
7/8/2014	10:57:25	0	28	3	0
7/8/2014	10:57:40	0	29	3	0
7/8/2014	10:57:55	0	68	2	0
7/8/2014	10:58:10	0	83	2	0
7/8/2014	10:58:25	0	89	2	0
7/8/2014	10:58:40	0	94	2	0
7/8/2014	10:58:55	0	92	1	0
7/8/2014	10:59:10	0	73	1	0
7/8/2014	10:59:25	0	62	2	0
7/8/2014	10:59:40	0	28	2	0
7/8/2014	10:59:55	0	14	2	0
7/8/2014	11:00:10	0	13	2	0
7/8/2014	11:00:25	0	7	3	0
7/8/2014	11:00:40	0	13	3	1
7/8/2014	11:00:55	0	36	2	0
7/8/2014	11:01:10	0	97	2	0
7/8/2014	11:01:25	0	121	2	0
Average		0.00	76.95	2.53	0.78
7/8/2014	11:01:40	18.2	126	1	0
7/8/2014	11:01:55	20.8	34	1	0
7/8/2014	11:02:10	20.9	8	1	0
7/8/2014	11:02:25	21	3	1	0
7/8/2014	11:02:40	21	2	1	0
7/8/2014	11:02:55	21	1	1	0
7/8/2014	11:03:10	21	1	1	0
7/8/2014	11:03:25	20.9	1	1	0
7/8/2014	11:03:40	21	0	1	0
7/8/2014	11:03:55	21	0	1	1
7/8/2014	11:04:10	0.8	0	1	2
7/8/2014	11:04:25	0.2	3	1	1
7/8/2014	11:04:40	0	6	1	1

Total Air Analysis, Inc
Data Acquisition System

Facility: ARA Frauenfeld, Switzerland

Date: 7/8/2014

Source: ICE GenSet, 250 KW Max

Run No.:

2

Date	Time	O2	CO	NO	NO2
7/8/2014	11:04:55	0	33	1	0
7/8/2014	11:05:10	0	70	1	0
7/8/2014	11:05:25	0	71	1	0
7/8/2014	11:05:40	0	61	1	0
7/8/2014	11:05:55	0	46	1	0
7/8/2014	11:06:10	0	38	1	0
7/8/2014	11:06:25	0	28	1	0
7/8/2014	11:06:40	0	20	1	0
7/8/2014	11:06:55	0	16	1	0
7/8/2014	11:07:10	0	14	1	0
7/8/2014	11:07:25	0	12	1	0
7/8/2014	11:07:40	0	20	1	0
7/8/2014	11:07:55	0	31	1	0
7/8/2014	11:08:10	0	28	1	0
7/8/2014	11:08:25	0	23	1	0
7/8/2014	11:08:40	0	23	1	0
7/8/2014	11:08:55	0	13	1	0
7/8/2014	11:09:10	0	12	1	0
7/8/2014	11:09:25	0	13	1	0
7/8/2014	11:09:40	0	20	1	0
7/8/2014	11:09:55	0	38	1	0
7/8/2014	11:10:10	0	37	1	0
7/8/2014	11:10:25	0	30	1	0
7/8/2014	11:10:40	0	21	1	0
7/8/2014	11:10:55	0	18	1	0
7/8/2014	11:11:10	0	22	1	0
7/8/2014	11:11:25	0	21	1	0
7/8/2014	11:11:40	0	14	1	0
7/8/2014	11:11:55	0	14	1	0
7/8/2014	11:12:10	0	12	1	0
7/8/2014	11:12:25	0	11	1	0
7/8/2014	11:12:40	0	7	1	0
7/8/2014	11:12:55	0	8	1	0
7/8/2014	11:13:10	0	4	14	0
7/8/2014	11:13:25	0	1	30	0
7/8/2014	11:13:40	0	18	22	0
7/8/2014	11:13:55	0	53	10	0
7/8/2014	11:14:10	0	103	4	0
7/8/2014	11:14:25	0	139	3	0
7/8/2014	11:14:40	0	161	2	0
7/8/2014	11:14:55	0	179	2	0
7/8/2014	11:15:10	0	175	1	0
7/8/2014	11:15:25	0	172	1	0
7/8/2014	11:15:40	0	149	1	0
7/8/2014	11:15:55	0	138	1	0
7/8/2014	11:16:10	0	129	1	0
7/8/2014	11:16:25	0	120	1	0
7/8/2014	11:16:40	0	119	1	0
7/8/2014	11:16:55	0	126	1	0

7/8/2014	11:17:10	0	121	1	0
7/8/2014	11:17:25	0	104	1	0
7/8/2014	11:17:40	0	86	1	0
7/8/2014	11:17:55	0	88	1	0
7/8/2014	11:18:10	0	79	1	0
7/8/2014	11:18:25	0	68	1	0
7/8/2014	11:18:40	0	64	1	0
7/8/2014	11:18:55	0	64	1	0
7/8/2014	11:19:10	0	66	1	0
7/8/2014	11:19:25	0	59	1	0
7/8/2014	11:19:40	0	50	1	0
7/8/2014	11:19:55	0	47	1	0
7/8/2014	11:20:10	0	46	1	0
7/8/2014	11:20:25	0	44	1	0
7/8/2014	11:20:40	0	44	1	0
7/8/2014	11:20:55	0	47	1	0
7/8/2014	11:21:10	0	60	1	0
7/8/2014	11:21:25	0	40	1	0
7/8/2014	11:21:40	0	34	1	0
7/8/2014	11:21:55	0	29	1	0
7/8/2014	11:22:10	0	26	1	0
7/8/2014	11:22:25	0	19	1	0
7/8/2014	11:22:40	0	39	1	0
7/8/2014	11:22:55	0	44	1	0
7/8/2014	11:23:10	0	33	1	0
7/8/2014	11:23:25	0	26	1	0
7/8/2014	11:23:40	0	22	1	0
7/8/2014	11:23:55	0	22	1	0
7/8/2014	11:24:10	0	21	1	0
7/8/2014	11:24:25	0	21	1	0
Average		0.00	52.46	2.00	0.00
7/8/2014	11:24:40	19.5	19	1	0
7/8/2014	11:24:55	20.8	8	1	0
7/8/2014	11:25:10	21	3	1	0
7/8/2014	11:25:25	21	2	1	0
7/8/2014	11:25:40	21	3	1	0
7/8/2014	11:25:55	21	3	1	0
7/8/2014	11:26:10	21	2	1	0
7/8/2014	11:26:25	21	1	1	0
7/8/2014	11:26:40	21	1	1	0
7/8/2014	11:26:55	0.3	25	1	2
7/8/2014	11:27:10	0.1	48	1	1

Total Air Analysis, Inc
Data Acquisition System

Facility: ARA Frauenfeld, Switzerland

Date: 7/8/2014

Source: ICE GenSet, 250 KW Max

Run No.: 3

Date	Time	O2	CO	NO	NO2
7/8/2014	11:27:25	0	50	1	0
7/8/2014	11:27:40	0	44	1	0
7/8/2014	11:27:55	0	41	1	0
7/8/2014	11:28:10	0	29	1	0
7/8/2014	11:28:25	0	27	1	0
7/8/2014	11:28:40	0	22	1	0
7/8/2014	11:28:55	0	22	1	0
7/8/2014	11:29:10	0	21	1	0
7/8/2014	11:29:25	0	19	1	0
7/8/2014	11:29:40	0	19	1	0
7/8/2014	11:29:55	0	18	1	0
7/8/2014	11:30:10	0	55	1	0
7/8/2014	11:30:25	0	31	1	0
7/8/2014	11:30:40	0	48	1	0
7/8/2014	11:30:55	0	43	1	0
7/8/2014	11:31:10	0	16	1	0
7/8/2014	11:31:25	0	14	1	0
7/8/2014	11:31:40	0	27	1	0
7/8/2014	11:31:55	0	24	1	0
7/8/2014	11:32:10	0	15	1	0
7/8/2014	11:32:25	0	8	1	0
7/8/2014	11:32:40	0	47	1	0
7/8/2014	11:32:55	0	90	1	8
7/8/2014	11:33:10	0	102	1	0
7/8/2014	11:33:25	0	81	1	0
7/8/2014	11:33:40	0	54	1	0
7/8/2014	11:33:55	0	44	1	0
7/8/2014	11:34:10	0	30	1	0
7/8/2014	11:34:25	0	24	1	0
7/8/2014	11:34:40	0	24	1	0
7/8/2014	11:34:55	0	25	1	0
7/8/2014	11:35:10	0	18	1	0
7/8/2014	11:35:25	0	18	1	0
7/8/2014	11:35:40	0	17	1	0
7/8/2014	11:35:55	0	17	1	0
7/8/2014	11:36:10	0	14	1	0
7/8/2014	11:36:25	0	14	1	0
7/8/2014	11:36:40	0	10	1	0
7/8/2014	11:36:55	0	30	1	0
7/8/2014	11:37:10	0	61	1	0
7/8/2014	11:37:25	0	15	1	0
7/8/2014	11:37:40	0	15	1	0
7/8/2014	11:37:55	0	25	1	0
7/8/2014	11:38:10	0	22	1	0
7/8/2014	11:38:25	0	17	1	0

7/8/2014	11:38:40	0	28	1	0
7/8/2014	11:38:55	0	21	1	0
7/8/2014	11:39:10	0	23	1	0
7/8/2014	11:39:25	0	20	1	0
7/8/2014	11:39:40	0	21	1	0
7/8/2014	11:39:55	0	20	1	0
7/8/2014	11:40:10	0	17	1	0
7/8/2014	11:40:25	0	11	1	0
7/8/2014	11:40:40	0	8	1	0
7/8/2014	11:40:55	0	6	1	0
7/8/2014	11:41:10	0	6	1	0
7/8/2014	11:41:25	0	16	1	0
7/8/2014	11:41:40	0	23	1	0
7/8/2014	11:41:55	0	19	1	0
7/8/2014	11:42:10	0	10	1	0
7/8/2014	11:42:25	0	8	1	0
7/8/2014	11:42:40	0	8	1	0
7/8/2014	11:42:55	0	9	1	0
7/8/2014	11:43:10	0	11	1	0
7/8/2014	11:43:25	0	7	1	0
7/8/2014	11:43:40	0	6	1	0
7/8/2014	11:43:55	0	13	1	0
7/8/2014	11:44:10	0	17	1	0
7/8/2014	11:44:25	0	16	1	0
7/8/2014	11:44:40	0	10	1	0
7/8/2014	11:44:55	0	18	1	0
7/8/2014	11:45:10	0	32	1	0
7/8/2014	11:45:25	0	71	1	0
7/8/2014	11:45:40	0	74	1	0
7/8/2014	11:45:55	0	63	1	0
7/8/2014	11:46:10	0	54	1	0
7/8/2014	11:46:25	0	38	1	0
7/8/2014	11:46:40	0	24	1	0
7/8/2014	11:46:55	0	14	1	0
7/8/2014	11:47:10	0	10	1	0
7/8/2014	11:47:25	0	17	1	0
7/8/2014	11:47:40	0	26	1	0
Average		0.00	26.85	1.00	0.10
7/8/2014	11:47:55	19.8	20	1	0
7/8/2014	11:48:10	20.9	6	1	0
7/8/2014	11:48:25	21	1	1	0
7/8/2014	11:48:40	21	0	1	0
7/8/2014	11:48:55	21	0	1	0
7/8/2014	11:49:10	21	0	1	0
7/8/2014	11:49:25	21	0	1	0
7/8/2014	11:49:40	21	0	1	0
7/8/2014	11:49:55	21	0	1	0
7/8/2014	11:50:10	21	0	1	0
7/8/2014	11:50:25	21	0	1	0
7/8/2014	11:50:40	21	0	1	0
7/8/2014	11:50:55	21	0	1	0
7/8/2014	11:51:10	21	0	1	0



FORM 2: Calibration Recordkeeping For Portable Analyzers

Pre-Test Calibration

DATE: 7/3/2014 TIME (start/stop): 14:00 / 14:50
MONITOR: ECOM J2KN NAME: Total Air Analysis, Inc.

If the reading is re-calibrated, then put an "R" next to it in the box.

*** The NO and CO response times are the time required to respond to 95% of a step change in the analyzer response to the span gases. For NO₂, it is the time required to respond to 90% of a step change.



FORM 2 : Calibration Recordkeeping For Portable Analyzers

Post-Test Calibration

MONITOR: ECOM 12KN DATE: 7/11/2014 TIME (start/stop): 10:30 / 11:15 NAME: Total Air Analysis, Inc.

*If the reading is re-calibrated, then put an "R" next to it in the box

*** The NO and CO response times are the time required to respond to 95% of a step change in the analyzer response to the span gases. For NO₂, it is the time required to respond to 90

Appendix B

EPA Method 18

Total Hydrocarbons Determination

Methods of analyses

The values in the column "100% CH₄" refer to 100 % Methane.
The values below "Results former samples" refer to the original gas.

Methane (CH₄) according to DIN 51872-04-A (GC-FID)
Hydrocarbons according to VDI 3865 Bl. 4 (GC-FID)

Longuich, 01.08.2014

i. V. Dr. Thomas Häusler
(Laboratory Director)

i. A. Eva Friedrich
(Environmental Services - Laboratory)

Die Prüfergebnisse beziehen sich auf die untersuchten Proben. Die Veröffentlichung und Vervielfältigung unserer Prüfberichte und Gutachten zu Werbezwecken sowie auszugweise Verwendung in sonstigen Fällen bedürfen unserer schriftlichen Genehmigung. Alle Dienstleistungen werden auf Grundlage der anwendbaren Allgemeinen Geschäftsbedingungen der SGS, die auf Anfrage zur Verfügung gestellt werden, erbracht.

Laboratory:


卷之三


1210 East 2223 rd Street, # 314 Carson, CA 90745 (310) 518 5133 Fax: (310) 518 5107

CHAIN OF CUSTODY

Appendix C

Operating Outputs





Appendix D

Quality Assurance/Quality Control

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15AC1S8	Reference Number:	48-124363593-2
Cylinder Number:	CC203680	Cylinder Volume:	144.3 CF
Laboratory:	ASG - Los Angeles - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32013	Valve Outlet:	660
Gas Code:	NO	Certification Date:	Mar 20, 2013

Expiration Date: Mar 20, 2016

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	23.00 PPM	22.42 PPM	G1	+/- 1.4% NIST Traceable	03/13/2013, 03/20/2013
NITRIC OXIDE	23.00 PPM	22.34 PPM	G1	+/- 1.4% NIST Traceable	03/13/2013, 03/20/2013
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12061650	CC344943	20.23 PPM NITRIC OXIDE/NITROGEN	+/- 1.5%	Apr 15, 2015
NTRM	12061650	CC344943-NOX	20.28 PPM NOx/NITROGEN	+/- 1.5%	Apr 15, 2015

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Mar 14, 2013
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Mar 14, 2013

Triad Data Available Upon Request

Notes:

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Airgas Specialty Gases
 11711 S. Alameda Street
 Los Angeles, CA 90059
 (323) 568-2208 Fax: (323) 567-3686
www.airgas.com

Part Number:	E02NI99E15AC672	Reference Number:	48-124413173-2
Cylinder Number:	CC158749	Cylinder Volume:	144.3 CF
Laboratory:	ASG - Los Angeles - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32014	Valve Outlet:	350
Gas Code:	CO,BALN	Certification Date:	Jan 13, 2014

Expiration Date: Jan 13, 2022

Certification performed in accordance with "EPA Tracability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	90.00 PPM	89.80 PPM	G1	+/- 0.9% NIST Traceable	01/13/2014
NITROGEN	Balance				
CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062258	CC366865	97.56 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	May 25, 2018
ANALYTICAL EQUIPMENT					
Instrument/Make/Model		Analytical Principle	Last Multipoint Calibration		
Nicolet 6700 AMP0900118 CO		FTIR	Dec 18, 2013		

Triad Data Available Upon Request

Notes:

Approved for Release



CERTIFICATE OF ANALYSIS

Customer Name: Total Air Analysis, Inc.
Stock/Analyzer Tag #: A030-106780PN
Customer Reference: Verbal
MESA Reference: 111293
Date of Certification: February 15, 2013
Recommended Shelf Life: 2 Years

Cylinder Number: ALFS108858
Product Class: ±2% NIST Traceable
Cylinder Contents: 140 CF @ 2000 PSI
Cylinder CGA: A030-HP-660/SS
Analysis Method: Process Analyzers
Preparation Method: Gravimetric

Component	Requested Concentration (2)	Reported Concentration (2,3)
Nitrogen Dioxide	80 ppm	74.5 ppm
Nitrogen	Balance	Balance

Authorized Signature:

- (1) The fill pressure shown on the COA is as originally quoted. The fill pressure measured by the customer may differ from the fill pressure originally quoted due to temperature effects, compressibility of the individual components when blended together in the cylinder, gauge accuracy or reduction in content volume before shipping as a result of samples withdrawn for laboratory QC necessary to ensure product quality.
- (2) Unless otherwise stated, concentrations are given in molar units.
- (3) Vapor pressure mixes are blended at a sufficiently low pressure so as to eliminate phase separation under most low temperature conditions encountered during transport or storage. However, it is generally recommended that cylinders containing vapor pressure restricted mixes be placed on the floor in a horizontal position and rolled back and forth to improve homogeneity of the gas phase mixture before being put into service.

Analytical Gas Standards are prepared and analyzed using combinations of NIST traceable weights, SRM's provided by NIST, or internal gas standards that have been verified for accuracy using procedures published by the US-EPA. Pure gases are analyzed and certified for purity using minor component Analytical Gas Standards prepared according to the methods specified above. Balances are calibrated to NIST test weights covered by NIST test number 822/278982-10, S/N 33071. Reference Certification #'s: 1072/U, 901/V, 833/V, and 3280/E. Calibration methods are in conformance with MIL-STD 45662A.

MESA Specialty Gases & Equipment

division of MESA International Technologies, Inc.
2427 S. Anne St. • Santa Ana, California 92704 • USA
TEL: 714-434-7102 • FAX: 714-434-8006 • E-mail: mail@mesagas.com
On-line Catalog at www.mesagas.com