

BOARD MEETING DATE: November 5, 2021

AGENDA NO. 2

PROPOSAL: Set Public Hearing December 3, 2021 to Consider Adoption of and/or Amendments to South Coast AQMD Rules and Regulations:

Determine That Proposed Amended Rule 1134 – Emissions of Oxides of Nitrogen from Stationary Gas Turbines, Is Exempt from CEQA; and Amend Rule 1134

Proposed Amended Rule 1134 will remove ammonia limits for selective catalytic reduction systems that will be addressed during permitting, clarify applicable NOx concentration limits for recuperative gas turbines, and incorporate a narrow exemption for use of liquid fuel for turbines used at health facilities during natural gas curtailments. Other amendments are included to update provisions for Continuous Emission Monitoring Systems, remove startup and shutdown permit requirements which will be addressed in Rule 429 – Start-Up and Shutdown Exemption Provisions for Oxides of Nitrogen, and provide other clarifications. This action is to adopt the Resolution: 1) Determining that Proposed Amended Rule 1134 – Emissions of Oxides of Nitrogen from Stationary Gas Turbines, is exempt from the requirements of the California Environmental Quality Act; and 2) Amending Rule 1134 – Emissions of Oxides of Nitrogen from Stationary Gas Turbines. (Reviewed: Stationary Source Committee, October 15, 2021)

The complete text of the proposed rule, staff report and other supporting documents will be available from the South Coast AQMD's publication request line at (909) 396-2001, or Mr. Derrick Alatorre – Deputy Executive Officer/Public Advisor, South Coast AQMD, 21865 Copley Drive, Diamond Bar, CA 91765, (909) 396-2432, dalatorre@aqmd.gov and on the Internet (www.aqmd.gov) as of November 3, 2021.

RECOMMENDED ACTION:

Set public hearing December 3, 2021 to determine that Proposed Amended Rule 1134 – Emissions of Oxides of Nitrogen from Stationary Gas Turbines, is exempt from CEQA; and Amend Rule 1134.

Wayne Nastri
Executive Officer