

Amazon.com Services, LLC – POC2

Hearing Board Case #6267-2

Facility ID 203446

Regular Variance Conditions

May 13, 2026

1. Petitioner shall limit the operation of the Portable Internal Combustion Engines (ICE) as described in Permits to Operate (PO) Nos. G80184, G80185, G80186, and G80187 to supply electrical power only to maintain warehouse operations needed for the receipt, inventory management, storage, and distribution of materials and finished products.
2. Petitioner shall operate no more than three (3) of the four (4) permitted ICEs simultaneously at any time.
3. Petitioner shall maintain a monthly operating log for each ICE beginning May 1, 2026, and shall send the monthly operating log to South Coast AQMD by email to AQ Inspector II Mauricio Enriquez (menriquez@aqmd.gov) and AQ Engineer II Kaesean Brown, (kbrown1@aqmd.gov) on the first Tuesday of each month starting June 2, 2026. The operating log shall include the following for each ICE:
 - a. Date and hours of operation; and
 - b. Date, hours, and description of maintenance and testing operations.
4. Petitioner shall notify South Coast AQMD by email to AQ Inspector II Mauricio Enriquez (menriquez@aqmd.gov) and AQ Engineer II Kaesean Brown, (kbrown1@aqmd.gov) within one business day of receiving permanent electrical service from Southern California Edison (SCE) for the building(s) located at 4000 S Hamner Ave., Ontario CA 91761.
5. Petitioner shall cease operation of each ICE within one business day of receiving permanent electrical service from SCE for the building(s) located at 4000 S Hamner Ave., Ontario CA 91761.
6. Petitioner shall calculate, record, and report all excess emissions during the variance period, and pay the appropriate excess emission fees to the Clerk of the Board by January 31, 2027, or within 45 days of receiving permanent electrical service from SCE.