

I, Aaron Deguzman, declare:

1. I am a Radio Engineer with the Riverside County Sheriff's Public Safety Enterprise Communications Department (Petitioner). If called as a witness, I can testify to the following based on my personal knowledge.
2. I am familiar with and have reviewed the petition filed in support of Case No. 6229-4 and specifically with the equipment at issue in this petition, Internal Combustion (IC) Engine (P/O G02627) located at 488 Elsinore Heights, Lake Elsinore, CA92530 Facility ID# 159361).
3. Riverside County Sheriff's Public Safety Enterprise Communications (PSEC) is a public entity that provides communications to and from dispatchers for both law enforcement and many first responder entities throughout Riverside County.
4. In support of the findings required to grant this regular variance:
 - a. On or about May 7th, 2026, an unforeseen power loss occurred due to the site being vandalized leaving the site on emergency generator power. On May 14th Riverside County was able to restore power which kept the County within the allotted run time of 200 hours per year.
 - b. As a result of the vandalism, the Riverside County Public Safety Enterprise Communications (PSEC) Ridge Road site was left powered by an emergency generator for nearly a week due to sourcing materials and repairs needed to return the site to commercial power. Most if not all resources were engaged to support law enforcement and first responders alike. The Ridge Road communications site provides encrypted public safety radio coverage for Murrieta Fire, Police, and Riverside County Sheriff amongst interagency travelers.

- c. During my time in this role, I have worked with AQMD Counsel to accomplish the goals of a petition for variance on one other occurrence. In hopes that PSEC would be able to rectify the power issue at Ridge Road before the 200 hours was reached we waited 1 1/2 days before the site would reach the allotted hours. Fortunately, PSEC was able to source most of the material and was able to restore power on May 14th before reaching 200 hours. The permitted generator has run a total of 186.7 hours as of the date of this declaration. The petition for variance was requested due to fact that by the end of the year with nothing more than the regular service and weekly exercise the generator will fall out of compliance, particularly due to the fact that the summer marks the beginning of fire season.
- d. Replacements for the missing and stolen parts were ordered on May 8, 2026, and were installed on May 14, 2026. However, even with newly installed parts, there will only be 13.3 hours left on the engine through the end of 2026. Historically, the County has needed to run this engine over its allotted hours due to fire-related emergencies during this time of year. With only 13.3 hours left on the engine it is likely that the County will be in violation of its permitted limit soon.
- e. The benefit of keeping the engine operational outweighs turning it off due to air contaminants. The engine maintains essential communications, and the generators are located a significant distance away from any residential or business areas.
- f. On May 14, 2026, the new main fuse was installed and utility power was automatically restored by the automatic transfer switch to Ridge Road. The

generator's current hours is 186.7 hours for the 2026 calendar year. The variance requested is for future potential emergency use.

- g. I provided evidence and testimony in support of an Interim Variance, which was granted by this Board on June 3, 2026. I request that this testimony and evidence be incorporated into the record for purposes of this Regular Variance hearing.
- h. The County has continued to maintain compliance with the Interim Variance conditions since June 3, 2026. This includes running the ICE for no longer than 1 hour per month, maintaining a monthly operating log, and sending records to the South Coast AQMD.
- i. If not granted, a large portion of I15 freeway and covering the West side of the I15 in the Lake Elsinore surrounding area, could face a lack of critical communication during a power outage, which is more likely now that fire season has started. Maintaining communication is essential for law enforcement and first responders.

I declare under the penalty of perjury under the laws of the State of California that the foregoing is true and correct. Executed on the 15th day of July 2026 in Riverside, California.

Aaron DeGuzman

Aaron DeGuzman