BEFORE THE HEARING BOARD OF THE

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

In the Matter of SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. Petitioner, v. Green Gen LA LLC [Facility ID 192014] Respondent.	Case No. 6141-2 **DECLARATION OF MICHAEL MAZUR RE PETITION FOR AN ORDER FOR ABATEMENT; FILED IN SUPPORT OF CONSENT CALENDAR** Hearing Date: November 18, 2026 Time: 9:30 a.m. Place: South Coast Air Quality Management District 21865 Copley Drive Diamond Bar, CA 91765

I, Michael Mazur, declare:

1. I am the owner and operator of Green Gen LA LLC ("Green Gen"). If called as a witness, I could testify to the following based on personal knowledge
2. Green Gen operates a facility ("Facility") that converts landfill gas into energy at the Toyon Canyon Landfill using an internal combustion engine (ICE). The Facility is located at 5050 Mt. Hollywood Drive, Los Angeles, 90027, within South Coast AQMD's jurisdiction and is subject to South Coast AQMD rules. The facility holds an active permit to operate the ICE under South Coast AQMD Facility ID 192014.
3. I am familiar with the petition for Order for Abatement filed in Case no 6300-1, and I am familiar with the issues presented in the petition related to the South Coast AQMD Rule 218 requirement to install a continuous emission monitoring system (CEMS), as stated in Condition 15 of the permit to operate (P/O G64172).
4. The ICE started operation at the landfill on or about July 1, 2022. Since that time, the engine has operated regularly to generate electricity for sale to the electric grid.

5. During an inspection by the South Coast AQMD on or around January 22, 2026, the inspector observed the ICE in operating without a Rule 218-certified CEMS unit to monitor NOx emissions.

6. Following the inspection, the district determined that Green Gen had violated Rule 218(c)(1)(A) for operating its ICE without a District approved CEMS and issued a notice of violation (NOV P68897) on April 14, 2026, alleging a violation of Rule 218(c)(1)(A).


7. Green Gen submitted a complete CEMS application to the district on June 5, 2026, and which was issued an Initial Approval by Mr. Huy Le, an engineer with the South Coast AQMD Source Test Engineering group, on October 20, 2026.

8. Since receipt of the Initial Approval, Green Gen has ordered all CEMS equipment and components, which are scheduled for delivery during the month of November.

9. It is the intention of Green Gen to install and begin operating the CEMS as soon as all equipment, analyzers, and components are received and as soon as practicable.

10. Our tentative schedule indicates that the CEMS will be installed and operable, with certification testing completed, by February 17, 2027.

I declare under penalty of perjury under the laws of the State of California that the foregoing is true and correct. Executed this 4th day of November __, 2026 at Los Angeles, California.



MICHAEL MAZUR