

Revision

Revision 1 (DRAFT – Issue for Review)

Date

September 10, 2019

QUALITY ASSURANCE PROJECT PLAN
TORRANCE REFINERY RULE 1180 FENCELINE AIR
MONITORING SYSTEM

DRAFT

This page is intentionally blank.

DRAFT

A. PROJECT MANAGEMENT

A.1 Title and Approval Sheet

Document Title: Quality Assurance Project Plan for Torrance Refinery Rule 1180
Fenceline Air Monitoring System

Revision/Date: **Revision 1 (DRAFT – Issue for Review)/September 10, 2019**

System Owner: Name (print): _____
Environmental Manager
Torrance Refining Company
3700 W. 190th Street, Torrance, California 90504

_____/_____
Signature/Date

Program Quality Assurance Manager: Name (print): _____
Spectrum Environmental Solutions
2340 W Braker Lane Austin, Texas 78731

_____/_____
Signature/Date

System Manager/Operator: Name (print): _____
Spectrum Environmental Solutions
2340 Braker Lane, Suite A, Austin, TX 78758

_____/_____
Signature/Date

Rule 1180 Quality Assurance Officer: Name (print): _____
South Coast Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765

_____/_____
Signature/Date

This approval sheet may be signed in counterparts for full approval.

A.2 Table of Contents

A.	PROJECT MANAGEMENT	1
A.1	Title and Approval Sheet	1
A.2	Table of Contents	2
A.3	Distribution List	7
A.4	Project Organization and Roles	7
A.5	Problem Definition/Background	11
A.6	System Description and Approach	11
A.6.1	Open-Path Monitors	18
A.6.2	Fixed-Point Monitors	19
A.6.3	Meteorological Monitoring	20
A.6.4	Ancillary Equipment	21
A.7	Quality Objectives and Criteria	21
A.7.1	Project Quality Objectives	22
A.7.2	Measurement Performance Criteria	22
A.8	Training and Certifications	24
A.9	Documents and Records	24
B.	DATA GENERATION AND ACQUISITION	26
B.1	Sampling Process Design	26
B.2	Sampling Methods	26
B.2.1	Open-Path Monitoring Systems	26
B.2.2	Fixed-Point Monitor Data	27
B.2.3	Meteorological Data Collection	27
B.2.4	Backup Monitoring	27
B.3	Monitoring Data Documentation, Custody and Control	27
B.4	Analytical Methods	27
B.4.1	Spectral Methods for Open-Path analyzers	27
B.4.2	Black Carbon Analyzer	28
B.4.3	Hydrogen Sulfide Analyzer	28
B.5	Quality Control	29
B.5.1	Automated QA/QC	29
B.5.2	Statistics for the Assessment of QC Checks	29
B.6	Equipment Inspection, Testing, and Maintenance	30
B.6.1	Open-Path FTIR Monitor Inspection, Testing and Maintenance	31
B.6.2	Open-Path UVDOAS Monitor Inspection, Testing and Maintenance	31
B.6.3	Black Carbon Monitor Inspection, Testing and Maintenance	32
B.6.4	Inspection, Testing and Maintenance of Hydrogen Sulfide Monitors	33
B.6.5	Inspection, Testing and Maintenance of Meteorological Sensors	33
B.6.6	Remote and Visual Inspection	34
B.7	Equipment Calibration	35
B.7.1	Fenceline Air Monitoring System Validation for Open-Path Systems	35
B.7.2	Quality Assurance for Black Carbon Monitors (Aethalometers)	38
B.7.3	Quality Assurance for Hydrogen Sulfide Monitors	39
B.7.4	Meteorological Equipment Calibrations	39
B.7.5	Fenceline Air Monitoring System Calibration and Verification Recordkeeping	40
B.8	Inspection of Supplies and Consumables	40
B.9	Non-Direct Measurements	40
B.10	Data Management	41

B.10.1	Website Management and Community Interface	42
B.10.2	Public Notification System	42
C.	ASSESSMENT AND OVERSIGHT	43
C.1	Audits and Response Actions	43
C.1.1	Technical Systems Audits	43
C.1.2	Performance Evaluation Audits	44
C.2	Reports to Management	44
D.	DATA VALIDATION AND USABILITY	45
D.1	Data Review, Verification, and Validation	45
D.1.1	Open-Path and Point Source Monitors	45
D.1.2	Meteorology Sensors	46
D.2	Verification and Validation Methods	46
D.3	Reconciliation with Data Quality Objectives	48
D.3.1	Assessment of Measurement Performance	48
D.3.2	Data Quality Assessment	48

TABLES

Table A-1:	Distribution list	7
Table A-2:	Key individuals and responsibilities	8
Table A-3:	Target air pollutants and monitored meteorological parameters	14
Table A-4:	Rule 1180 fenceline air monitoring system equipment	14
Table A-5:	Approximate detection levels for open-path monitors	18
Table A-6:	Performance specifications for hydrogen sulfide and black carbon fixed-point monitors.	20
Table A-7:	Performance specifications for the meteorological tower components	20
Table A-8:	DQIs and MQOs for refinery fenceline air monitoring systems	23
Table A-9:	DQIs and MQOs for the meteorological tower system	23
Table B-1:	Inspection, testing and maintenance activities for open-path FTIR monitors	31
Table B-2:	Inspection, testing and maintenance activities for open-path UVDOAS monitors	32
Table B-3:	Inspection, testing and maintenance activities for black carbon monitors	32
Table B-4:	Inspection, testing and maintenance activities for hydrogen sulfide monitors	33
Table B-5:	Inspection, testing and maintenance activities for meteorological sensors	34
Table B-6:	Quality assurance for FTIR monitors	35
Table B-7:	Quality assurance for open-path UVDOAS monitors	36
Table B-8:	Reference gases to be used during commissioning and periodic QA checks for fenceline monitoring systems	38
Table B-9:	Quality assurance for black carbon monitors (aethalometers)	39
Table B-10:	Quality Assurance for hydrogen sulfide monitors	39
Table B-11:	Meteorological sensor calibration and accuracy criteria	40

FIGURES

Figure A-1:	QA organization chart	8
Figure A-2:	Layout of open-path FTIR, open-path UVDOAS and fixed-point monitors	13
Figure B-2:	Raw and validated data flow	41

APPENDICES

Appendix I – Fenceline Air Monitoring Equipment Specifications

Appendix II – Torrance Refinery Rule 1180 Fenceline Air Monitoring Plan

REVISION HISTORY

Revision	Date	Prepared by	Approved by	Comment
0	July 27, 2018	Glenn England	Scott Weaver	Issue for review - SCAQMD
1	September 10, 2019	Glenn England	Valerie Tse	Issue for review – DRAFT for SCAQMD review

TORCRule1180QAPP_Draft1.0.docx

DRAFT

ACRONYMS AND ABBREVIATIONS

Acronym	Definition
%	percent
°	degrees
°C	degrees centigrade
µg/m ³	micrograms per cubic meter
cm	centimeter
cm ⁻¹	inverse centimeters (wavelength)
CV	coefficient of variation
DC	direct current
DQI	data quality indicator
DQO	data quality objective
EPA	U.S. Environmental Protection Agency
FAQ	frequently-asked-questions
FTIR	Fourier transform infrared
GB	gigabytes
GHz	gigahertz
hPa	hectopascals
Hz	Hertz
K	Kelvins
km	kilometer
LAN	local area network
LED	light-emitting diode
m/s	meters per second
mm//hr	millimeters per hour
mm/hr	millimeters per hour
MQO	measurement quality objective
ng/m ³	nanograms per cubic meter
nm	nanometer
NO	nitric oxide
NO ₂	nitrogen dioxide
NO _x	nitrogen oxides
O&M	operation and maintenance
OPA	open-path analyzer location
OPR	open-path retroreflector location
PC	personal computer
ppb	parts per million
ppm	parts per million
PMT	photomultiplier tube
QA	quality assurance
QAPP	quality assurance project plan
QC	quality control
SCAQMD	South Coast Air Quality Management District
SEP	supplemental environmental project
SOPs	standard operating procedures
TBD	to be determined
TORC	Torrance Refining Company, LLC
USB	universal serial bus

Acronym	Definition
UV	ultraviolet
UVDOAS	ultraviolet differential optical absorption spectroscopy
VAC	volts alternating current
VDC	volts direct current
VOCs	volatile organic compounds
W	watts

DRAFT

A.3 Distribution List

The distribution list (Table A-1) identifies all individuals that should receive a copy of this Quality Assurance Project Plan (QAPP), either in hard copy or electronic format, including any subsequent revisions.

Table A-1: Distribution list

Name and Role	Organization	Email	Phone Number
Valerie Tse, System Owner	Torrance Refining Company	valerie.tse@pbfenergy.com	(310) 212-4597
Craig Sakamoto, Rule 1180 Program Manager	Torrance Refining Company	craig.sakamoto@pbfenergy.com	(310) 212-1884
Andrea Polidori, Rule 1180 Program Manager	South Coast Air Quality Management District	apolidori@aqmd.gov	(909) 396-3283
Brian Cochran, Program QA Manager	Spectrum Environmental Solutions	brian@spectrumenvsoln.com	(512) 739-2904
George Lipinski, System Manager/Operator	Spectrum Environmental Solutions	george@spectrumenvsoln.com	(512) 966-9685
Dan Currin, Data/QC Manager	Spectrum Environmental Solutions	Dan@spectrumenvsoln.com	(512)906-9128
Alex Bellon, Website/Data System Manager	Spectrum Environmental Solutions	Alex@spectrumenvsoln.com	(512)913-2213
Sam Celentano, Technical Specialist/Site Operator	Spectrum Environmental Solutions	Sam@spectrumenvsoln.com	(512) 646-4555
Casey Dreyer, Data Reviewer	Spectrum Environmental Solutions	Casey@spectrumenvsoln.com	(512) 646-4555
Cory Higdon, Data Reviewer	Spectrum Environmental Solutions	Cory@spectrumenvsoln.com	(512) 646-4555
Bryan Benaway, Lead Internal Auditor	Spectrum Environmental Solutions	Bryan@spectrumenvsoln.com	(512) 646-4555

A.4 Project Organization and Roles

This section identifies the roles and responsibilities of the key individuals involved in the operation of the fenceline air monitoring system (Table A-2) and lines of authority and communications between these individuals and authorities. The organizational chart (Figure A-1) provides lines of authority and communications for all organizations involved in operation and maintenance of the fenceline air monitoring system (including contractors and subcontractors) to accomplish the QA objectives specified in this QAPP.




Figure A-1: QA organization chart

Table A-2: Key individuals and responsibilities

Name	Organization	Roles	Responsibilities
Valerie Tse	Torrance Refining Company	System Owner	Overall system performance Financial resources to operate and maintain the System Appoint System Manager and Program QA Manager Review/approve QAPP
Craig Sakamoto	Torrance Refining Company	Rule 1180 Program Manager	Overall system operation, maintenance and data management Review/approve quarterly reports Procure Third-Party QA assessor
George Lipinski	Spectrum Environmental Solutions	System Manager/Operator	System operation and maintenance Oversee technical specialists and instrument suppliers Coordinate staff resources

Table A-2: Key individuals and responsibilities

Name	Organization	Roles	Responsibilities
Brian Cochran	Spectrum Environmental Solutions	Program Quality Assurance Manager	Prepare/revise/approve QAPP Conformance with QAPP QAPP updates & revisions Coordinate internal periodic QA checks and audits Review/approve quarterly reports
Dan Currin	Spectrum Environmental Solutions	Data/Quality Control Manager	Oversee data collection & processing Oversee daily data anomaly checks & investigations Oversee data review & validation Review/approve quarterly reports
Alex Bellon	Spectrum Environmental Solutions	Website/Data System Manager	Website administration Upload reports Ensure timely response to feedback Issue notifications
Sam Celentano	Spectrum Environmental Solutions	Technical Specialists/Site Operators	Remote and on-site system operation Preventative maintenance Unscheduled maintenance (including minor repairs) System maintenance notifications Prepare first draft quarterly reports
Casey Dreyer Cory Higdon	Spectrum Environmental Solutions	Data Reviewers	Monitor real-time data collection & processing Perform daily data anomaly checks & investigations Perform manual data review & validation
Bryan Benaway	Spectrum Environmental Solutions	Lead Internal Auditor	Internal auditing tasks Internal performance evaluations Internal periodic technical audits Internal reporting system audits
TBD	TBD	Third-Party Quality Assurance Assessor	Conduct third-party QA activities including: <ul style="list-style-type: none"> • Technical systems audits e.g., field, laboratory, data systems, data validation, data storage, reporting & recordkeeping, personnel, training; • Performance evaluation audits; • Data quality reviews.

Torrance Refining Company, LLC (Torrance Refinery) is the **System Owner** with overall responsibility for all aspects of fenceline air monitoring system. The System Owner provides the financial resources necessary to operate and maintain the fenceline air monitoring system in accordance with this QAPP. The System Owner appoints the organizations that will be responsible for system operation, maintenance, data management and reporting. The System Owner also reviews and approves the QAPP.

The system will be managed by a **Rule 1180 Program Manager** appointed by Torrance Refinery. The Rule 1180 Program Manager will act as the central point of contact for Torrance Refinery, the South Coast Air Quality Management District (SCAQMD) and the **Program Quality Assurance Manager**. The Rule 1180 Program Manager is responsible for overseeing the system's operation, maintenance, reporting, and data management.

The system will be operated by a **System Manager/Operator**. The System Manager/Operator will be responsible for operation and maintenance of the fenceline air monitoring system. The System Manager/Operator will oversee technical specialists, engineers, scientists, and technicians responsible for operation, maintenance, data collection, data quality, reporting, and website operations. The System Manager/Operator coordinates staff coverage and serves as a technical resource for site measurements.

The **Program Quality Assurance Manager** is responsible for assuring the quality of data on behalf of the Rule 1180 Program Manager. The Program Quality Assurance Manager may communicate directly with the System Owner, Rule 1180 Program Manager and SCAQMD, independently of the System Manager/Operator, providing assurance that any issues identified by the Program Quality Assurance Manager are promptly addressed. The Program Quality Assurance Manager provides QA oversight for the system and oversees and reports on QA activities to the Rule 1180 Program Manager. The Program Quality Assurance Manager assures that daily data review and data management activities are performed in accordance with the QAPP, works with the Rule 1180 Program Manager to ensure that any data issues are promptly addressed, and that data provided to the public are of high quality. The Program Quality Assurance Manager is responsible for developing QAPP updates and revisions when necessary.

Technical Specialists/Site Operators conduct system operation checks and perform instrument maintenance. The technical specialists ensure that all measurements are collected in accordance with SOPs, standard methods, and regulations, where applicable. Technical specialists perform the required quality checks on instruments and document all work in site logs. Technical specialists may conduct these activities on-site or remotely, as applicable to the specific activities.

The **Instrument Suppliers** provide technical support for the instruments deployed in the field.

The **Data/Quality Control Manager** is responsible for ensuring that daily data reviews are conducted, oversees data collection and review of data anomalies (e.g., fail auto-screening), and ensures that data validation follows the schedule and procedures described in the QAPP. The Data/Quality Control Manager is responsible for preparing quarterly reports, providing message board updates for O&M activities and report availability and for delivering the validated data to the System Manager/Operator.

Daily data review and data validation are conducted by experienced air monitoring system analysts. The **Data Reviewers** communicate with the Data/Quality Control Manager when there are issues and may also interact with the Technical Specialists when they observe potential O&M issues that needs to be addressed.

The **Website/Data System Manager** is responsible for properly displaying data on the website, managing inquiries from the public, and ensuring that validated quarterly reports are available for download on a quarterly basis. Automated alerting will notify the Website/Data System Manager when the real-time data are not available on the website. The Website/Data System will be responsible for assessing and fixing data communication and other information technology–related issues concerning the website and data system.

The **Lead Internal Auditor** will perform auditing tasks, performance evaluations, periodic technical audits, and system audits.

The **Third-Party QA Assessor** will be responsible for assessing whether the fenceline air monitoring system is being operated and maintained in accordance with the *Torrance Refinery Rule 1180 Fenceline Air Monitoring Plan* (provided in Appendix II) and this Quality Assurance Project Plan. The Third-Party QA Assessor or designated representative will coordinate and perform third-party QA activities. These will include developing and performing periodic technical systems audits and performance evaluation audits. The Third-Party QA Assessor will prepare audit reports to the Program Administrator and recommendations for corrective actions, if any.

A.5 Problem Definition/Background

This QAPP applies to a fenceline air monitoring system installed at the Torrance Refinery to comply with SCAQMD Rule 1180 *Refinery Fenceline and Community Air Monitoring*¹ (the “Rule”). This QAPP is intended to satisfy the requirements of Rule 1180 and its associated *Refinery Fenceline Air Monitoring Guidelines*.² As suggested in the SCAQMD Rule 1180 guidelines, this QAPP generally conforms with content requirements specified in EPA guidelines.³

Rule 1180 requires monitoring for target air compounds along the refinery fenceline using open-path optical and point measurement technologies and meteorological monitoring instruments. The Rule requires public access to the data in real time via a public website and notification system.

This QAPP defines criteria and actions that the project team will take to ensure that the data collected meet all regulatory requirements and the data quality objectives (DQOs) defined in the QAPP.

A.6 System Description and Approach

The fenceline air monitoring system will collect continuous monitoring data for the target pollutants utilizing open-path monitors and fixed-point monitors to provide continuous real-time data for target air pollutants at or near the Torrance Refinery perimeter fenceline. The monitoring system is intended as a permanent installation with an estimated lifespan of at least twenty years.

The system configuration includes six open-path analyzer locations (OPA), identified as OPA-1 through OPA-6 in Figure A-2 and listed in Table A-4. Each of these six locations will have one monostatic open-path Fourier transform infrared (FTIR) analyzer and one monostatic open-path ultraviolet differential optical absorption (UVDOAS) analyzer. All locations serve two paths⁴ on an alternating 5-minute basis by use of a computer-controlled motorized pan-and-tilt mount. For each of the six open-path analyzer locations there are two paths identified as “a” and “b”, with open-path retroreflector (OPR) for each analyzer located at the path end opposite the analyzer (e.g., path from OPA-1 to OPR-1a, path OPA-1

¹ See <http://www.aqmd.gov/docs/default-source/rule-book/reg-xi/r1180.pdf?sfvrsn=9> (accessed August 2019).

² See <http://www.aqmd.gov/docs/default-source/rule-book/support-documents/1180/rule-1180-guidelines.pdf> (accessed August 2019).

³ U.S.EPA, *Guidance for quality Assurance Project Plans*, QA-G5, 2002. EPA/240/R-02/009. See <https://www.epa.gov/sites/production/files/2015-06/documents/g5-final.pdf> (accessed August 2019)

⁴ See Figure A-2 in this QAPP and Section 5 of the *Torrance Refinery Rule 1180 Fenceline Air Monitoring Plan* (included in Appendix II) for path lengths.

to OPR-1b). Additionally, continuous fixed-point monitors for measuring black carbon and hydrogen sulfide are placed at six locations around the facility boundary (Figure A-2).

The fenceline air monitor locations were selected by considering potential for community exposure, locations of potential emission sources, and apparent prevalent wind directions. It is expected that the chosen locations will provide data representative of the overall air quality and meteorology of the area.

This QAPP also addresses meteorological monitoring as specified in the Rule 1180 Guidelines. Meteorological monitoring is necessary to characterize wind and weather patterns during monitoring and estimate movement and dispersion of pollutants. Rule 1180 Guidelines require monitoring for following meteorological parameters: ambient temperature, horizontal wind speed, horizontal wind direction, barometric pressure, relative humidity, visibility, and precipitation. The parameters to be monitored including target pollutants and meteorological parameters are listed in Table A-3. The major components and features of the system are summarized in Table A-4. See Appendix I of this QAPP for additional equipment specifications.

DRAFT




Figure A-2: Layout of open-path FTIR, open-path UVDOAS and fixed-point monitors

Table A-3: Target air pollutants and monitored meteorological parameters

Category	Parameters
Criteria air pollutants	Sulfur dioxide Nitrogen oxides (=nitric oxide + nitrogen dioxide)
Volatile organic compounds (VOCs)	Total VOCs (selected non-methane hydrocarbons) Formaldehyde Acetaldehyde Acrolein 1,3-Butadiene Benzene Toluene Ethylbenzene Xylenes (=o-xylene + m-xylene + p-xylene) Styrene ⁵
Other compounds	Hydrogen cyanide Hydrogen sulfide Carbonyl sulfide Ammonia Black carbon Hydrogen fluoride
Meteorological parameters	Horizontal wind speed and direction Temperature Precipitation Barometric pressure Relative humidity Visibility

Table A-4: Rule 1180 fenceline air monitoring system equipment

Component	Make/Model	Quantity
OPA-1 (Tag #A50001)		
Monostatic open-path FTIR system	Spectrum WaveRunIR	1
Monostatic open-path UVDOAS system	Spectrum OP-UVDOAS	1
Auto positioner/Pan and Tilt - open-path FTIR	Moog MPT-90	1
Auto positioner/Pan and Tilt - UVDOAS	Moog MPT-90	1
Local wind station	Met One All-in-One-2	1

⁵ Styrene data will be provided in quarterly reports only.

Table A-4: Rule 1180 fenceline air monitoring system equipment

Component	Make/Model	Quantity
OPA-2 (Tag #A50002)		
Monostatic open-path FTIR system	Spectrum WaveRunIR ⁶	1
Monostatic open-path UVDOAS system	Spectrum OP-UVDOAS ⁶	1
Auto positioner/Pan and Tilt - open-path FTIR	Moog MPT-90	1
Auto positioner/Pan and Tilt - open-path UVDOAS	Moog MPT-90	1
Black carbon monitor	Met One BC 1060	1
Hydrogen sulfide monitor	Teledyne API T101	1
Local wind station	Met One All-in-One-2	1
OPA-3 (Tag #A55001)		
Monostatic open-path FTIR system	Spectrum WaveRunIR ⁶	1
Monostatic open-path UVDOAS system	Spectrum OP-UVDOAS ⁶	1
Auto positioner/Pan and Tilt - open-path FTIR	Moog MPT-90	1
Auto positioner/Pan and Tilt - open-path UVDOAS	Moog MPT-90	1
Black carbon monitor	Met One BC 1060	1
Hydrogen sulfide monitor	Teledyne API T101	1
Local wind station	Met One All-in-One-2	1
OPA-4 (Tag #A72001)		
Monostatic open-path FTIR system	Spectrum WaveRunIR	1
Monostatic open-path UVDOAS system	Spectrum OP-UVDOAS	1
Auto positioner/Pan and Tilt - open-path FTIR	Moog MPT-90	1
Auto positioner/Pan and Tilt - open-path UVDOAS	Moog MPT-90	1
Black carbon monitor	Met One BC 1060	1
Hydrogen sulfide monitor	Teledyne API T101	1
Local wind station	Met One All-in-One-2	1
OPA-5 (Tag #A55002)		
Monostatic open-path FTIR system	Spectrum WaveRunIR	1
Monostatic open-path UVDOAS system	Spectrum OP-UVDOAS	1

⁶ To be installed and operated at completion of Supplemental Environmental Project (SEP) monitoring program, circa June 2021. See Section B.9 of this QAPP, Non-Direct Measurements for additional information.

Table A-4: Rule 1180 fenceline air monitoring system equipment

Component	Make/Model	Quantity
Auto positioner/Pan and Tilt - open-path FTIR	Moog MPT-90	1
Auto positioner/Pan and Tilt – open-path UVDOAS	Moog MPT-90	1
Black carbon monitor	Met One BC 1060	1
Hydrogen sulfide monitor	Teledyne API T101	1
Local wind station	Met One All-in-One-2	1
OPA-6 (Tag #A50003)		
Monostatic open-path FTIR system	Spectrum WaveRunIR	1
Monostatic open-path UVDOAS system	Spectrum OP-UVDOAS	1
Auto positioner/Pan and Tilt - open-path FTIR	Moog MPT-90	1
Auto positioner/Pan and Tilt – open-path UVDOAS	Moog MPT-90	1
Black carbon monitor	Met One BC 1060	1
Hydrogen sulfide monitor	Teledyne API T101	1
Local wind station	Met One All-in-One-2	1
OPR-1a		
Open-path FTIR Retroreflector	Spectrum	1
Open-path UVDOAS retroreflector	Spectrum	1
Black carbon monitor	Met One BC 1060	1
Hydrogen sulfide monitor	Teledyne API T101	1
OPR-1b		
Open-path FTIR Retroreflector	Spectrum	1
Open-path UVDOAS retroreflector	Spectrum	1
OPR-2a		
Open-path FTIR Retroreflector	Spectrum ⁶	1
Open-path UVDOAS retroreflector	Spectrum ⁶	1
OPR-2b		
Open-path FTIR Retroreflector	Spectrum ⁶	1
Open-path UVDOAS retroreflector	Spectrum ⁶	1
OPR-3a		
Open-path FTIR Retroreflector	Spectrum ⁶	1

Table A-4: Rule 1180 fenceline air monitoring system equipment

Component	Make/Model	Quantity
Open-path UVDOAS retroreflector	Spectrum ⁶	1
OPR-3b		
Open-path FTIR Retroreflector	Spectrum ⁶	1
Open-path UVDOAS retroreflector	Spectrum ⁶	1
OPR-4a		
Open-path FTIR Retroreflector	Spectrum	1
Open-path UVDOAS retroreflector	Spectrum	1
OPR-4b		
Open-path FTIR Retroreflector	Spectrum	1
Open-path UVDOAS retroreflector	Spectrum	1
OPR-5a		
Open-path FTIR Retroreflector	Spectrum	1
Open-path UVDOAS retroreflector	Spectrum	1
OPR-5b		
Open-path FTIR Retroreflector	Spectrum	1
Open-path UVDOAS retroreflector	Spectrum	1
OPR-6a		
Open-path FTIR Retroreflector	Spectrum	1
Open-path UVDOAS retroreflector	Spectrum	1
OPR-6b		
Open-path FTIR Retroreflector	Spectrum	1
Open-path UVDOAS retroreflector	Spectrum	1
Meteorological Tower System		
10-meter tower assembly	Met One 970895	1
Wind speed	Met One 101C/2672	1
Wind direction	Met One 020C/10296	1
Relative humidity/temperature	Met One 085-35/5980	1
Precipitation	Met One 360-1	1
Barometric pressure	Met One 092	1
Visibility	Met One 6400	1

A.6.1 Open-Path Monitors

The fenceline air monitoring system will use a combination of open-path monitors and fixed-point monitors. The system will include both open-path FTIR analyzers and open-path UVDOAS analyzers. Open-path monitors operate by projecting a beam of ultraviolet or infrared light through open air to a mirror (retroreflector) which reflects the light back to the monitor where spectral absorption characteristics are measured. The unique spectral absorption characteristics of each gas are used to calculate and record the concentrations of each gas present in the beam. The measurement represents an average concentration over the length of the beam. The Torrance Refinery open-path monitors will include consist of twelve analyzers at six locations serving twenty-four paths (twelve parallel paths) on all sides of the refinery with lengths between approximately 230-590 meters.

The light is transmitted to a retroreflector and back to a detector co-located with the transmitter. An auto-positioner (pan and tilt) will rotate the analyzer to alternate between two different retroreflectors for two paths at five-minute intervals, providing real-time five-minute measurements for each path at 10-minute intervals. The five-minute measurements also will be used to calculate 1-hour, 8-hour and, for black carbon only, 24-hour rolling averages for each of the compounds on Table A-5 updated every ten minutes.

The lower and upper detection levels for the open-path monitors are dynamic quantities. Detection levels will vary among different paths according to their fixed path lengths. Detection levels also will vary in time as analyzer performance and atmospheric conditions and composition vary. The instrument data systems will calculate the lower detection level for each five-minute pollutant measurement based on the past 30 minutes of measurement data.

The open-path monitors will include a reference gas cell that can be placed in the beam path during quality assurance activities. This will enable periodic quality assurance checks using reference gas mixtures containing known concentrations of a reference gas (or gases).

Additional equipment specifications are provided in Appendix I of this QAPP.

Table A-5: Approximate detection levels for open-path monitors

Parameter	Manufacturer	Model	Reporting units	Approximate lower detection level (ppb)	Approximate upper detection level ⁷ (ppm)
Hydrogen fluoride	Spectrum	WaveRunIR	ppb	4	10,000
Total VOCs				--	--
Nitrogen oxides				10	10,000
Formaldehyde				2	10,000
Acetaldehyde				10	10,000
Acrolein				4	10,000
1,3 Butadiene				8	10,000
Carbonyl sulfide				1.5	10,000

⁷ Upper detection levels will be available after manual validation and reprocessing of raw data.

Table A-5: Approximate detection levels for open-path monitors

Parameter	Manufacturer	Model	Reporting units	Approximate lower detection level (ppb)	Approximate upper detection level ⁷ (ppm)
Ammonia				2	10,000
Hydrogen cyanide				3	10,000
Sulfur dioxide	Spectrum	OP-UVDOAS	ppb	4	100
Benzene				0.5	100
Toluene				2	100
Ethyl benzene				5	100
Xylenes (m, o and p)				5	100

A.6.2 Fixed-Point Monitors

Black carbon and hydrogen sulfide will be monitored using fixed-point analyzers, which analyze samples collected from a single location each. Met One BC 1060 Black Carbon Monitors will monitor black carbon concentrations at six locations around the fenceline. The BC 1060 analyzer is a two-wavelength aethalometer, which measures the amount of black carbon in the air via attenuation of light signals across a filter tape. Ambient air is drawn through a size-selective inlet and through a glass fiber tape onto which ambient particulate matter is deposited. The tape is then advanced to a light detector, which measures optical transmission of light at 880 nanometers (nm) and 370 nm wavelengths through the tape filter, thereby providing an average measurement of ambient black carbon for the selected sampling time.

The lower detection limit for aethalometers will decrease with increasing sampling time. Thus, a single measurement collected over a one-hour period would have a lower detection level than a measurement collected over five minutes. The instruments will be configured to collect and record data in five-minute averages. The data will be used to calculate rolling averages for other time periods, updated every five minutes. The data will be evaluated during system commissioning to determine if five minutes is sufficient to meet the DQOs and may be adjusted for longer sampling durations if necessary.

Hydrogen sulfide will be monitored at six locations around the fenceline using Teledyne/Advanced Pollution Instrumentation (Teledyne/API) T101 hydrogen sulfide analyzers. In the T101 analyzer, sulfur dioxide is removed from the sample gas in a scrubber. Hydrogen sulfide in the sample gas then is converted into sulfur dioxide in a molybdenum converter operating at 315 °C, designed to minimize conversion of reduced sulfur species other than hydrogen sulfide. Sulfur dioxide then is measured through excitation by ultraviolet (UV) light, where sulfur dioxide molecules absorb UV light and become excited at one wavelength, then decay to a lower energy state emitting UV light at a different wavelength. The emitted light is captured on a photomultiplier tube through a bandpass filter tuned to wavelengths emitted by excited sulfur dioxide molecules and is translated into a reading of hydrogen sulfide concentration.

The hydrogen sulfide analyzer will collect and record data in five-minute averages. The data will be used to calculate rolling averages, updated every five minutes.

Table A-6 lists approximate pollutant detection limits and ranges for fixed-point monitors. See Appendix I of the QAPP for fixed-point monitor equipment specifications.

Table A-6: Performance specifications for hydrogen sulfide and black carbon fixed-point monitors.

Parameter	Manufacturer	Model	Reporting Units	Lower detection level	Upper detection level
Black carbon	Met One	BC-1060	ng/m ³	200	100,000
Hydrogen sulfide	Teledyne/ Advanced Pollution Instrumentation	T101	ppb	0.4	10,000

A.6.3 Meteorological Monitoring

The meteorological monitoring tower will use high quality sensors that meet EPA specifications⁸ for accuracy, range and resolution (Table A-7). The meteorological instruments will collect and record data continuously. The data will be used to calculate rolling averages updated every five minutes.

Table A-7: Performance specifications for the meteorological tower components

Parameter	Sensor Make and model	Reporting units	Accuracy ⁹	Range	Resolution
Horizontal wind speed	Met One 010C 3-cup anemometer	Meters per second (m/s)	± 0.1	0.4 - 55.9	0.1
Horizontal wind direction	Met One 020C airfoil vane	Degrees (°)	± 3	0 to 360	0.1
Ambient temperature	Met One 083E thermistor	Degrees Celsius (°C)	± 0.15	-30 to 50	0.1
Barometric Pressure	Met One 092 solid-state pressure transducer	Hectopascals (hPa)	± 0.35 (at 20 °C) ±1.0 over full range ±0.5 over any 200 hPa range	500 to 1,100	0.1
Relative humidity	Met One 083E thin film polymer capacitor	Percent (%)	± 2	0 to 100	0.1

⁸ *Quality Assurance Handbook for Air Pollution Measurement Systems*, Volume IV: Meteorological Measurements, U.S. Environmental Protection Agency, Research Triangle Park, North Carolina, March 2008, EPA-454/B-08-002. See https://www3.epa.gov/ttn/amtic/files/ambient/met/Volume_IV_Meteorological_Measurements.pdf (accessed July 19, 2018)

⁹ Accuracy, range and resolution values listed in this table are the manufacturer’s published performance specifications.

Table A-7: Performance specifications for the meteorological tower components

Parameter	Sensor Make and model	Reporting units	Accuracy ⁹	Range	Resolution
Precipitation	Met One 360 dual-chambered tipping bucket	Millimeter per hour (mm/hr)	± 1% of reading (0 to 30 mm/hr) ±5% of reading (30 to 120 mm/hr)	0 to 120	0.25
Visibility	Met One 6400 IR forward scattering	Kilometers (km)	± 10% of reading	0.006 to 80	--

A.6.4 Ancillary Equipment

Ancillary equipment includes sample inlets, sample transport lines, calibration and QA check equipment, computers, data loggers, communication devices, electricity supply and conditioning equipment, lighting, etc.

A.7 Quality Objectives and Criteria

DQOs for the fenceline air monitoring system were established to assure monitoring data can be reported with a known degree of confidence. DQOs presented in this QAPP were established considering EPA guidelines¹⁰ as a general example with modifications as appropriate for the informational purposes of this Rule 1180 monitoring system:

- Monitoring data will be collected with instrumentation that provides continuous averaged measurements;
- Records of quality control and quality assurance procedures performed during data collection will be retained. These include calibration checks with reference gases introduced into cells in the open-path monitor beams, fixed-point monitor calibrations, etc.;
- Reference gases shall be working standards certified by comparison to a National Institute of Science and Technology Gaseous Standard Reference Material, where these are commercially available;
- The data completeness objective will be 75% per calendar quarter for all fenceline air quality monitoring data including open-path monitors, fixed-point monitors and meteorological monitors. Note, open-path monitor interferences and signal degradation from uncontrollable adverse atmospheric conditions such as fog, rain, ozone, particulate matter and visibility affect data completeness; therefore, periods of incomplete data due to atmospheric conditions will be excluded from the determination of the data completeness.

It should be recognized that DQOs for open-path monitoring technologies are not well-established because they are new technologies in permanent monitoring system applications and performance in

¹⁰ *Ambient Monitoring Guidelines for Prevention of Significant Deterioration (PSD)*, U.S. Environmental Protection Agency, May 1987. EPA-450/4-87-007. See <https://www.epa.gov/sites/production/files/2015-07/documents/monguide.pdf> (accessed August 2019).

such applications is not well established. The actual reliability of the instruments will affect availability for collecting monitoring data. The frequency and magnitude of interferences from variable atmospheric conditions will affect the availability for collecting monitoring data and detection levels.

A.7.1 Project Quality Objectives

The overall project quality objective is to assure data quality commensurate with the requirements of the *Torrance Refinery Rule 1180 Fenceline Air Monitoring Plan* (provided in Appendix II). Data quality indicators (DQIs) for the system are provided below.

A.7.2 Measurement Performance Criteria

The DQIs which define monitoring system data quality relative to the DQOs are:

- Precision – a measure of agreement among repeated measurements of the same property under identical or substantially similar conditions;
- Bias – the systematic or persistent distortion of a measurement process that causes errors in one direction;
- Accuracy – a measure of overall agreement of a measurement to a known value; it includes a combination of random error (precision) and systematic error (bias);
- Representativeness – a qualitative term that expresses “the degree to which data accurately and precisely represent a characteristic of a population;
- Comparability – a qualitative term that expresses the measure of confidence that one data set has when compared to another;
- Sensitivity – a measure of a method or instrument’s ability to discriminate between measurement responses representing different levels of the variable of interest; and
- Completeness – a measure of the amount of valid data obtained from a measurement system.

Representativeness was addressed during the design of this air monitoring network and can be evaluated in terms of the spatial coverage and temporal resolution. For example, the system described in this plan includes measurement paths that will actively monitor pollutant concentrations along approximately 85% of the refinery perimeter fenceline. These measurement paths border residential, commercial, and industrial communities on all sides of the refinery and provide near-complete coverage on the predominantly downwind sides. With regard to temporal resolution, all of the measurement equipment utilized in this study sample continuously and generate high time resolution data (i.e., 5-minute discrete or average measurements). As such, the design will assure that the data generated by the fenceline air monitoring system will appropriately characterize pollutant concentrations along the refinery fenceline. An assessment of the representativeness of this project’s monitoring data also will take place as a part of the processes described in Section D.3 of this QAPP, Reconciliation with Data Quality Objectives.

Comparability is assessed in multiple ways, including comparing measured concentrations against historical air data and data from nearby air monitoring stations (e.g., comparing measured ozone data against nearby SCAQMD-operated ozone monitors). Additional information on this topic is included in Section D.1 of this QAPP, Data Review, Verification, and Validation.

The remaining DQIs are addressed in measurement quality objectives (MQOs) for open-path and fixed-point monitors (Table A-8) and meteorology monitors (Table A-9). Completeness will be evaluated against the calendar quarter data set of hourly averages with a minimum 75% completeness of 5-minute data (adverse atmospheric conditions, acts of God, vandalism, terrorism,

loss of station power or other events over which neither the refinery nor their monitoring contractor has control over will not be included in data loss calculations). Note that an MQO for precision is not specified for meteorological measurements. Formulas for calculating DQIs are presented in Section B.5 of this QAPP.

Table A-8: DQIs and MQOs for refinery fenceline air monitoring systems

DQIs	MQOs for open-path systems	MQOs for fixed point systems	MQOs for meteorological systems
Completeness	75%	75%	75%
Accuracy	See Tables B-6 – B-7	See Tables B-9 – B-10	See Table B-11
Precision	See Tables B-6 – B-7	See Tables B-9 – B-10	See Table B-11
Sensitivity (detection limits)	See Table A-5	See Table A-6	--

Table A-9: DQIs and MQOs for the meteorological tower system¹¹

Measurement	Method	Reporting Units	Operating Range	System Accuracy	Sensitivity (resolution)	Completeness
Ambient Temperature	Thermistor	°C	-30 to 50	± 0.15	0.1	75%
Relative Humidity	Psychrometer/Hygrometer	%	0 to 100	± 2	0.1	75%
Barometric Pressure	Aneroid Barometer	hPa	500 to 1,100	±0.35 (at 20 °C) ±1.0 over full range ±0.5 over any 200 hPa range	0.01	75%
Wind Speed	Cup or sonic anemometer	m/s	0.4 to 50.0	± 0.1	0.003 (0.1 mph)	75%
Wind Direction	Vane or sonic anemometer	Degrees (°)	0 to 360	± 5, includes orientation error	0.1	75%
Precipitation	Tipping Bucket	mm/hr	0 to 50	±1% of reading (0 to 30 mm/hr) ±5% of reading (30 to 120 mm/hr)	0.25	75%

¹¹ Accuracy, range and resolution values listed in this table are the manufacturer’s published performance specifications of the corresponding sensors.

Table A-9: DQIs and MQOs for the meteorological tower system¹¹

Measurement	Method	Reporting Units	Operating Range	System Accuracy	Sensitivity (resolution)	Completeness
Visibility	Forward light scattering	meters	0.006 to 80	± 10% of reading	--	75%

A.8 Training and Certifications

Adequate education and training are key components to any successful monitoring system that strives to produce data of known quality meeting DQOs. Activities conducted under this QAPP will be performed by individuals with proper training and experience. All personnel assigned to operation, maintenance, quality assurance, and data handling will be sufficiently trained in the underlying technical and scientific principles behind the air monitoring equipment being used. Staff assigned to operate and maintain the system will be trained on operation and maintenance of the system prior to and during the start-up phase. The System Manager/Operator will determine specific training requirements for operation and maintenance of the system. Training will be provided by the System Manager/Operator or designated representatives, and a record of training will be maintained by the System Manager/Operator.

A.9 Documents and Records

The System Manager/Operator is responsible for distributing the most recently-approved QAPP (and other documents used throughout the project operation) to all personnel identified in the QAPP distribution list via email. Controlled versions of all project documents, including the QAPP, will be maintained in electronic format by the Program Quality Assurance Manager on a network server location accessible to the System Manager/Operator, Rule 1180 Program Manager, and Program Quality Assurance Manager staff. The QAPP and project documents should be reviewed, updated and re-approved as the fenceline air monitoring system requirements, design or equipment change. These documents can be made available to SCAQMD staff upon request.

The dataset created for this monitoring program will consist of these components stored for at least five years in the project database and project files:

- For open-path monitors:
 - The 5-minute concentration measurements for each path;
 - Detection limits for the 5-minute concentration measurements generated from each path;
 - Calculated 1-hour and 8-hour rolling average concentrations and respective detection limits for each path;
 - Individual absorption spectra for 5-minute measurements from each path;
- 5-minute average wind speed, wind direction, ambient temperature, barometric pressure, visibility, relative humidity and visibility measurements at the meteorological tower, and the calculated hourly rolling average of the 5-minute meteorological data;
- 5-minute average concentration data generated from each hydrogen sulfide monitor and the calculated 1-hour and 8-hour rolling average concentrations; and

- 5-minute average concentration data generated from each black carbon monitor and the calculated 8-hour and 24-hour rolling average concentrations.

The following sources of information will support these data:

- Station log books (in electronic form);
- Absorption spectra and raw data files from the open-path FTIR and UVDOAS monitors;
- Calibration and maintenance records for all measurement systems;
- Data validation and editing instructions;
- Quarterly QA audits of field operations and system performance; and
- Third-party QA audit, inspection, assessment and corrective action reports.

Quarterly data summary reports will be prepared as a part of this air monitoring program. These reports will include a comparison of monitored target pollutant concentrations against their respective health thresholds, assessments of data completeness, a description of any significant instrument issues encountered, and a summary of quality control efforts. Additional detail on these quarterly reports are provided in Section B.10, Data Management and Section C.2, Reports to Management of this QAPP.

DRAFT

B. DATA GENERATION AND ACQUISITION

B.1 Sampling Process Design

Fenceline air monitoring data will be collected using open-path instruments to measure and record pollutant concentrations over a path interval of nominally 500 meters (corresponding to a folded optical path length of 1000 meters for the monostatic systems) along or near the Torrance Refinery fenceline. Additionally, continuous fixed-point monitors will be used at six representative locations on or near the facility fenceline to monitor levels of black carbon and hydrogen sulfide. The selection of monitoring sites is discussed in the *Torrance Refinery Rule 1180 Fenceline Air Monitoring Plan* (provided in Appendix II). Additional information on the design of this monitoring network is provided in Section A.6 of this QAPP.

B.2 Sampling Methods

This section describes the field work associated with this program, including the sampling methods and equipment that are used. All measurements are performed on a continuous basis; no physical samples are collected for offsite analysis. Standard operating procedures and methods for all of the measurement equipment used in this study can be found in the respective equipment operation manuals.

B.2.1 Open-Path Monitoring Systems

This QAPP will serve as the primary reference for the open-path FTIR and open-path UVDOAS monitoring systems for the Torrance Refinery. All pertinent O&M and QA/QC procedures are cited as references and summarized in this QAPP.

The open-path analyzers are described in Section A.6.1 of this QAPP. The open-path FTIR analyzer is a Spectrum WaveRunIR™, and the open-path UVDOAS analyzer is a Spectrum OP-UVDOAS analyzer. Both are mono-static multi-gas open-path analyzers. The analyzer systems operate by sending a beam of infrared or ultraviolet light through open air from a light source to a retroreflector cube array that redirects the light beam back to the analyzer.

The System Manager Operator team will remotely perform daily system checks, data validations, and will travel to the site as needed to perform both routine and emergency maintenance. The Technical Specialists/Site Operators will provide on-site checks and necessary routine maintenance (system alignment optimization, bulb replacement, etc.) or repairs. A cellular modem interface to the analyzer computer(s) and to the alarm system allows the System Manager/Operator team to remotely retrieve data and system logs, conduct system performance checks, and perform certain types of system recoveries and adjustments.

The open-path monitors will record concentrations along pathway segments along or near the perimeter fenceline. Each measurement will be collected over a 5-minute period. All the monitors will cover two adjacent pathways via use of an auto-positioner (pan and tilt) that will rotate the instrument between the two paths at programmed 5-minute intervals.

Pollutant concentration data will be collected using on-site computers which will parse the data and perform preliminary automated QC of the data. The data is then sent to a cloud server through a cellular connection every five minutes. Once delivered to the cloud server, validation calculations and distribution will occur. Concentration values will be presented on a public website as five-minute measurement data, rolling 1-hour averages, rolling 8-hour averages and, for black carbon only, rolling 24-hour averages, updated for each path every ten minutes.

B.2.2 Fixed-Point Monitor Data

The fixed-point monitors for black carbon and hydrogen sulfide are described in Section A.6.2 of this QAPP. The continuous data from each monitor will be collected in five-minute averages, updated every five minutes. The five-minute average data will be used to calculate 1-hour rolling averages and 1-hour rolling block averages will be used to calculate 8-hour and 24-hour rolling averages.

B.2.3 Meteorological Data Collection

Meteorological instruments installed on a 10-meter tower at one location within the refinery are described in Section A.6.3 of this QAPP. The meteorological instruments will be configured to collect and record data with high resolution (e.g., every five-minutes). The meteorological data may be used, for example, to establish pollutant trajectories or determine if the measured pollutant concentrations on a fenceline path originate upwind or downwind of Torrance Refinery operations.

B.2.4 Backup Monitoring

Rule 1180 requires alternate or temporary monitoring systems when the continuous monitoring systems are offline for extended periods (e.g., for maintenance or repair). The alternative monitoring systems will not be used to determine individual gaseous target compounds and/or surrogates when the open-path systems are down due to atmospheric conditions, but only in the event of extended periods for unscheduled maintenance or outages.

The backup monitoring plan is described in Section 6.6 of the *Torrance Refinery Rule 1180 Fenceline Air Monitoring Plan* (provided in Appendix II). The approach to backup monitoring may be adjusted over time, for example, as techniques and technologies evolve.

B.3 Monitoring Data Documentation, Custody and Control

The real-time open-path monitors and fixed-point monitors used to collect data for the fenceline air monitoring system do not involve physical sample shipping or custody transfer. However, the real-time monitoring data produced by the monitors will be secured and carry chain-of-custody information to prevent unauthorized changes. Field operation records include site visit logs, continuous monitor calibration/validation documents, and maintenance logbooks. Many of these records are in electronic form, primarily as spreadsheets or text files. All field operation records are returned at least monthly to the Data/QA Manager for inclusion in the project files. The automatic data polling systems are password protected and only selected System Manager/Operator team members have access.

Monitoring data chain-of-custody records will be maintained as specified in Section 2 of the Rule 1180 Guidelines. The original monitoring data records (including the original spectral data from open-path monitors) will be stored as read-only files. Changes will be made only to duplicates of the original files. Changes to data records, when required, will generally occur during data validation activities. Each data record will include one or more fields for data qualifiers entered during data review and validation. If a change is required, the original record will be flagged "invalid – correction applied" or similarly marked and will not be included in recalculation of time-averaged results. A duplicate record with corrected data will be created for the same date and time and flagged "duplicate – validated" and included in recalculation of time-averaged results. The time and date of each change to a data record, if any, will be noted along with the names of the persons making and approving each change.

B.4 Analytical Methods

The analytical methods for each monitor type are described briefly below.

B.4.1 Spectral Methods for Open-Path analyzers

The analytical methods employed for the open-path FTIR and open-path UVDOAS systems are based on applying a least squares regression analysis to compare calibrated reference spectra to measured

absorption spectra as described in EPA Compendium Method TO-16¹². Tables A-5 and A-6 of the QAPP present the target compounds and their respective detection limits. Table 7-2 of the *Torrance Refinery Rule 1180 Fenceline Air Monitoring Plan* (provided in Appendix II) lists the selected health-based inhalation exposure thresholds for each compound.

B.4.2 Black Carbon Analyzer

BC concentrations are calculated based on a presumed relationship between measured optical attenuation through the filter tape as BC accumulates and ambient BC levels based on historical measurement data collected by thermo-optical methods. The relationship between the attenuation of laser light through quartz filters onto which ambient particulate samples containing soot had been collected and the concentration of “graphitic carbon” of the same samples has been established in previous literature, and this correlation has been found to be linear over a wide concentration range.^{13,14}

The BC analyzer measures ambient concentration of black carbon by measuring the change in optical transmission as BC-containing particulate matter accumulates onto a filter. Transmission of light coming from light emitting diodes is measured across filter tape onto which sampled aerosol containing BC is being accumulated. Reference transmission across a clean portion of the filter tape is simultaneously measured. As BC accumulates onto the filter tape light transmission across the portion of the tape onto which BC is accumulating relative to the reference transmission will decrease. This transmission data is converted into BC concentration by normalizing by volumetric flow rate, time interval of measurement and cross-sectional area of the filter spot.

The Met One BC 1060 black carbon analyzer uses two industry-standard wavelengths, 880 nm and 370nm, to determine the concentration of black carbon and “UVPM” (UV light absorbing PM).

B.4.3 Hydrogen Sulfide Analyzer

UV fluorescence fixed-point monitors will be used to monitor hydrogen sulfide. The Teledyne/Advanced Pollution Instrumentation T101 UV fluorescence hydrogen sulfide analyzer is selected to monitor hydrogen sulfide concentrations at six locations around the fenceline. Hydrogen sulfide is measured on the principle that hydrogen sulfide can be converted into sulfur dioxide. The hydrogen sulfide-to-sulfur dioxide converter receives sample gas from which the sulfur dioxide has been removed by a scrubber, which removes sulfur dioxide from the sample gas. The hydrogen sulfide converter is a molybdenum converter operating at 315 °C and is designed to minimize conversion of reduced sulfur species other than hydrogen sulfide. Sulfur dioxide is measured through excitation by UV light from a low-pressure zinc-vapor lamp.

Sulfur dioxide molecules absorb UV light and become excited at a wavelength of approximately 214 nm, then decay to a lower energy state emitting UV light at wavelength of 330 nm. Excitation light is supplied by a low-pressure zinc-vapor lamp, and light from the lamp is focused using a UV source lens and passes through a bandpass filter configured to allow light with a wavelength of 214 nm, the excitation frequency of sulfur dioxide.

¹² *Long-Path Open-Path Fourier Transform Infrared Monitoring of Atmospheric Gases*, Compendium Method TO-16, U.S. Environmental Protection Agency, Cincinnati, Ohio, 1999. See <https://www3.epa.gov/ttn/amtic/files/ambient/airtox/to-16r.pdf> (accessed July 19, 2018).

¹³ Rosen, H., Hansen, A. D., Gundel, L., and Novakov, T., “Identification of the optically absorbing component in urban aerosols.” *Appl. Opt.*, **17**:3859-3861, 1978.

¹⁴ Gundel, L., Dod, R., Rosen, H., and Novakov, T., “The relationship between optical attenuation and black carbon concentration for ambient and source particles.” *The Science of the Total Environment*, **36**:197-202, 1984.

Light emitted from the decay of excited sulfur dioxide molecules is captured on a photomultiplier tube (PMT) through a bandpass filter tuned to a wavelength of 330 nm corresponding to light emitted by excited sulfur dioxide molecules. This filter trips away light outside of the fluorescence spectrum of decaying excited sulfur dioxide including reflected UV from the source lamp and other stray light. To further assure that the PMT only detects light given off by decaying sulfur dioxide the pathway of the excitation UV and field of view of the PMT are perpendicular to each other and the inside surfaces of the sample chamber are coated with a layer of black Teflon® that absorbs stray light.

B.5 Quality Control

This section describes QC calculations for the monitoring systems.

B.5.1 Automated QA/QC

Automated QA/QC checks will be performed continuously on all incoming data. Additionally, data will be compared against threshold concentrations determined specifically for facility conditions. If anomalies are found in incoming data, an email notification will be sent to the System Manager/Operator and Program Quality Assurance Manager.

B.5.2 Statistics for the Assessment of QC Checks

Calculations of measurement uncertainty will be carried out following procedures like those used for ambient air monitoring networks¹⁵, provided in the following subsections.

B.5.2.1 Percent Difference

All measurement quality checks start with a comparison of an audit concentration or value (flow rate) to the concentration/value measured by the analyzer using the percent difference calculation shown in Equation 1. For each single point check the percent difference, d_i , is calculated as follows:

$$d_i = \frac{meas - audit}{audit} \times 100 \quad \text{Equation 1}$$

Where, $meas$ is the concentration indicated by the monitoring organization's instrument and $audit$ is the audit concentration of the standard used in the QC check being measured.

B.5.2.2 Precision Estimate

The precision estimate is used to assess the one-point QC checks for each instrument. The precision estimator is the coefficient of variation (CV) and is calculated using equation 2:

$$CV, \% = \frac{\sigma_{meas}}{C_{meas}} \times 100 \quad \text{Equation 2}$$

Where C_{meas} is the average measured gas concentration and σ_{meas} is the standard deviation of the measurements, defined as:

$$\sigma_{meas} = \sqrt{\frac{\sum (C_{meas} - C_{meas})^2}{n-1}} \quad \text{Equation 3}$$

Where C_{meas} is a single measured concentration and n refers to the number of measurements conducted.

B.5.2.3 Accuracy Estimate

Accuracy, A , is defined as:

¹⁵ Quality Assurance Requirements for Monitors used in Evaluations of National Ambient Air Quality Standards, Appendix A, Part 58, Title 41 U.S. Code of Federal Regulations.

$$A, \% = \frac{C_{audit} - C_{meas}}{C_{audit}} \times 100 \quad \text{Equation 4}$$

Where C_{audit} refers to the average value of the reference gas and C_{meas} refers to the average value of all measurements.

B.5.2.4 Completeness

Completeness is a measure of the amount of valid data obtained from a measurement system. Completeness objectives are listed in Table A-8 for open-path and fixed-point monitors and Table A-9 for meteorological monitors.

Due to the nature of open-path measurement devices, atmospheric conditions such as fog, high humidity, rain, ozone, particulate matter, haze, and other conditions can affect a monitor's ability to provide reliable data. Since these conditions are uncontrollable, it is not possible to mitigate their effects.

Scheduled and unscheduled maintenance also results in loss of data. Scheduled or preventative maintenance is predictable and accounted for in setting data completeness objectives. Unscheduled maintenance is determined by the robustness of the monitoring equipment designs, component selections and preventative maintenance procedures. It should be noted that the reliability of the open-path monitors is not well known over long periods of continuous operation and this was considered in establishing data completeness objectives.

The data completeness criteria for all monitoring systems (fixed point, open-path and meteorological) is 75% for hourly, daily and quarterly data completeness. Hourly, daily and quarterly completeness for open-path systems are defined as follows:

$$\% \text{ complete}_{\text{hourly}} = 100 \times \frac{n_{\text{valid}}}{12 - n_{\text{excluded}}} \quad \text{Equation 5}$$

Where n_{valid} refers to the number of valid 5-minute measurements taken within one hour, and n_{excluded} refers to the number of measurements invalidated due to atmospheric conditions or scheduled maintenance.

$$\% \text{ complete}_{\text{daily}} = 100 \times \frac{h_{\text{valid}}}{24 - h_{\text{excluded}}} \quad \text{Equation 6}$$

Where h_{valid} refers to the number of hours in a day with complete data (i.e., hours that have met or exceeded the target completeness percentage) and h_{excluded} refers to the number of hours during which all data is invalidated due to unsuitable atmospheric conditions or scheduled maintenance.

$$\% \text{ complete}_{\text{quarterly}} = 100 \times \frac{d_{\text{valid}}}{d_{\text{quarter}} - d_{\text{excluded}}} \quad \text{Equation 7}$$

Where d_{valid} refers to the number of days in the quarter with complete data (i.e., days that have met or exceeded the target completeness percentage), d_{quarter} refers to the number of days in that quarter and d_{excluded} refers to the number of days during which all data is invalidated due to unsuitable atmospheric conditions or scheduled maintenance.

The completeness target for the meteorological systems will be 90%, following the same definitions as above.

B.6 Equipment Inspection, Testing, and Maintenance

The System Manager/Operator team performs equipment inspection, testing and routine maintenance to assure the monitoring data quality meets DQOs. This section cites procedures and summarizes recordkeeping requirements for all field analytical instrumentation and equipment. Instrument maintenance logs will be maintained, and all instrumentation will be checked prior to use. Detailed

descriptions of how inspections and maintenance activities are performed can be found in the instrument operation manuals referenced in this section (see “Procedure Documents” listed in Tables B-1 through B-5). Additionally, information on how re-inspections should be performed and how to assess the effectiveness of corrective actions can also be found in the instrument manuals referenced in this section.

Field personnel will also be responsible for ensuring that critical spare parts are included with the field instruments to reduce potential downtime for repairs. The inventory will primarily contain parts that are subject to frequent failure, have limited useful lifetimes, and/or cannot be obtained in a timely manner.

B.6.1 Open-Path FTIR Monitor Inspection, Testing and Maintenance

Routine open-path FTIR monitor inspection, testing and maintenance will be performed according to the manufacturer’s recommendations (Table B-1). This table also list the recommended frequency for each activity and cites the section numbers of the manufacturer’s Operation and Maintenance Manual (Procedure Document) where the procedures may be found.

Table B-1: Inspection, testing and maintenance activities for open-path FTIR monitors

Activity	Frequency	Procedure Document
Cleaning the optical bearing	Every 2 years	<i>Open-Path FTIR Manual, Spectrum Environmental Solutions, Section 3.1</i>
Validation cell inspection	Annually	<i>Open-Path FTIR Manual, Spectrum Environmental Solutions, Section 3.3</i>
IR source inspection	Annually	<i>Open-Path FTIR Manual, Spectrum Environmental Solutions, Section 3.4</i>
HeNe laser voltage level inspection	Annually	<i>Open-Path FTIR Manual, Spectrum Environmental Solutions, Section 3.5</i>
IR detector inspection	Annually	<i>Open-Path FTIR Manual, Spectrum Environmental Solutions, Section 3.8</i>
Optimizing the Tracker Positioning	Quarterly	<i>Open-Path FTIR Manual, Spectrum Environmental Solutions, Section 3.9</i>
Retroreflector array cleaning	Every six months	<i>Open-Path FTIR Manual, Spectrum Environmental Solutions, Section 3.10</i>
Telescope turning flat cleaning	Every six months	<i>Open Path FTIR Manual, Spectrum Environmental Solutions, Section 3.11</i>
Telescope optics cleaning	Every two years	<i>Open-Path FTIR Manual, Spectrum Environmental Solutions, Section 3.11</i>

B.6.2 Open-Path UVDOAS Monitor Inspection, Testing and Maintenance

Routine open-path UVDOAS monitor inspection, testing and maintenance will be performed according to the manufacturer’s recommendations (Table B-2). This table also list the recommended frequency for each activity and cites the section number of the manufacturer’s Operation and Maintenance Manual (Procedure Document) where the procedures may be found.

Table B-2: Inspection, testing and maintenance activities for open-path UVDOAS monitors

Activity	Frequency	Procedure Document
Cleaning retroreflector array	Every six months	<i>Open-Path UV Manual</i> , Spectrum Environmental Solutions, Section 3.2
Validation cell inspection	Annually	<i>Open-Path UV Manual</i> , Spectrum Environmental Solutions, Section 3.3
UV lamp inspection	Annually	<i>Open-Path UV Manual</i> , Spectrum Environmental Solutions, Section 3.4

B.6.3 Black Carbon Monitor Inspection, Testing and Maintenance

Routine black carbon monitor inspection, testing and maintenance will be performed according to the manufacturer’s recommendations (Table B-3). This table lists the suggested frequency for each activity and cites the section number of the manufacturer’s Operation and Maintenance Manual (Procedure Document) where the procedures may be found. Maintenance that is recommended on an “as required” basis will be evaluated once the systems are commissioned at the facility.

Table B-3: Inspection, testing and maintenance activities for black carbon monitors

Activity	Minimum frequency	Procedure Document
Temperature, Pressure, and Flow Audits and Calibrations	Monthly	BC 1060 Operation Manual ¹⁶ , Met One Instruments, Section 6.4
Flow System Leak Checks	Quarterly	BC 1060 Operation Manual ¹⁶ , Met One Instruments, Section 6.5
Debris Filter Changes	Annually	BC 1060 Operation Manual ¹⁶ , Met One Instruments, Section 6.6
Inlet and Cyclone Cleaning	Quarterly	BC 1060 Operation Manual ¹⁶ , Met One Instruments, Section 6.7
Filter Tape Installation, Loading, and Filter Material Notes	As required (typically 2- to 12-month intervals depending on sampling duration between measurements)	BC 1060 Operation Manual ¹⁶ , Met One Instruments, Section 3.7
Span check	Quarterly	BC 1060 Operation Manual ¹⁶ , Met One Instruments, Section 6.4
Leak test	Quarterly	BC 1060 Operation Manual ¹⁶ , Met One Instruments, Section 6.5
Replace cyclone O-rings	As required	BC 1060 Operation Manual ¹⁶ , Met One Instruments, Section 6.7

¹⁶ BC 1060 Black Carbon Monitor Operation Manual, BC 1060-9800, REV A, Met One Instruments.

B.6.4 Inspection, Testing and Maintenance of Hydrogen Sulfide Monitors

Routine hydrogen sulfide monitor inspection, testing and maintenance will be performed according to the manufacturer’s recommendations (Table B-4). This table lists the suggested frequency for each activity and cites the section number of the manufacturer’s Operation and Maintenance Manual (Procedure Document) where the procedures may be found. Maintenance recommended on an “as required” basis will be evaluated once the systems are commissioned at the facility.

Table B-4: Inspection, testing and maintenance activities for hydrogen sulfide monitors

Activity	Frequency	Procedure document
Change the sample particulate filter	Weekly	Teledyne API, User Manual Model T101 UV Fluorescence hydrogen sulfide Manual ¹⁷ , Section 7.3.1
Replace the sulfur dioxide scrubber reagent	Every six months	Teledyne API, User Manual Model T101 UV Fluorescence H ₂ S Manual ¹⁷ , Section 7.3.3
Change the external zero air scrubber	Every six months	Teledyne API, User Manual Model T101 UV Fluorescence H ₂ S Manual ¹⁷ , Section 7.3.4
Replace the hydrogen sulfide-to-sulfur dioxide converter catalyst	Annually or as required	Teledyne API, User Manual Model T101 UV Fluorescence H ₂ S Manual ¹⁷ , Section 7.3.5
Change the critical flow orifice and sintered filters	Annually	Teledyne API, User Manual Model T101 UV Fluorescence H ₂ S Manual ¹⁷ , Section 7.3.7
Perform flow check	Every six months	Teledyne API, User Manual Model T101 UV Fluorescence H ₂ S Manual ¹⁷ , Section 8.5.2
Verify test functions	Weekly	Teledyne API, User Manual Model T101 UV Fluorescence H ₂ S Manual ¹⁷ , Appendix C

B.6.5 Inspection, Testing and Maintenance of Meteorological Sensors

Routine meteorological sensor inspection, testing and maintenance will be performed according to the manufacturer’s recommendations (Table B-5). This table lists the suggested frequency for each activity and cites the section number of the manufacturer’s Operation and Maintenance Manual (Procedure Document) where the procedures may be found. Most of these sensors should operate for an extended period of time with a minimum of care or maintenance.

¹⁷ Model T101 UV Fluorescence H₂S Analyzer, Document 07266C DCN7335, 10 August 2016. Teledyne API.

Table B-5: Inspection, testing and maintenance activities for meteorological sensors

Sensor	Activities	Frequency	Procedure Document
Met One 010C wind speed sensor	Inspect for proper operation	Every 6 months	Met One Model 010C Wind Speed Sensor Manual, Section 4.2
	Inspect wind speed sensor bearings	Every 6 months	Met One Model 010C Wind Speed Sensor Manual, Section 4.5
Met One 020C wind direction sensor	Inspect for proper operation	Every 6 months	Met One Model 020C Wind Direction Sensor Manual, Section 7.6
	Inspect wind direction sensor bearings	Every 6 months	Met One Model 020C Wind Direction Sensor Manual, Section 8.1
Met One 083E relative humidity and temperature sensor	Inspect for proper operation	Every 6 months	Met One Model 083E/085 Relative Humidity / Temperature Sensor Manual, Section 4.0
Met One 092 barometric pressure sensor	Clean the sintered filter	As required	Met One Model 092 Barometric Pressure Sensor Manual, Section 8.0
Met One 360 precipitation gauge	Clean the funnel and buckets. Verify that the bucket moves freely.	Every 6 months	Met One Model 360 Precipitation Gauge Operation Manual, Section 4.0
Met One 6400 visibility sensor	Inspect for proper operation. Clean optics.	Every 3 months	Belfort Instrument Visibility Sensor Manual Model 6400, Section 4.0

B.6.6 Remote and Visual Inspection

Quality control activities will include:

- Periodic checks by a remote operator;
- Periodic and as-needed site visits; and
- Documentation of the condition of the various equipment in the site log book. Any equipment maintenance or repairs also will be documented in the site log.

Data validation will be performed in real time and at regular intervals to verify measurement anomalies and facilitate early detection of equipment malfunctions. Any discrepancies in the logs or inconsistencies with this QAPP will be brought to the attention of the Rule 1180 Program Manager, Program Quality Assurance Manager, and the System Manager/Operator. Corrective actions will be implemented by the System Manager/Operator as appropriate, verified by the Program Quality Assurance Manager and reported to the Rule 1180 Program Manager. Section D.1 of this QAPP provides additional details regarding data validation activities.

B.7 Equipment Calibration

This section summarizes calibration procedures and frequency. For open-path systems, there are no field calibrations because the instruments are factory calibrated to spectral reference libraries. A reference gas cell and one reference gas of known concentration will be used with the open-path monitors for quality assurance purposes. Periodic calibration checks will be performed for the fixed-point and meteorological monitors.

Calibrations and validations, flow rate checks, audits, and calculations will be selectively reviewed by the Program Quality Assurance Manager to ensure that:

- Quality assurance procedures are being followed;
- The performance of all equipment is within the limits specified in this document;
- All calculations are being performed properly; and
- All data are reasonable and technically consistent.

B.7.1 Fenceline Air Monitoring System Validation for Open-Path Systems

Verify the instrument performance through various checks, many of which are described in EPA Method TO-16r¹² and in the *EPA Handbook for Optical Remote Sensing for Measurement and Monitoring of Emissions Flux and Particulate Matter*¹⁸. This document outlines general QA/QC procedures for a variety of sensing technologies, and its guidelines were used to inform this QAPP.

The frequency and acceptance criteria for each check is shown in Tables B-6 through B-8.

Table B-6: Quality assurance for FTIR monitors

Parameter	Frequency	Acceptance criteria	Procedure document
Reference gas QA checks	Quarterly for first two years; semi-annually if QA checks meet acceptance criteria in at least 80% of preceding eight quarterly checks. After major maintenance Initial commissioning	Accuracy: $\leq 30\%$ of reference gas value, calculated using Equation 4 presented in Section B.5.2 Precision: $\pm 25\%$, calculated using Equation 2 presented in Section B.5.2	<i>Factory and Site Acceptance Test Plan, TORC Rule 1180 Project, Spectrum Environmental Solutions, Section 2.1.5</i>
Line shift	Continuous	0.5 cm ⁻¹ resolution	<i>Factory and Site Acceptance Test Plan, TORC Rule 1180 Project, Spectrum Environmental Solutions, Section 2.1.2</i>
Black body radiation (background)	Continuous	--	<i>Open-Path FTIR Manual, Spectrum Environmental Solutions, Section 2.2.2 Basics of Data Collection</i> Software algorithm executed every 5 minutes

¹⁸ *EPA Handbook: Optical and Remote Sensing for Measurement and Monitoring of Emissions Flux of Gases and Particulate Matter*, U.S. Environmental Protection Agency, September 1, 2018. See <https://www.epa.gov/sites/production/files/2016-06/documents/gd-052.pdf> (accessed May 2019).

Table B-6: Quality assurance for FTIR monitors

Parameter	Frequency	Acceptance criteria	Procedure document
Baseline noise determination	Once at commissioning	Instrument signal intensity divided by the sum of instrument noise and stray light must be > 5	<i>Factory and Site Acceptance Test Plan, TORC 1180 Project, Spectrum Environmental Solutions, Section 2.1.3 Noise Equivalent Absorbance (NEA) Testing</i>
Stray light check	Continuous	--	<i>Open-Path FTIR Manual, Spectrum Environmental Solutions, Section 2.2.2 Basics of Data Collection; Software algorithm executed every 5 minutes</i>
Detection level (sensitivity)	Quarterly for first two years; semi-annually if QA checks meet acceptance criteria in at least 80% of preceding eight quarterly checks. After major maintenance Initial Commissioning	Equal to or less than the approximate minimum detection levels specified in this QAPP for each target pollutant	<i>Factory and Site Acceptance Test Plan, TORC 1180 Project, Spectrum Environmental Solutions, Section 2.1.4 Detection Limit Sensitivity</i>
Instrument Resolution	Once at Commissioning	0.5 cm ⁻¹ resolution	<i>Factory and Site Acceptance Test Plan, TORC Rule 1180 Project, Spectrum Environmental Solutions, Section 2.1.1 Instrument Resolution</i>
Detector Linearity	Once at Commissioning	< 3.0% standard deviation	<i>Factory and Site Acceptance Test Plan, TORC Rule 1180 Project, Spectrum Environmental Solutions, Section 2.1.6 Detector Linearity</i>
Path Repeatability Tests	Once at Commissioning	< 3.0% standard deviation	<i>Factory and Site Acceptance Test Plan, TORC Rule 1180 Project, Spectrum Environmental Solutions, Section 2.1.7 Path Repeatability Tests</i>

Table B-7: Quality assurance for open-path UVDOAS monitors

Parameter	Frequency	Acceptance criteria	Procedure document
Reference gas check	Quarterly for first two years; semi-annually if QA checks meet acceptance criteria in at least 80% of preceding eight quarterly checks. After major maintenance Initial Commissioning	Accuracy: ≤ 30% of reference gas value, calculated using Equation 4 presented in Section B.5.2 Precision: ± 25%, calculated using Equation 2 presented in Section B.5.2	<i>Factory and Site Acceptance Test Plan, TORC Rule 1180 Project, Spectrum Environmental Solutions, Section 2.2.5</i>

Table B-7: Quality assurance for open-path UVDOAS monitors

Parameter	Frequency	Acceptance criteria	Procedure document
Detection level (sensitivity)	Annual	Equal to or less than the approximate minimum detection levels specified in this QAPP for each target pollutant	<i>Factory and Site Acceptance Test Plan, TORC 1180 Project, Spectrum Environmental Solutions, Section 2.2.4 Detection Limit Sensitivity</i>
Line shift	Continuous	0.5 cm ⁻¹ resolution	<i>Factory and Site Acceptance Test Plan, TORC 1180 Project, Spectrum Environmental Solutions, Section 2.2.2 Line Shift Correction</i>
Baseline noise equivalent absorbance (NEA) test	Once at commissioning	--	<i>Factory and Site Acceptance Test Plan, TORC 1180 Project, Spectrum Environmental Solutions, Section 2.2.3 Noise Equivalent Absorbance (NEA) Testing</i>
Path repeatability test	Once at commissioning	< 3.0% standard deviation	<i>Factory and Site Acceptance Test Plan, TORC 1180 Project, Spectrum Environmental Solutions, Section 2.2.6</i>

Note, because open-path instruments rely on accurate spectroscopy, surrogates are used in place of measuring DQOs for each parameter. All open-path instruments will have a reference gas or a QA cell. Reference gases with path adjusted concentrations¹⁹ will be used for checking DQOs.

B.7.1.1 Reference Gas Spectra

Each FTIR monitor will be compared against a known IR spectra curve (e.g., from the Pacific Northwest National Laboratory) for certain pollutants of concern. An instrument challenge test is conducted by taking a measurement of a known concentration in an enclosed cell placed into the normal measurement path, over a fixed path length and at a known temperature and pressure. This serves as a quality assurance check in the presence of all the spectral interferences present in the normal measurement path. That measurement is then compared to the reference spectra, and if values are within acceptable criteria, the calibration can be verified. Calibration generally requires one point, since absorption and response are linear.

A FTIR or UVDOAS challenge test with one measured gas verifies performance for all measured gases because it verifies the spectral measurements and analysis used for all gases.¹⁸ Instrument challenge tests will be performed with ethyl benzene, selected because of its lesser toxicity compared with other target pollutants and satisfactory absorbance in both the infrared and ultraviolet bands making it suitable for both the FTIR and UVDOAS challenge tests.

Another type of QA check is known as an “atmospheric challenge.” In this check, the atmospheric concentration of a gas measured by the open path system will be compared against an expected or known concentration value. For the UVDOAS systems, the atmospheric check will be conducted by

¹⁹ To achieve the same ppb-m absorbance with the short reference gas cell as in the full monitor path, reference gas concentrations need to be much higher than in the ambient air (in proportion to the optical path length difference between the monitor path and reference cell).

comparing the measured ambient air ozone concentration against the ozone concentration measured by a nearby ambient ozone monitor operated by an independent organization (e.g., SCAQMD). For the FTIR systems, the atmospheric check will be conducted by comparing the measured concentration of nitrous oxide (N₂O) against its global average concentration of approximately 330 ppb²⁰. This check is possible with N₂O as it is a fixed atmospheric gas with a relatively uniform spatial and temporal distribution.

Table B-8 summarizes information for both of these challenges. Atmospheric challenges and instrument challenges should be performed after initial commissioning, major repair or replacement; spectral method changes; and periodically as needed. The results of all challenges will be noted in the operations log. Any significant difference between measured and expected concentrations will be noted and investigated.

Table B-8: Reference gases to be used during commissioning and periodic QA checks for fenceline monitoring systems

Challenge Type	UVDOAS monitors	FTIR monitors
Instrument challenge	Ethyl benzene (or equivalent gas) approximately 120 ppb path equivalent (750 ppm/balance nitrogen)	Ethyl benzene (or equivalent gas) approximately 120 ppb path equivalent (750 ppm/balance nitrogen)
Atmospheric challenge	Measured atmospheric ozone is compared against nearby ozone monitoring site(s)	Measured atmospheric nitrous oxide is compared against the global average nitrous oxide concentration (approximately 330 ppb)

B.7.1.2 Baseline Determination and Spectral Line Drift

Instrument noise is the radiation seen by an instrument resulting from the operation of internal electronics and sensors. A spectral baseline reading is determined by measuring the instrument noise in a controlled environment. Each time a FTIR monitor is powered up or on a quarterly basis, the spectral baseline will be determined, to account for this baseline when calculating concentrations.

Over time, the baseline reading can drift, especially as the instrument heats up during use. Therefore, the first hour of data collected after powering up an instrument will be discarded, to allow the instrument to properly warm up and begin collecting valid data.

B.7.1.3 Stray Light Check

Prior to installation of open-path FTIR monitors, a stray light check will be conducted to determine the percentage of light coming from background sources, when compared to the instrument readings. The intensity of the instrument signal shall be at least 5 times the combined intensity of background light and instrument noise.

B.7.2 Quality Assurance for Black Carbon Monitors (Aethalometers)

Table B-9 lists quality assurance criteria for the black carbon monitors.

²⁰ See <https://www.n2olevels.org/> (accessed September 9, 2019).

Table B-9: Quality assurance for black carbon monitors (aethalometers)

Method	Frequency	Acceptance criteria	Procedure document
Flow Calibration	Once every 6 months	$\leq \pm 5\%$ (% difference)	BC1060 Black Carbon Monitor ¹⁶ , Met One Instruments, Section 6.4
Leakage check	Once every 6 months	$\leq \pm 10\%$ (% difference)	BC1060 Black Carbon Monitor ¹⁶ , Met One Instruments, Section 6.5
Neutral density optical filter test	Annual	$\leq \pm 10\%$ (% difference of slope of attenuation values)	BC1060 Black Carbon Monitor ¹⁶ , Met One Instruments, Section 6.4.6

B.7.3 Quality Assurance for Hydrogen Sulfide Monitors

Table B-10 lists calibration procedures and acceptance criteria for the hydrogen sulfide monitors. Reference gases with hydrogen sulfide concentrations of 0 ppb, 100 ppb and 1,000 ppb will be introduced during the zero/span calibration.

Table B-10: Quality Assurance for hydrogen sulfide monitors

Parameter	Frequency	Acceptance Criteria	Procedure Document
Zero/span calibration	Every three months	$\pm 10\%$	Teledyne API, Model T101 UV Fluorescence H ₂ S Analyzer, User Manual ¹⁷ , Section 6
sulfur dioxide scrubber check	Every three months	$\leq 2\%$	Teledyne API, Model T101 UV Fluorescence H ₂ S Analyzer, User Manual ¹⁷ , Section 7.3.3
Hydrogen sulfide converter efficiency check	Every three months	$\geq 96\%$	Teledyne API, Model T101 UV Fluorescence H ₂ S Analyzer, User Manual ¹⁷ , Section 7.3.5

B.7.4 Meteorological Equipment Calibrations

This section summarizes calibration information for the meteorological sensors at the meteorological tower system. The meteorological sensors are fully calibrated by the manufacturer at the time of purchase. Additional calibrations and system audits for all meteorological equipment will be conducted on a bi-annual basis, with calibrations and audits alternating on a periodic basis. The frequency for calibration and accuracy checks was established on the basis that these measurements are for information purposes rather than for monitoring relative to established standards. Table B-11 summarizes the calibration and accuracy criteria for the meteorological equipment.

Table B-11: Meteorological sensor calibration and accuracy criteria

Measurement parameter	Measurement principle	Accuracy criteria	Frequency
Ambient temperature	Aspirated Thermistor Met One 076B, 060-A2	±1.0 °C	Every 12 months
Relative humidity	Thin film polymer capacitor, Met One 083E	±7% relative humidity	Every 12 months
Barometric pressure	Capacitor Met One 090D	±3 mb	Every 12 months
Wind speed	Anemometer/Pulse Frequency Counter Met One 010C	±0.2 m/s	Every 12 months
Wind direction	Vane Potentiometer Met One 020C	±5 degrees	Every 12 months
Precipitation	Dual-chambered tipping bucket Met One 360	±10%	Every 12 months
Visibility	IR forward scattering Met One 6400	±10%	Every 12 months

B.7.5 Fenceline Air Monitoring System Calibration and Verification Recordkeeping

All calibration data will be recorded and documented following the processes described in Section A.9, Documents and Records, and B.10, Data Management. Additionally, the field operator will document the serial numbers of all equipment used in the calibration process in the field log, and identifying information for all gas standards (e.g., cylinder ID, certification date, verified concentration, etc.) will be documented in the field log. The field operator will have primary responsibility for analyzing the calibration data following the procedures and processes described and referenced in this section.

B.8 Inspection of Supplies and Consumables

Acceptance criteria for supplies and consumables vary with the operation being conducted and are generally described in the relevant SOPs. In general, the SOPs are checked to ensure the adequate criteria for supplies and consumables are met and appropriate for use for the operation. Reference gas labels will be checked to ensure they are traceable to NIST standards and meet the required accuracy and concentration specifications. All parts received via shipment will be opened and examined to ensure they are not damaged, the packing slips will be archived, and an inspection log shall be maintained which records when the incoming shipments were received and inspected.

The spare parts and consumable items strategy is designed to achieve the data completeness criteria without an inventory of redundant complete analyzers. The System Manager/Operator will order and maintain spare parts inventory for the fenceline air monitoring systems, at the minimum quantities recommended by the respective suppliers and as necessary to achieve the data completeness criteria. The System Manager/Operator will also maintain a consumable supplies inventory and update it as consumable items are used, or as new parts are ordered. The System Manager/Operator will perform routine and emergency maintenance, including the replacement of spare parts, in an expedited manner.

B.9 Non-Direct Measurements

This section identifies types of data that are not directly generated or collected by this measurements program. As referenced in Table A-4 (air monitoring system equipment by location), the open path

measurement systems (UVDOAS and FTIR) at OPA-2 and OPA-3 will not be operated by Torrance Refinery until the conclusion of a Supplementary Environmental Project (SEP) being administered by SCAQMD. The SEP is scheduled for completion by approximately June 2021. Until that time, the open path monitors at these two locations and related operation, maintenance, and data validation will be supplied by a third party. The Torrance Refinery fenceline air monitoring system will download data produced by the SEP systems into its database and display them on the public website; however, Torrance Refinery is not responsible for validating the SEP data. See Section B.10.1, Website Management and Community Interface, for additional information.

B.10 Data Management

Pollutant concentration data will be collected using on-site computers which will parse the data and perform preliminary automated QC of the data. The data is then sent to a cloud server through a cellular connection – every five minutes for further validation, archiving, and distribution. Once delivered to the cloud server, validation calculations and distribution will occur. Concentration values will be presented on a public website as five-minute measurements, 1-hour rolling averages, 8-hour rolling averages, and, for black carbon only, 24-hour rolling averages. These values will be updated for each path every ten minutes for the open-path systems and every five minutes for fixed-point monitors.

The pathway for raw and validated data is shown in Figure B-2 and described in detail in the following sections.




Figure B-2: Raw and validated data flow

B.10.1 Website Management and Community Interface

A publicly accessible website will be created to display data in real time. A detailed description of the website with a proposed layout, directions for interactions, and figures is provided in Section 7 of the *Torrance Refinery Rule 1180 Fenceline Air Monitoring Plan* (provided in Appendix II), but a brief overview of its functionality is provided below.

The overall goals of the website are to: inform the public of pollutant concentrations at or near the refinery fenceline; inform the public of fenceline air monitoring system operations, outages, and events; and educate the public on the health-based concentration thresholds, monitoring techniques and procedures, and provide links to community emergency response planning resources.

A message board page will show a history of notifications in chronological order. This will primarily be used to notify the public of pollutant concentrations that are greater than thresholds, instrument outages (planned or unplanned), and announce the availability of quarterly data reports. Users will also be able to subscribe, to receive automated notifications from the website through an email service.

A data page will show real time values for conditions at the facility in an interactive map. Users can view current concentrations at any of the monitors placed around the facility fenceline and view meteorological conditions in real time. Users also will be able to view historical data for a given time period, monitor, and parameters of their choosing.

All quarterly data reports will be made available on the website for download through the Reports page. Any third-party data displayed on the website or contained in quarterly reports will be clearly marked as such.

Finally, a Learning Center page will provide some insight into monitoring operations, in the form of a FAQ page. This section will also provide information on the monitors used, potentially emitted pollutants and their health effects, significant threshold levels, commonly used terms and definitions, etc. Links will be provided to additional resources for users that want to learn even more.

B.10.2 Public Notification System

An email notification system, available to anyone, will send automated email alerts to announce a pollutant anomaly, planned or unplanned monitor outages, or the availability of quarterly data reports.

Automated public notifications will be sent via email immediately after a 1-hour rolling average pollutant concentration is measured that is greater than its respective inhalation exposure threshold. Measurements invalidated via the automatic QA/QC system, such as during known instrument outages or when instruments are showing operational errors, will not generate automated public notifications. However, they will be reviewed by the Data/Quality Control Manager and the Program Quality Assurance Manager.

C. ASSESSMENT AND OVERSIGHT

C.1 Audits and Response Actions

The project team includes a quality assurance specialist whose duties are solely in the area of independent assessment of the measurement effort. This individual is part of the same corporate organization as the project team but holds no duties or interests in the operation of any of the monitoring sites and networks that he/she audits. To promote objectivity and independence, the specialist maintains designated audit equipment in a separate location from the operations center and has access to the Program Quality Assurance Manager for assistance in promoting the quality objectives of the company. The Program Quality Assurance Manager is also available to assist in resolution of project issues related to quality. Assessments conducted for this project fall into two categories: Technical systems audits and performance evaluation audits. Both provide vital information regarding the status of the project team operation and how well the measurement data adhere to the quality specifications of the QAPP.

All performance and technical systems audits are conducted following the guidance documents in the “EPA Quality Assurance Handbook” series, Volumes I, II, and IV. Additional method specific quality guidance is provided by the applicable sections of the manufacturer operating manuals, in the absence of an EPA guidance document specific to the application of an equipment-specific measurement.

C.1.1 Technical Systems Audits

Technical systems audits for the field operation have several areas of focus. The primary goal of Technical system audits is to determine if operation and maintenance of the fenceline air monitoring system conforms with the procedures and criteria specified in this QAPP. The audit is conducted employing a checklist as a guide to the major topics to be assessed, and the auditor is free to allot greater amounts of time to any particular area as needed. The checklist is prepared in advance of the audit and is based on information presented in the QAPP and in general, the guidance of the EPA QA Handbook series.

The field technical system audit includes a review of overall equipment siting and exposure, site visit logs, continuous analyzer and meteorological operating procedures and documentation and any site maintenance activities. From this assessment, the auditor is able to determine the quality requirements for the monitoring effort from the QAPP, and then report on the level of adherence to the specifications. This review includes traceability documentation for gas standards and test equipment to conduct quality control checks on pollutant and meteorological monitors. Where the specification appears incomplete or inadequate, the auditor should be able to apply EPA guidance document information and personal experience.

Technical systems audits may cover the following instrumentation aspects:

- Compare actual O&M practices with SOPs;
- Inspect preventative and unscheduled maintenance logs;
- Inspect spare parts inventories;
- Inspect exterior and interior structures (clean, serviceable, etc.);
- Review of logs and determinations if past problems were addressed/resolved;
- Examine all open-path, point source and meteorological monitor functions and components using the maintenance checklist to confirm that the equipment is operating with manufacturer specifications; and

- Analysis methods for of target compound(s) accuracy, precision and sensitivity per requirements listed in Table A-8 and A-9.

C.1.2 Performance Evaluation Audits

Performance evaluation audits are quantitative audits and will be conducted periodically coincident with one of the programmed quarterly assurance checks. Performance evaluation audits will consist of third-party reviews of open-path analyzer spectral analysis and blind challenges of the monitors with reference gases with concentrations known only to the third-party assessor. Performance evaluation audits will be performed by the Third-Party QA Assessor.

C.2 Reports to Management

Report for field performance and technical systems audits conducted include a statement of the scope of the audit, summary presentation of results, and a listing of specific observations or findings related to the specifications under review. Also, the field data and traceability documents for each audit standard employed are included. The auditor should always provide the field technician and or the System Manager/Operator a list of preliminary findings and recommendations during a debriefing meeting held at the conclusion of the audits. If significant deficiencies are determined that impact the ability of the system to properly function, the System Manager/Operator will be notified immediately. The System Manager/Operator will notify the Rule 1180 Program Manager of the situation and advise them of the response actions being undertaken to restore the systems to full operational status. A formal report should be provided to the project team within three weeks of completion of the audits. If there are no corrective action items, the auditor may close the audit. If further action is required, the audit will be classified as open pending verification that the corrective action was completed, and the audit specification is met.

The System Manager/Operator team will develop quarterly reports summarizing systems performance and containing the final validated monitoring results for that quarter. Quarterly reports will be due by the end of the month, following the month for which the data were collected. After the quarterly reports have been approved, they will be posted on the Torrance Refinery website for public access.

D. DATA VALIDATION AND USABILITY

D.1 Data Review, Verification, and Validation

Data review, validation and verification procedures are presented in this section. Three types of data are collected for this project:

- Continuous data from the open-path systems;
- Continuous data from the point source monitors; and
- Continuous data from the meteorology sensors.

Data will be declared invalid whenever documented evidence exists demonstrating that a monitor was malfunctioning, or data were collected under non-representative conditions. It should be noted that the monitors are independent of one another for the purpose of documenting invalid data. For example, if the meteorological system is down, the data from an open-path or point source monitor may still be acceptable and reported.

Data reviews and appropriate validations will be performed for each monthly data set under the supervision of the project manager. The data management task leader will verify that the data from the individual monitors are complete for the month. The task leader will then inform the System Manager/Operator when the complete data set is ready.

The activities involved in validation of the data in general include the following:

- Reviewing the site visit logs, calibration data (as appropriate), audit data, and project memoranda for indications of malfunctioning or instrument maintenance events; and
- Examining the monitor and meteorology data for spikes in the data, unusual persistence, unusually high rates of change, or measurement values that seem incongruous with normal measurement ranges and/or diurnal variations. Spectral analysis for selected large or anomalous measurements may be required; and
- Comparing measured concentrations against data from nearby air monitoring stations.

Data are never declared invalid solely because they are unlikely to occur in nature but may be flagged as suspect and be subject to further review until the cause for the apparent anomaly is determined. The results from all quality control and quality assurance checks are evaluated to determine if the DQOs for each instrument are being met.

Evidence of overwhelming measurement bias, external influences on the representativeness of the data, or lack of reproducibility of the measurement data may be cause for the data to be judged invalid.

D.1.1 Open-Path and Point Source Monitors

The open-path and point source monitor measurements and system performance data are obtained continuously via modem. They are reviewed at least daily to verify that the systems are collecting data and that there are no indications of equipment malfunctions. If a problem is detected in the daily reviews, the System Manager/Operator (or his designee) is immediately notified (text or email) so that he can direct the site operator's corrective actions. This contact is documented via email and distributed to the project team so that the situation may be accounted for in the monthly validation process and summary reports.

Spectral data are archived continuously. All other data are archived by on System Manager/Operator network drives so that they are available to post-processing and reporting personnel. Manual spectral

validations are performed on data above the action levels listed in Table 7-3 of the *Torrance Refinery Rule 1180 Fenceline Air Monitoring Plan* (provided in Appendix II). Additional data validations will be performed as needed/required during reporting or times where operations of the open-path systems are suspect.

A conservative approach is taken with the open-path data in that it is accepted as is except under situations where QC indicators are met. The primary QC indicators are past alarms events that have been validated as false positives or any data deemed erroneous due to known system influences or failures.

D.1.2 Meteorology Sensors

The meteorology data are retrieved and subject to manual data review. Certain screening tests, such as those recommended by EPA,²¹ will be performed to aid in identifying data that require further investigation.

D.2 Verification and Validation Methods

The specific checks performed during the automated QA/QC will depend on the parameter and type of instrument. However, the following general types of checks will be performed on all measurements:

- Range checks will confirm the measurement is within pre-defined minimum and maximum values;
- Sticking value checks will be used to flag data for further review;
- Rate of change checks will confirm that subsequent observations change by a reasonable extent and will be used to identify potentially spurious data or instrument failure for further review;
- Sensor codes or alarms generated by the instruments, if available, will be used to validate observation data; and
- The return beam intensity, for open path instruments, will be used to validate data.

Per US EPA guidance on remote sensing for monitoring of ambient pollutants,¹⁸ there are four levels of data validation: level 0, 1, 2 and 3. These levels are described below along with specific validation activities that will be performed to ensure validity and usability of the fenceline data collected from the open path and fixed-point monitors.

Level 0 verification includes review of raw calibration data and initial setup observation prior to collecting field data. It also includes field observation of the equipment setup and function.

Calibration data from the open path analyzers, fixed point monitors and meteorological system will be reviewed after each verification check has been performed to ensure they satisfy requirements set forth in this QAPP, SOPs or operation manuals for the following criteria:

- Calibrations are performed on schedule;
- Calibrations are performed in the proper sequence;
- Calibration standards reflect conditions expected during operational measurements; and

²¹ *On-Site Meteorological Program Guidance for Regulatory Modeling Applications*, U.S. Environmental Protection Agency, February 2000. EPA-454/R-99-5. See <https://www3.epa.gov/scram001/guidance/met/mmqrma.pdf> (accessed August 2019).

- Linearity checks or other checks were performed to ensure the measurement system was stable during calibration.

Monthly visual field inspections will also be performed to visually verify performance of monitors as follows:

- The equipment is operational and optical data was being collected and stored;
- The equipment is aimed correctly, and the collected data is different from zero or full saturation; and
- There are no anomalies in the time-series of data collected by the monitors or meteorological sensors.

These inspections will be logged and kept on file for audit inspections or other review.

Level 1 validation involves downloading data from the measurement systems/instruments and reviewing variables calculated as part of the QC process. Specific aspects that will be reviewed are the following:

- Whether the signal intensity from the equipment has drifted or diminished relative to the most recent maintenance activity;
- The frequency with which data exceeds the allowable ranges or fails the sticking value check;
- Whether the measurement system contained any data collection failure flags or other indication of anomalous data collection; and
- Whether the range and values of minimum detection limits reported by the instruments are within expected bounds.

Level 2 review entails validating measurement data relative to ancillary measurements and historical data. Calibration logs, audit reports, meteorological measurements, facility activity logs and historical measurement data will be used to perform a manual review to determine whether data flagged as anomalous should be corrected or invalidated. The following checks will be done monthly (at a minimum):

- Trends and excursions in optical data will be reviewed against prevailing wind speed and direction and facility process information;
- During the QA Manager review, data will be plotted, and special attention will be given to unusually low or high outliers or deviations in the minimum measured value from day to day;
- Data completeness and representativeness DQOs will be assessed; and
- Five-minute average data will be reviewed to flag and evaluate rapid changes in value between successive data points.

Level 3 data validation represents the highest level of data review conducted and will be performed by the independent Third-Party QA Assessor. This team will have a basic understanding of the instrument operation and will be familiar with typical results from similar measurement projects.

Level 3 data validation will determine what optical remote measurement data should be invalidated if a serious response problem with the optical technology is detected, or if calibration errors are

identified. The reasons for changes to data quality resulting from the validation process, as well as details of corrective action taken, will be documented. Flags on data will be reviewed to interpret combinations of multiple flags on the data and determine what data should be invalidated.

D.3 Reconciliation with Data Quality Objectives

Periodically throughout the data collection effort, it is the responsibility of the Program Quality Assurance Manager and System Manager/Operator to evaluate the project progress in meeting the client's goals for the measurement data. This evaluation will occur annually at a minimum. Two areas will be reviewed: the performance of the project in respect to the quality goals specified in the QAPP and the limitations (if any) on the measurement data for their intended use. Also, per the Rule 1180 Guidelines, this annual evaluation should also assess the effectiveness of the monitoring plan covering experimental design, representativeness of the data, and peer review. The results of this annual evaluation will be reported to Torrance Refinery.

D.3.1 Assessment of Measurement Performance

As part of the annual review the performance of the monitoring network will be assessed to determine to what extent the measurement data meet the requirements of the data user (client and/or regulatory agency). In Section A.7 on Quality Objectives and Criteria, a discussion of the DQIs was presented in relation to precision, accuracy, completeness, representativeness, and comparability goals for the monitoring effort. Specific quantitative measures of precision, accuracy and completeness were defined for use in estimating the quality of the data set. These measures will be calculated and compared to the project goals.

D.3.2 Data Quality Assessment

If any of the data quality measures indicate performance outside the desired objective (e.g., an audit results outside the project specification or a monthly completeness average less than the annual goal) the data associated with that result are not considered useless. The burden is on the project team to determine the extent to which a quality issue affects the related data, and ultimately how the issue impacts the fitness for use of the data. Most often a single isolated incident in which the performance objective is not met does not automatically render the data useless, but rather slightly reduces the confidence that the measurement is reliable and indicates that increased quality control measures are needed. Any such data for which there is a question of confidence will be appropriately flagged in the database. The DQOs are assessed periodically throughout the monitoring year, and a complete evaluation conducted at the completion of the year. A month in which the completeness statistic for a given monitor is below the objectives is cause for concern and corrective action, but if the other 11 months are within the objective, the confidence in the annual data set should remain high.

Any potential limitations of the validated data set will be identified and communicated. The project team will present all known or potential limitations on the data with each data submittal and will clearly flag any such data so that users may determine if the data should be used for a particular discussion or decision.

APPENDIX I
FENCELINE AIR MONITORING SYSTEM SPECIFICATIONS

DRAFT

Table I-1: Open-path FTIR analyzer specifications

Parameter	Units	Specification	Comment
Analyzer type	None	FTIR	
Wave resolution	cm ⁻¹	0.125 - 32	
Spectral range	cm ⁻¹	550 – 7,800	Range is dependent on supplier
Scan frequency	scans/second	Varies – 0.5 to 2 at 0.5 cm ⁻¹	Scan frequency increases as resolution decreases
Receiver configuration	None	monostatic	
Source type	None	Polaris™ long lifetime source	
Detector type	None	Mercury Cadmium Telluride (MCT)	
Detector cooling type	None	Stirling cyrocooler	
Detector temperature	K	77	
Beam splitter	None	ZnSe	
Interferometer type	None	90° dynamically aligned Michelson interferometer	
Signal to noise ratio	None	100,000:1	
Bench stabilization	None	Dynamic alignment	Algorithm reduces noise
QA gas cell type	None	Internal linear dual pass cell	Cell can be moved into beam path.
Cell Window	None	ZnSe	
Operating Temperature	°C	0 to 60 °C	
Time resolution (averaging time)	Minutes per reading	5 per path	
Power requirement	VAC	110 - 240	
Signal sampling	ADC	24-bit	Used for data acquisition
Output	None	USB	
Material of construction	None	Aluminum with stainless steel fasteners	Robust and ruggedness required

Table I-2: FTIR – ancillary equipment specifications

Parameter	Units	Specification	Comment
Alignment Mechanism/Rotating Pedestal/Auto-positioner			
Type	None	Moog MPT-90	
Mechanism	None	Pan and Tilt Unit	Required to remotely position analyzer
Load capacity	pounds	At least 100	
Pan movement range	°	435°	
Tilt movement range	°	180°	
Operating temperature	°F	5 to 131	Without heaters (heaters not required in southern California weather conditions)
Motor type	None	Stepper	
Communications to pan & tilt		RS232 or LAN to PC	
Communications to sensors		RS232 Analog or LAN pass-through	
Material	None	Housing: 6061-T6 aluminum, stainless steel hardware permanently sealed radial ball bearings	
Retroreflectors			
Configuration	None	Open hollow cubes	Hollow cube retro reflectors have three flat sides that are attached in an orientation so that the reflected beam exits at nearly the same angle of incidence as the incoming beam.
Mounting	None	Rail mounted	
Material (substrate)	None	Polished glass	
Coating	None	Gold coating	
Surface quality	None	80-50 scratch dig	
Adhesion	None	Mil F-48616; Humidity MIL F-48616 or equivalent	
Operating temperature range	°C	-40 to 60	

Table I-2: FTIR – ancillary equipment specifications

Parameter	Units	Specification	Comment
Reflectivity	cm ⁻¹	500 to 15,000	
Array configuration	None	85 to 104 cubes	Varies by path length
Enclosure	None	Customer supplied	
Heater	None	Optional	Can help reduce condensation
Heater power consumption	W	480 maximum	Required 120 VAC, 5 amp, 60 Hz

Table I-3: FTIR – computer and software specifications

Parameter	Specification	Comment
Computer	Windows 7 or above; Memory: 3 GB minimum; Dual Core 2.1 GHz processor; Min. 2 USB ports; Ethernet port; 802.11 b/g/n wireless LAN.	
Software		
Type	Real-time monitoring of pollutants	
Data display	Real-time display of results as well as instrument diagnostics.	
Alarms	User programmable to set alarms when concentrations are greater than thresholds	
Notifications	Ability to send notifications when pollutant concentrations greater than a specified threshold are measured	
Beam intensity	Ability to display beam intensity being measured	
Communication	Compatible with all computer systems and software for data processing	The equipment should be able to communicate alarms, operational parameters and results with a computer.
Remote control	Calibrations and augments done remotely	

Table I-3: FTIR – computer and software specifications

Parameter	Specification	Comment
Smart features	Analytical method customization; Background and interference compensation; Retroactive spectra analysis.	

Table I-4: Open-path UVDOAS analyzer specifications

Parameter	Units	Specification	Comment
Analyzer type	None	open-path UVDOAS	
Receiver configuration	None	monostatic	
Spectrometer resolution	nm	0.5	
UV source		150 W Xenon lamp	
UV source replacement	hours	Every 3000 hours	Minimum expected lifetime; can be longer as long as sufficient light is being emitted
Operational wavelength	nm	210-340	
Beam operating temperature	°C	-20 to 50	
Indoor shelter temperature limits	°C	-15 to 35	
Bench stability	None	Thermally-stabilized	
Operating humidity	%	0 to 95%	
Detector type	None	2048 pixel spectrometer	
QA gas cell	None	8-cm flow-through cell	
Electrical requirements	VAC	110 or 240, single phase, 50-60 Hz, 5 amp maximum	
Time resolution (averaging time)	minutes	5 minutes per reading	
Data acquisition rate	Milliseconds/scan	10-1000	
Data output rate		10 sec – 5 min	User configurable
Output	None	USB	
Material of construction	None	Aluminum with stainless steel fasteners	Robust and ruggedness required

Table I-5: Open-path UVDOAS – ancillary equipment specifications

Parameter	Units	Specification	Comment
<i>Alignment Mechanism / Rotating Pedestal / Auto-positioner</i>			
Type	None	Moog MPT-90	
Mechanism	None	Pan and Tilt Unit	Required to remotely position analyzer
Load capacity	pounds	At least 100	
Pan movement range	°	435°	
Tilt movement range	°	180°	
Operating temperature	°F	5 to 131	Without heaters (heaters not required in southern California weather conditions)
Motor type	None	Stepper	
Communications to pan & tilt		RS232 or LAN to PC	
Communications to sensors		RS232 analog or LAN pass-through	
Material	None	Housing: 6061-T6 aluminum, stainless steel hardware permanently sealed radial ball bearings	
<i>Retroreflectors</i>			
Configuration	None	Open hollow cubes	Hollow cube retro reflectors have three flat sides that are attached in an orientation so that the reflected beam exits at nearly the same angle of incidence as the incoming beam.
Mounting	None	Rail mounted	
Material (substrate)	None	Polished glass	
Coating	None	Enhanced aluminum coating	
Surface quality	None	80-50 scratch dig	
Adhesion	None	Mil F-48616; Humidity MIL F-48616 or equivalent	

Table I-5: Open-path UVDOAS – ancillary equipment specifications

Parameter	Units	Specification	Comment
Operating temperature range	°C	-40 to 60	
Reflectivity	Nm	200-400	
Array configuration	None	27 to 37 cubes	Varies by path length
Enclosure	None	Customer supplied	
Heater	None	Optional	Can help reduce condensation
Heater power consumption	W	480 maximum	Required 120 VAC, 5 amp, 60 Hz.

Table I-6: Open-path UVDOAS – computer and software specifications

Parameter	Specification	Comment
Computer	Windows 7 or above; Memory: 3GB minimum; Dual Core 2.1 GHz processor; Min. 2 USB ports; Ethernet port; 802.11 b/g/n wireless LAN.	
Software		
Type	Real-time monitoring of pollutants	
Data display	Real-time display of results as well as instrument diagnostics.	
Alarms	User programmable to set alarms when concentrations are greater than thresholds	
Notifications	Ability to send notifications when pollutant concentrations greater than a specified threshold are measured	
Beam intensity	Ability to display beam intensity being measured	
Communication	Compatible with all computer systems and software for data processing	The equipment should be able to communicate alarms, operational parameters and results with a computer.
Remote control	Calibrations and augments done remotely	

Table I-6: Open-path UVDOAS – computer and software specifications

Parameter	Specification	Comment
Smart Features	Analytical method customization; Background and interference compensation; Retroactive spectra analysis.	

Table I-7: Aethalometer specifications

Parameter	Units	Specification	Comment
Cartridge filter bypass	None	Required	Filter used for clean air tests, should be replaced once a year.
Electronic data output	None	Single serial output through either RS-232, USB, or Ethernet port.	1200 to 115200 baud.
Calibration kit	None	Neutral density optical filter calibration kit or equivalent	Ability to calibrate the absorptive properties of the instrument
Filter tape material	None	Reinforced glass fiber	Reduce effects of relative humidity.
Flow rate options	Liters per minute	2	
Internal vacuum pump	None	Internal DC powered pump	
Light source	(nm)	LED light sources at different wavelengths	Different wavelengths measure the absorption of different types of carbon (including black carbon at 880 nm).
Power supply	Watts (W)	12 V DC. Universal 100-240 VAC 50/60 Hz input.	12 VDC 8.5 amp output supply included.
Pulse damper	None	Recommended	Decrease pump pulsations to minimize interferences with sensitive measurements.
Resolution	Microgram per cubic meter ($\mu\text{g}/\text{m}^3$)	0.001	
Sample inlet tubing	None	Static Dissipative tubing	Minimize amount of tubing required.
Time base of measurements	Seconds (s)	5-minute time base	

Table I-8: Black carbon analyzers - computer and software specifications

Parameter	Specification	Comment
Computer	Minimum 1 GB, Windows 7	
Software		
Alarms	Operational parameters and analyzer operation issues logged	
Communication	Compatible with all computer systems and software for data processing	
Remote control	Alarm identification and troubleshooting, calibration and flow checks, ability to view real time concentrations remotely	
Data display	Physical display on equipment and remote display of consolidated data	
Data processing	5-minute, 1-hour, 8-hour averaging capabilities, processing of alarms and QA check information	

Table I-9: Hydrogen sulfide UV fluorescence analyzer specifications

Parameter	Units	Specification	Comment
Manufacturer/model	--	Teledyne/API T-101	
Electronic data output	None	RS-232, Ethernet, or USB port capabilities; Capability to transmit analyzer information to software	
Flow rate options	Liters per minute	0.65 - 1	
Light source	(nm)	LED light sources in the range of sulfur dioxide absorption wavelengths	UV light in the range of wavelengths absorbed by sulfur dioxide (190 nm - 230 nm).
Power supply	Watts (W)	100-230VAC, 50/60Hz (auto-switching) – 200-300 W average	Standard US Connection.
Resolution	ppb	1	
Time base of measurements	Seconds (s)	5-minute time base	

Table I-9: Hydrogen sulfide UV fluorescence analyzer specifications

Parameter	Units	Specification	Comment
Operating Temperature	°C	20-30	
Lag time	seconds	25	

DRAFT

TORRANCE REFINERY FENCELINE AIR MONITORING PLAN (REVISION 2, XX/XX/2019)

[The Monitoring Plan will be attached once approved by SCAQMD]

DRAFT

DRAFT