## Proposed Rule 1179.1 NOx Emission Reductions from Combustion Equipment at Publicly Owned Treatment Works Facilities

Working Group Meeting #1 May 2, 2019

### **Agenda**

- O Background
- O Rule development process
- O Current and proposed applicability
- O BARCT assessment
- O Equipment located at POTWs
- O Next Steps



### **Background**

- O Proposed Rule 1179.1 is designed to address NOx emissions from certain combustion equipment at Publicly Owned Treatment Works facilities
- O Publicly owned treatment works (POTWs) are
  - Wastewater treatment or reclamation plants owned or operated by a public entity
  - Includes all operations within the boundaries of the wastewater and sludge treatment plant
- O 30 publicly owned wastewater treatment facilities
- O Addressing NOx combustion equipment in a rule that is specific to POTWs can better tailor requirements to issues that are unique to these facilities

3

### **Unique Characteristics of POTWs**



Use of digester gas



Siloxanes



Potential Effects of SB 1383



Financial Challenges

### **Digester Gas**

- O Digester gas has a lower heating value than natural gas
  - Digester gas ≈ 650 Btu; Natural gas ≈ 1050 Btu\*
  - Lower energy content (Btu) almost twice as much digester gas needed to do the same amount of work as natural gas
- O Digester gas being used to fuel engines, boilers, turbines and fuel cells
- O Digester gas produced from wastewater contains siloxanes
  - Fouls combustion equipment (e.g., engines and turbines)
  - Affects catalyst performance in conventional NOx pollutant control equipment such as Selective Catalytic Reduction (SCR) and Non-Selective Catalytic Reduction (NSCR) technologies

\*Staff Report for Proposed Amended Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines, Appendix G

5

### **Siloxanes**

- O Siloxane combustion causes silicon dioxide forming a glass-like deposit on equipment
  - Increases equipment maintenance
  - May cause significant damage if left unremoved
  - Can make catalyst-based post-combustion controls less effective
- O Gas cleaning technology is available to remove some siloxanes and other impurities
  - 7 out of 10 facilities with engines and/or turbines fueled with digester gas are using gas cleaning technology
  - 2 facilities are using a gas cleaning technology for fuel cell projects


### **Potential Effects of SB 1383**

- O SB 1383 approved by the Governor on September 19, 2016 seeks to reduce short-lived climate pollutants and requires a diversion of food waste to landfills
  - 50% reduction in the level of the statewide disposal of organic waste from the 2014 level by 2020
  - ▼75% reduction in the level of the statewide disposal of organic waste from the 2014 level by 2025
- O An alternative to landfills are POTWs for food processing
  - Some POTWs currently accepting food waste to convert to usable biogas
- O More information is needed to understand the scope of any potential impacts on POTW operations/NOx equipment
  - e.g., digester gas production, more combustion sources, emission impacts, contaminants


7


### **Financial Challenges**

- O POTWs are essential public services that have structured procurement processes
  - Requires approval from governing bodies (e.g., city council, board of directors, board of county supervisors, etc.)
- O Consideration of existing gas-to-energy contracts
- O Unknown costs of accepting organic waste



# Staff encourages early and continued input from all stakeholders throughout the rulemaking process Goal is a proposal that all facilities can comply with and that meets the objectives of the proposed rule Staff encourages facilities to meet with staff to discuss any concerns – unique situations, clarification of provisions, etc. Facilities with unique equipment are encouraged to schedule site visits with staff





### **Regulatory Background**

- O South Coast AQMD Rule 1179 applies to POTWs and has provisions pertaining to volatile organic compounds (VOCs)
- O Combustion equipment at POTWs are currently subject to NOx source-specific rules

RULE	NOx SOURCE-SPECIFIC	
No rule	Turbines	
1146, 1146.1, 1146.2 (Rule 1146 Series)	Boilers	
1110.2	Non-emergency Internal Combustion Engines	
1147	Miscellaneous Combustion Equipment	
1118.1	Non-Refinery Flares	

O The following slides will discuss the current applicability of these rules

13

### **Rule 1134**

- O Applies to stationary gas turbines 0.3 megawatt or larger
- O However, it excludes turbines located at publicly owned treatment works

### **Rule 1146 Series**

- O Rule 1146 and 1146.1 apply to boilers, steam generators, and process heaters
  - Rule 1146 applies to those units ≥ 5 mmbtu/hr
  - Rule 1146.1 applies to those units >2 and <5 mmbtu/hr
- O Rule 1146.2 applies to only natural gas-fired water heaters, boilers, and process heaters ≤ 2 mmbtu/hr
- O Rule 1146 Series is applicable to POTWs only until equipment is subject to a NOx emission limit in a Regulation XI rule adopted or amended after December 7, 2018
  - Upon adoption of Rule 1179.1, the requirements contained in Rule 1146 Series would no longer apply

15

### **Rule 1110.2**

- O Applies to all stationary gaseous and liquid fueled engines over 50 bhp
- O Rule contains:
  - NOx, VOC, and CO limitations
  - Inspection and monitoring (I&M) plans
  - CEMS requirements
- O Currently applicable to engines at wastewater treatment facilities
- O Previous rulemaking assessments (2012 amendments, plus technology assessments) included engines fueled by digester gas
  - Current limit of 11 ppm NOx (corrected to 15% oxygen) has been in effect since January 1, 2017

### **Rule 1147**

- O Regulates NOx emissions from miscellaneous sources
- O Included are dryers, heaters, kilns, furnaces, fryers, afterburners, etc.
- O Includes miscellaneous combustion equipment located at wastewater treatment facilities
- O BARCT assessment to be conducted during 1147 series rulemakings

17

### **Rule 1118.1**

OAddresses non-refinery flares (e.g., fired on digester gas)

OTechnology evaluation conducted as part of the rulemaking

ORule adopted January 4, 2019

١R

### **Proposed Applicability**

OObjective: to capture combustion equipment that has not undergone a recent BARCT analysis

### **OProposed Applicability:**

- Turbines fueled by digester gas produced at POTWs
- Natural gas turbines located at POTWs (none currently exist)
- Boilers fueled by digester gas produced at POTWs
- Natural gas boilers located at POTWs

19

### **Proposed Applicability (continued)**

OStakeholders requesting consideration of engines

- Although Rule 1110.2 represents current BARCT, there are other specific operational provisions unique to POTWs that could be addressed in this rule
- OStaff will be exploring options for these unique operational provisions

### **Equipment Not Proposed for Inclusion**

- Staff evaluated the equipment located at the 30 facilities and reviewed:
  - Permits
  - Equipment registrations
  - Inspection reports
- The following NOx combustion equipment were identified:
  - 10 microturbines (permit exempt)
  - 5 hot water heaters (permit exempt)
  - 2 emergency turbines
  - Emergency engines (Rule 1470)
  - Other miscellaneous equipment covered by Rule 1147
- 1 dryer (Rule 1147)
- 2 afterburners (Rule 1147)
- 4 portable engines (1110.2)
- Flares (Rule 1118.1)

21


### **Equipment Not Proposed for Inclusion (continued)**


- O Staff recommends that this equipment not be included in the applicability of Rule 1179.1
  - Not unique to wastewater treatment operations
  - Covered by other rules

BARCT ASSESSMENT		
2,		

### **Purpose of a BARCT Assessment**

- OA Best Available Retrofit Control Technology (BARCT) assessment is conducted periodically for specific sources to identify any potential emission reductions
- OBARCT assessments for some rulemakings were not completed for equipment at POTWs due to their inherent uniqueness
  - Rule 1134 (turbines) and Rule 1146 series (boilers)
- OBARCT assessments will be continued from these previous rulemakings





### **Equipment Breakdown**

- O Before assessing regulatory requirements and emission limits of existing units, staff conducted an initial review of specific combustion equipment located at POTWs
- O Staff reviewed:
  - Type of equipment (boilers, turbines, and engines)
    - Fuel type
    - Size
    - Number of units

27


### **Boilers**

- O 52 Boilers located at POTWs
  - Provide heat for anaerobic digesters
- O Fuel types
  - Digester gas
  - Natural gas
  - Dual fuel (digester or natural gas)

29


## Digester Gas Boilers at POTWs O 9 boilers fueled by digester gas Digester gas units less than 2 mmbtu/hr are meeting 30 ppmv limit (Rule 1146.2) Digester gas units larger than 2 mmbtu/hr are meeting 15 ppmv limit (Rules 1146 and 1146.1) O Need additional information for digester gas limits on some units • Rule 1146.2 applies only to

natural gas



### **Dual Fuel Boilers at POTWs**

- O 36 dual fuel boilers
  - Digester or natural gas fired
- O Dual fuel units are meeting the natural gas and digester gas limits in Rules 1146 and 1146.1
- O Need additional information for digester gas limits on some units
  - Rule 1146.2 applies only to natural gas



### **Turbines**

- O 6 Turbines (2 facilities)
  - Electricity generation
- OUnits meet emission limits specified in permits

Turbines						
Fuel	Size (MW)	Units	NOx Limit (ppmv)			
Digester Gas	15.75	3	18.8			
Digester Gas	18.6	3	25			

<sup>\*</sup>NOx limit corrected to 15% oxygen, by volume on a dry basis

### **Engines**

- O 43 Non-emergency internal combustion engines
  - Electricity generation
  - Pumps
  - Aeration blowers

OSizes range from 200 to 4,200 bhp

Fuel	Size (hp)	Units
Dual fuel Digester gas (primary) and Natural gas	50-500	2
	>500	18
Digester gas	>500	1
Natural gas	50-500	8
	>500	6
Dual Fuel Natural gas (primary) and LPG	50-500	3
	>500	5

33


### **Engines - Summary**

- OBARCT analysis was conducted for engines at POTWs in previous Rule 1110.2 rulemakings
- OMost engines are complying with Rule 1110.2 limits for natural gas and digester gas (11 ppm NOx) and utilize control technology
  - Control equipment used are SCR (w/ gas clean up) and NSCR (3 way catalysts)
  - 2 facilities are under variances and will convert to fuel cell technology, along with electrification and Tecogen technology

### **Emissions Inventory**

### O Emissions summary:

- Facilities using the majority of digester gas for beneficial use
  - Approximately 15% of produced digester gas is flared
- O Majority of emissions from POTWs are from turbines



### **Summary**

- O Proposed Rule 1179.1 is a NOx rule specific to POTWs that addresses their unique operations/equipment
  - Digester gas production, financial constraints, food waste
- O Proposed applicability includes digester and natural gas fueled boilers and turbines
  - Rule 1146 series (boilers) is only applicable until adoption of Rule 1179.1
  - Rule 1134 (turbines) exempts wastewater facilities
- O BARCT assessment on boilers and turbines
  - Other NOx combustion equipment have recent or upcoming BARCT assessments
- O Initial stages of information gathering (types of equipment, emission limits, emissions)

